

The pressure gauge shall be completed with 3/8" BSPP male thread for connection. An isolating cock shall be provided for mounting at the connection.

The wetted parts of the diaphragm type pressure gauge shall be compatible with the fluid measured.

4. OUTPUT CONTACTS

Output contacts where required shall be DPDT contacts rated at 2A 220V 50Hz.

- End of this Specification -