

CONTROLLING OFFICER'S REPLY**DEVB(W)101****(Question Serial No. 1960)**Head: (194) Water Supplies DepartmentSubhead (No. & title): (000) Operational ExpensesProgramme: (1) Water Supply: Planning and DistributionControlling Officer: Director of Water Supplies (C L WONG)Director of Bureau: Secretary for DevelopmentQuestion:

What were the numbers of reports of fresh water main bursts and salt water main bursts in various districts that the Water Supplies Department received in each of the past 3 years? What was the quantity of fresh water wasted each year? What is the progress of Government's Replacement and Rehabilitation Programme for water mains?

Asked by: Hon CHAN Hak-kan (Member Question No. (LegCo use): 50)Reply:

The numbers of water main burst cases in 2015, 2016 and 2017 by districts are tabulated below –

District	Fresh Water			Salt Water		
	2015	2016	2017	2015	2016	2017
Central & Western	4	3	3	3	0	2
Eastern	2	7	6	4	4	6
Islands	3	9	2	0	0	0
Southern	2	3	1	1	1	1
Wan Chai	0	2	6	1	1	2
Kowloon City	9	7	1	16	11	4
Kwun Tong	2	2	0	4	7	6
Sham Shui Po	2	1	2	3	3	1
Wong Tai Sin	2	0	0	4	0	2
Yau Tsim Mong	5	4	1	12	3	3
North	7	1	0	0	1	0
Sai Kung	4	2	1	2	4	2
Sha Tin	6	5	2	2	1	4
Tai Po	3	2	1	12	6	2

Kwai Tsing	8	3	5	6	7	9
Tuen Mun	3	2	0	4	0	6
Tsuen Wan	1	3	2	2	3	2
Yuen Long	6	8	3	0	0	0
Total	69	64	36	76	52	52

The amount of water drained away due to fresh water main bursts was less than 0.01% of the total fresh water supplied.

The programme of replacement and rehabilitation of about 3 000 km water mains was implemented in stages starting from 2000. All stages of the programme were substantially completed by end 2015. The outstanding works remaining include some connections of the newly replaced/rehabilitated water mains to the customers and a few sections of mainlaying works with difficult site conditions due to heavy traffic, congested underground utilities or noise restriction. They are anticipated to be completed within 2018.

- End -

CONTROLLING OFFICER'S REPLY

DEVB(W)102

(Question Serial No. 0718)

Head: (194) Water Supplies Department
Subhead (No. & title): Not Specified
Programme: (2) Water Quality Control
Controlling Officer: Director of Water Supplies (C L WONG)
Director of Bureau: Secretary for Development

Question:

The residues of treatment agents and disinfectants for drinking water may combine with the chemicals in water to form health-affecting chemical substances. In this regard, are regular tests conducted by the Water Supplies Department?

Asked by: Hon CHAN Tanya (Member Question No. (LegCo use): 10)

Reply:

All raw water undergoes stringent treatment processes at the water treatment works in Hong Kong before being supplied to the customers. The Water Supplies Department (WSD) has implemented a comprehensive water quality monitoring programme by taking water samples from water treatment works, service reservoirs, distribution networks and consumers' taps to monitor their water quality including the by-products formed from treatment chemicals and disinfectants to ensure the safety of the drinking water.

According to the monitoring results, the quality of treated water supplied by WSD complies fully with the Hong Kong Drinking Water Standards, which currently adopt the guideline values/provisional guidelines values recommended by the World Health Organization's Guidelines for Drinking-water Quality and the treated water is safe for consumption.

- End -

CONTROLLING OFFICER'S REPLY

DEVB(W)103

(Question Serial No. 0101)

Head: (194) Water Supplies Department

Subhead (No. & title): Not Specified

Programme: (3) Customer Services

Controlling Officer: Director of Water Supplies (C L WONG)

Director of Bureau: Secretary for Development

Question:

What was the number of applications for meters in each of the past 4 years (i.e. from 2014 to 2017)? And, what was the respective number of applications made by the catering industry out of the total? What was the average, longest and shortest time needed respectively for handling applications for meters and completing installation of meters in each year of the same period? And, what were the respective figures for the catering industry? How many complaints about meters were received in each year of the same period? And, what was the respective number of complaints received from the catering industry? What were the respective expenditure and staffing required for processing meter applications for each of the said period and the estimated expenditure and staffing for 2018?

Asked by: Hon CHEUNG Yu-yan, Tommy (Member Question No. (LegCo use): 33)

Reply:

The applications for water supply are mainly for new buildings and from various trades including the catering industry. The whole approval process of the applications for water supply generally involves vetting of plumbing proposals submitted by the applicants, checking of their pipes/fittings proposals and inspection of the completed plumbing works. The Water Supplies Department (WSD) does not readily have information on the time for handling individual processes of these applications, but we can capture the total processing time of the whole approval process, i.e. from first application for water supply to the final approval of the completed plumbing works. The total processing time includes not only the time

taken by WSD to process the application but also the time taken by the applicant for submission of plumbing proposal, revision(s) and supplementary information, and rectification of plumbing works not complying with the requirement. The numbers of applications for water supply, the total processing time, the numbers of staff and associated expenditures involved in processing the applications for new buildings and catering industry in the past four years from 2014 to 2017 are tabulated below.

	2014		2015		2016		2017	
	New Buildings	Catering	New Buildings	Catering	New Buildings	Catering	New Buildings	Catering
Number of applications #	2 510	379	2 224	305	1 871	136	1 303	291
Average total processing time of completed cases in calendar days	155 (12 – 797)^	81 (11 – 444)^	222 (15 – 647)^	129 (15 – 549)^	150 (26 – 325)^	105 (37 – 374)^	146 (15 – 307)^	98 (35 – 302)^
Number of staff and associated expenditure involved in processing the applications##	74 \$25 million		75 \$27 million		98 \$39 million		108 \$45 million	

This represents the number of applications received in that year that have also obtained approval of the completed plumbing works.

Applications from the catering industry are handled together with other applications by the same teams. There is no breakdown of the numbers of staff involved in handling applications from the catering industry.

^ The figures in bracket represent the range of the total processing time in calendar days.

Among the above four years, the average total processing time of applications for water supply in 2015 is comparatively longer. This is mainly due to the implementation of various measures for enhancing drinking water safety in the wake of the excess lead-in-water incident in July 2015. The vetting of applications for water supply involved more procedures and the processing time was therefore lengthened. With a view to shortening the processing time of applications for water supply, the WSD has implemented various measures, including streamlining internal workflow and deploying as well as recruiting additional manpower to handle the applications. These measures have been proved to be effective. The WSD will continue to review and enhance these measures to further shorten the time needed to process applications for water supply.

In addition, the WSD has implemented a pilot scheme in November 2017 to enhance the processing of applications for water supply from the catering industry. As at January 2018, 126 applications have been received under the scheme and among which 20 applications have obtained approval of the completed plumbing works, with an average total processing time of 30 days. Preliminary results of the pilot scheme show that the processing time of applications by the catering industry for water supply can be substantially shortened which is welcomed by the plumbing industry. The WSD will continue to monitor the performance of the pilot scheme. If its effectiveness could sustain, the WSD is prepared to adopt such scheme as a standing arrangement.

The numbers of complaints relating to water meters in 2014, 2015, 2016 and 2017 were 278, 225, 282 and 281 respectively. The complaints mainly concerned defective meter and wrong meter arrangement which had been duly followed up. We do not maintain separate complaint record for the catering industry.

The expenditures associated with the processing of applications for water supply from 2014 to 2017 were shown in the above table and were mainly on staff costs.

The estimated number of staff involved in handling applications for water supply in 2018 is 108 and the associated expenditure is \$46 million.

- End -

CONTROLLING OFFICER'S REPLY

DEVB(W)104

(Question Serial No. 1038)

Head: (194) Water Supplies Department

Subhead (No. & title): Not Specified

Programme: (1) Water Supply: Planning and Distribution

Controlling Officer: Director of Water Supplies (C L WONG)

Director of Bureau: Secretary for Development

Question:

It is mentioned under Programme (1) that the Water Supplies Department will study the feasibility of relocating service reservoirs into caverns. In this regard, please inform this Committee, in a tabular format, of:

1. the location, name and area of the service reservoirs being considered;
2. the future land uses of the released sites;
3. whether there will be a change in water quality after the relocation; if yes, the details of it.

Asked by: Hon HO Kai-ming (Member Question No. (LegCo use): 52)

Reply:

1. Details of service reservoirs being considered for relocation into caverns are tabulated below:

Name	Location	Approximate area of service reservoir(s) (square metre)
Diamond Hill fresh water and salt water service reservoirs	Sha Tin Pass Road, Wong Tai Sin	9 400
Yau Tong fresh water and salt water service reservoirs	Pik Wan Road, Yau Tong	6 000
Yau Tong No. 2 fresh water service reservoir	Ko Chiu Road, Yau Tong	7 300
Tsuen Wan No. 2 fresh water service reservoir	Shing Mun Road, Tsuen Wan	6 550

2. For the relocation of Diamond Hill fresh water and salt water service reservoirs into caverns, feasibility of relocation has been established. At present, we have

consulted the Development Panel of Legislative Council (LegCo) on the funding proposal to upgrade the investigation, design and associated site investigation works related to the relocation to Category A and will seek funding approval from Finance Committee of the LegCo. The future land uses of the released site are subject to a separate planning and engineering study to be carried out in due course.

For the relocation of Yau Tong fresh water and salt water service reservoirs, Yau Tong No. 2 fresh water service reservoir and Tsuen Wan No. 2 fresh water service reservoir into caverns, the relevant feasibility studies are under way. Upon establishing the feasibility of their relocations, the future land uses of the released sites will be considered at a subsequent stage.

3. Relocation of service reservoirs into caverns will not affect the water quality.

- End -

CONTROLLING OFFICER'S REPLY**DEVB(W)105****(Question Serial No. 2872)**Head: (194) Water Supplies DepartmentSubhead (No. & title): Not SpecifiedProgramme: (1) Water Supply: Planning and DistributionControlling Officer: Director of Water Supplies (C L WONG)Director of Bureau: Secretary for DevelopmentQuestion:

It is mentioned under Programme (1) that the Water Supplies Department will implement the total water management strategy with focuses on water conservation and water loss management as well as on development of new water resources. In spite of Department's implementation of Water Intelligent Network (WIN), with the mains aging, many districts encounter main bursts every year. In this regard, please inform this Committee, in tabular format, of:

1. the number of main bursts occurred in each district in Hong Kong in the past 3 years;
2. the average time needed for repair of a main burst in the past 3 years;
3. the quantity in cubic metre of fresh water wasted in each main burst in the past 3 years;
4. the progress and details of the main replacement in the coming year.

Asked by: Hon HO Kai-ming (Member Question No. (LegCo use): 51)Reply:

1. The numbers of fresh and salt water main bursts occurred in the past three years by districts are tabulated below –

District	Fresh Water			Salt Water		
	2015	2016	2017	2015	2016	2017
Central & Western	4	3	3	3	0	2
Eastern	2	7	6	4	4	6
Islands	3	9	2	0	0	0
Southern	2	3	1	1	1	1
Wan Chai	0	2	6	1	1	2
Kowloon City	9	7	1	16	11	4
Kwun Tong	2	2	0	4	7	6
Sham Shui Po	2	1	2	3	3	1

District	Fresh Water			Salt Water		
	2015	2016	2017	2015	2016	2017
Wong Tai Sin	2	0	0	4	0	2
Yau Tsim Mong	5	4	1	12	3	3
North	7	1	0	0	1	0
Sai Kung	4	2	1	2	4	2
Sha Tin	6	5	2	2	1	4
Tai Po	3	2	1	12	6	2
Kwai Tsing	8	3	5	6	7	9
Tuen Mun	3	2	0	4	0	6
Tsuen Wan	1	3	2	2	3	2
Yuen Long	6	8	3	0	0	0
Total	69	64	36	76	52	52

2. The average time needed for repair of a main burst in the past three years is tabulated below—

	Fresh Water			Salt Water		
	2015	2016	2017	2015	2016	2017
Average time needed for repair of a main burst (hours)	8.1	10.0	10.0	17.0	19.4	20.0

In 2016 and 2017, the average time needed for repair of a main burst has increased due to the more congested underground conditions with lots of utilities, making repair of the water mains more difficult. Besides, there were occasions when adjacent sections of water mains were found to be in unsatisfactory condition and had to be replaced, resulting in longer repair time.

As regards the longer average time needed for repair of a salt water main burst, in addition to the above factors, there were cases when the repair of the salt water main bursts was deferred to minimise the traffic impact in the daytime or noise nuisance at night-time, thus lengthening the repair time of salt water mains.

3. The average amount of water drained away due to a fresh water main burst in the past three years is tabulated below –

	Fresh Water		
	2015	2016	2017
Average amount of water drained away due to a fresh water main burst (cubic metre)	1,097	914	543

4. The programme of replacement and rehabilitation (the programme) of about 3 000 kilometres aged water mains was implemented in stages starting from 2000. All stages of the programme were substantially completed by end 2015. Given the much

improved condition of the water supply network after completion of the programme, the Water Supplies Department considers it will be more effective to sustain the healthiness of the network by a continuous risk-based assessment of the water mains on their need for improvement works including reprovisioning. The risk-based assessment comprises a review of the consequence and probability of failure of the water mains which takes into account various factors such as population and customers served, location, material, age, failure record, pipe size, etc. Based on the risk-based approach, a total of about 40 kilometres of water mains of high-risk or repeated failures will be reprovisioned in 2018-19.

- End -

CONTROLLING OFFICER'S REPLY

DEVB(W)106

(Question Serial No. 2874)

Head: (194) Water Supplies Department

Subhead (No. & title): (000) Operational Expenses

Programme: Not Specified

Controlling Officer: Director of Water Supplies (C L WONG)

Director of Bureau: Secretary for Development

Question:

It is mentioned in the Programme under the Budget that, as at 31 March 2018, there will be 4 483 posts in the establishment of the Water Supplies Department (WSD). Please inform this Committee of:

1. the WSD's establishment, the strength, and the numbers of vacancies and their percentage share by nature of work (categories of Water Supply, Water Quality Control, and Customer Services), duty/rank, and mode of employment in the past 3 years;
2. the WSD's increases in establishment and the involved expenditure by nature of work (categories of Water Supply, Water Quality Control, and Customer Services), duty/rank, mode of employment, and amount of salary in the past 3 years and the coming 1 year.

Asked by: Hon HO Kai-ming (Member Question No. (LegCo use): 50)

Reply:

1. The establishment in the Water Supplies Department (WSD) of various grades as categorised by types of duties in the past three years is tabulated below:

Types of Duties	Grade [#]	Establishment		
		2015-16 (As at 31 March 2016)	2016-17 (As at 31 March 2017)	2017-18 (Estimated as at 31 March 2018)
Water Supply	Directorate Grades	12	12	12
	Professional Grades	265	264	263
	Technical Grades	1 445	1 444	1 449
	General Grades/Common	1 169	1 168	1 168

Types of Duties	Grade [#]	Establishment		
		2015-16 (As at 31 March 2016)	2016-17 (As at 31 March 2017)	2017-18 (Estimated as at 31 March 2018)
	Grades			
Sub-total:		2 891	2 888	2 892
Water Quality Control	Directorate Grades	1	1	3
	Professional Grades	27	33	36
	Technical Grades	80	91	98
	General Grades/Common Grades	28	29	32
Sub-total:		136	154	169
Customer Services	Directorate Grades	1	1	1
	Professional Grades	28	34	35
	Technical Grades	427	438	439
	General Grades/Common Grades	510	510	520
Sub-total:		966	983	995
Management and Support	Directorate Grades	9	9	9
	Professional Grades	13	12	12
	Technical Grades	13	14	14
	General Grades/Common Grades	379	386	392
Sub-total:		414	421	427
Total:		4 407	4 446	4 483

involving around 100 ranks in the WSD

We do not have the breakdown of strength and vacancies as categorised by types of duties. The strength / vacancies and the vacancy rates in the WSD of various grades in the past three years are tabulated below:

Grade [#]	2015-16 (As at 31 March 2016)		2016-17 (As at 31 March 2017)		2017-18 (Estimated as at 31 March 2018)	
	Strength [*]	Vacancy (%)	Strength [*]	Vacancy (%)	Strength [*]	Vacancy (%)
Directorate Grades	22	1 (4.3)	25	-2 (N/A)	22	3 (12.0)
Professional Grades	341	-8 (N/A)	348	-5 (N/A)	351	-5 (N/A)
Technical Grades	1 926	39 (2.0)	1 942	45 (2.3)	1 941	59 (3.0)
General Grades/ Common Grades	1 656	430 (20.6)	1 609	484 (23.1)	1 736	376 (17.8)
Total:	3 945	462 (10.5)	3 924	522 (11.7)	4 050	433 (9.7)

involving around 100 ranks in the WSD

* staff are appointed on civil service terms; the strength may be greater than the establishment in some grades, thus giving a negative figure in the vacancy in the above table, mainly due to the inclusion of officers on pre-retirement leave in the strength figures.

2. The draft Estimates sought to increase the establishment ceiling by 27 and 45 non-directorate posts for 2015-16 and 2016-17 respectively. The draft Estimate for 2017-18 sought to increase the establishment ceiling by 20 non-directorate posts, comprising the creation of 23 posts and the lapse of three time-limited posts, and create two directorate posts (subject to the approval of the Legislative Council Finance Committee). The net increase of posts is therefore 22. The draft Estimate for 2018-19 seeks to increase the establishment ceiling by 83 non-directorate posts, comprising the creation of 84 posts and the lapse of one time-limited post, resulting in a net increase of 83 posts.

The additional posts envisaged in the draft Estimates and categorised by types of duties and their salaries are tabulated below. These do not include the creation or deletion of non-directorate posts by the Director of Water Supplies under delegated power, subject to the condition that the notional annual mid-point salary value specified in the relevant draft Estimate is not exceeded:

2015-16

Types of Duties	Rank	Number of Posts	Notional Annual Mid-point Salary Value of the Rank (\$million)
Water Supply	Engineer/ Assistant Engineer	1	0.674
Customer Services	Waterworks Inspector	1	0.594
	Assistant Waterworks Inspector	5	0.373
	Consumer Services Inspector	8	0.279
	Works Supervisor II	6	0.247
	Assistant Clerical Officer	6	0.233
Total:		27	

2016 -17

Types of Duties	Rank	Number of Posts	Notional Annual Mid-point Salary Value of the Rank (\$million)
------------------------	-------------	------------------------	---

Types of Duties	Rank	Number of Posts	Notional Annual Mid-point Salary Value of the Rank (\$million)
Water Supply	Engineer/ Assistant Engineer	1	0.702
Water Quality Control	Senior Engineer	1	1.309
	Senior Mechanical Engineer	1	1.309
	Senior Waterworks Chemist	1	1.309
	Waterworks Chemist	2	0.851
	Engineer/ Assistant Engineer	4	0.702
	Mechanical Engineer/ Assistant Mechanical Engineer	2	0.702
	Waterworks Inspector	4	0.622
	Engineering Laboratory Technician I	3	0.517
	Assistant Waterworks Inspector	2	0.391
	Consumer Services Inspector	6	0.291
	Engineering Laboratory Technician II/ Student Engineering Laboratory Technician	6	0.241
	Laboratory Attendant	2	0.203
	Water Sampler	2	0.203
Customer Services	Consumer Services Inspector	2	0.291
Management and Support	Motor Driver	6	0.203
Total:		45	

2017-18

Types of Duties	Rank	Number of Posts	Notional Annual Mid-point Salary Value of the Rank (\$million)
Water Supply	Engineer/ Assistant Engineer	1	0.733
Water Quality Control	Administrative Officer Staff Grade C	1	2.056
	Chief Engineer	1	1.733
	Senior Mechanical Engineer	1	1.364
	Senior Waterworks Chemist	1	1.364
	Engineer/ Assistant Engineer	1	0.733
	Assistant Waterworks Inspector	1	0.409

Types of Duties	Rank	Number of Posts	Notional Annual Mid-point Salary Value of the Rank (\$million)
	Consumer Services Inspector	1	0.305
Customer Services	Systems Manager	1	0.971
	Analyst/ Programmer I	3	0.713
	Accounting Officer II	1	0.451
	Assistant Waterworks Inspector	1	0.409
	Assistant Clerical Officer	6	0.255
Management and Support	Executive Officer II	1	0.472
	Motor Driver	4	0.212
	Total:	25	

Types of Duties	Rank	Number of Posts	Notional Annual Mid-point Salary Value of the Rank (\$Million)
Water Supply	Senior Engineer	1	1.390
	Engineer/ Assistant Engineer	6	0.749
	Electrical Engineer/ Assistant Electrical Engineer	1	0.749
	Waterworks Inspector	1	0.670
	Senior Technical Officer	1	0.584
	Liaison Officer II	1	0.442
	Assistant Waterworks Inspector	2	0.421
	Works Supervisor II	1	0.279
	Technical Officer/ Technical Officer Trainee	1	0.269
	Assistant Clerical Officer	1	0.263
	Artisan	2	0.218
Water Quality Control	Engineer/ Assistant Engineer	2	0.749
	Mechanical Engineer/ Assistant Mechanical Engineer	1	0.749
	Waterworks Inspector	2	0.670
	Engineering Laboratory Technician I	1	0.557
	Assistant Waterworks Inspector	7	0.421
	Consumer Services Inspector	6	0.314
	Works Supervisor II	1	0.279
	Engineering Laboratory Technician II/ Student Engineering Laboratory Technician	3	0.260
	Laboratory Attendant	1	0.218
	Water Sampler	3	0.218
	Artisan	3	0.218
	Clerical Assistant	1	0.205
Customer Services	Workman II	2	0.163
	Waterworks Inspector	4	0.670
	Clerical Officer	3	0.421
	Meter Reader I	1	0.314
	Assistant Clerical Officer	10	0.263
	Meter Reader II	1	0.218
Management and Support	Clerical Assistant	5	0.205
	Analyst/ Programmer I	3	0.734
	Analyst/ Programmer II	1	0.486
	Computer Operator I	1	0.401
	Motor Driver	4	0.218
Total:		84	

The above posts are/ will be filled by staff appointed on civil service terms.

- End -

CONTROLLING OFFICER'S REPLY

DEVB(W)107

(Question Serial No. 2171)

Head: (194) Water Supplies Department

Subhead (No. & title): Not Specified

Programme: (2) Water Quality Control

Controlling Officer: Director of Water Supplies (C L WONG)

Director of Bureau: Secretary for Development

Question:

The Water Supplies Department is responsible for water quality control. Regarding the incident of unpleasant odour in the water supplied to Tsuen Wan and Kwai Ching districts on 19 November, please inform this Committee:

1. In the report on the incident, the investigation revealed that the contractor did not seal off the two openings without plastic curtains for air insulation at the locations of the access manholes / cat ladders. Has the Department taken any punitive action against the contractor and made a claim for the additional cost incurred in the incident from the contractor? If yes, what are the details; if no, what are the reasons?

2. The investigation report pointed out that "The site work was supervised by a Works Supervisor II of the WSD. Both the staff responsible for reviewing the material and methodology proposed by the contractor and the staff supervising the work had underestimated the possibility that the VOCs released from the protective coating material in the eastern compartment could get into in the western compartment in operation through the two openings and dissolve in the drinking water." Were the related staff punished for the incident?

3. Did the Department adopt and implement the recommendations given in the report? If yes, what are the details and progress? If not, what are the reasons? How can the recurrence of the incident be prevented?

Asked by: Hon KWOK Ka-ki (Member Question No. (LegCo use): 10)

Reply:

1. The unsatisfactory performance of the contractor has been reflected in its performance report. We are also considering claiming the contractor for the additional cost incurred due to the incident.

2. The incident showed that the staff responsible for reviewing the material and methodology proposed by the contractor and the staff supervising the works lacked the awareness of the possible impact of the maintenance works on drinking water quality. In this connection, we consider that provision of necessary training to the staff is more appropriate than taking disciplinary action against them. To this end, we have already taken steps to strengthen training for front-line staff to enhance their awareness of the possible risks on drinking water quality posed by construction and maintenance works.
3. All improvement measures as recommended in the report have been implemented. We believe that with the implementation of all the recommendation measures, the recurrence of the incident can be effectively prevented.

- End -

CONTROLLING OFFICER'S REPLY

DEVB(W)108

(Question Serial No. 2620)

Head: (194) Water Supplies Department
Subhead (No. & title): Not Specified
Programme: (2) Water Quality Control
Controlling Officer: Director of Water Supplies (C L WONG)
Director of Bureau: Secretary for Development

Question:

The Water Supplies Department (WSD) will continue to review the Waterworks Ordinance (Cap. 102) and Waterworks Regulations (Cap. 102A) to safeguard the drinking water quality through enhanced regulatory control of the inside services. In this regard, would the Government advise this Committee:

- 1 What were the details of the review and the enhancement measures adopted in the past 3 years?
- 2 Will any review targeting at the pollution to the water quality brought forth by emerging contaminant be included? For instance, how to ensure microplastics are kept away from the drinking water system and to prevent the citizens from consuming microplastics from drinking the water supplied by the WSD?

Asked by: Hon KWOK Wai-keung (Member Question No. (LegCo use): 50)

Reply:

1. The Water Supplies Department (WSD) has reviewed and put forth the Waterworks (Amendment) Bill 2017, Waterworks (Amendment) Regulation 2017 and Waterworks (Amendment)(No. 2) Regulation 2017 (collectively referred to as "the Amendments") to enhance the regulatory control of inside services to safeguard the drinking water quality. The Amendments have been approved by the Legislative Council, which have clearly specified the personnel who are allowed to carry out the construction etc. of inside services as well as their responsibilities. The Amendments have also enhanced the enforcement effectiveness by revising the time limit of prosecution by the Water Authority (WA) and empowering the WA to conduct inspection during construction etc. of inside services, thus enhancing the deterrent effect of contravening the Waterworks Ordinance (Cap. 102) (WWO). Furthermore, the Amendments updated the applicable technical requirements and standards for plumbing materials.

WSD is conducting a holistic review of the WWO and the Waterworks Regulations (Cap. 102A) for further enhancing the plumbing material control, process control of construction

of inside services and maintenance of inside services to safeguard drinking water quality.

2. WSD has established a mechanism to review emerging contaminants in drinking water. The mechanism involves literature review conducted by in-house Waterworks Chemists and engagement of consultants to provide regular updates on the latest worldwide development on the subject.

With regard to microplastics in drinking water, WSD has engaged a consultant to conduct a study which has revealed that there is currently no health-related guideline value for microplastics in the World Health Organisation's Guidelines for Drinking-water Quality. Also, according to the latest research findings, the risk associated with microplastics in drinking water on health is insignificant because drinking water is not the major source of human exposure to microplastics. Furthermore, the development of monitoring methodology for microplastics is still in the early stage of research and there is no internationally recognised standard method for monitoring microplastics in drinking water.

WSD will continue to keep in view the international researches and development on microplastics in drinking water.

- End -

CONTROLLING OFFICER'S REPLY

DEVB(W)109

(Question Serial No. 1248)

Head: (194) Water Supplies Department

Subhead (No. & title): Not Specified

Programme: (3) Customer Services

Controlling Officer: Director of Water Supplies (C L WONG)

Director of Bureau: Secretary for Development

Question:

Regarding water main bursts and faults, would the Government inform this Committee:

(a) What were the respective numbers of cases of fresh water and salt water main bursts occurred in the territory in the past 2 years?

(b) Please use the following table to provide the information of cases of fresh water and salt water main bursts occurred in Yuen Long and Tuen Mun districts in the past 2 years:

Incident Date	Location	Type of Water Mains	Cause of Main Bursts	Time taken for Repair

(c) Does the Department have a plan in 2018-19 to replace the fresh water and salt water mains that have experienced main bursts in Yuen Long and Tuen Mun districts? If yes, what is the expenditure involved and what are the details?

Asked by: Hon LEUNG Che-cheung (Member Question No. (LegCo use): 14)

Reply:

(a) The numbers of fresh and salt water main bursts occurred in the territory in the past two years are tabulated below –

Year	Fresh Water	Salt Water	Total

2016	64	52	116
2017	36	52	88

(b) Details of the fresh and salt water main bursts occurred in Yuen Long and Tuen Mun in the past two years are tabulated in **Appendix I**.

(c) The programme of replacement and rehabilitation (the programme) of about 3 000 kilometres aged water mains was implemented in stages starting from 2000. All stages of the programme were substantially completed by the end of 2015. Given the much improved condition of the water supply network after completion of the programme, the Water Supplies Department considers it more effective to sustain the healthiness of the network by a continuous risk-based assessment of the water mains to determine the need for improvement works including re-provisioning. The risk-based assessment comprises a review of the consequence and probability of failure of the water mains taking into account various factors, such as population and customers served, location, material, age, failure record, pipe size, etc.

Based on the risk-based assessment, aged fresh water mains at Wang Yip Street West in Yuen Long and aged salt water mains at Lung Mun Road and Wu Chui Road in Tuen Mun will be re-provisioned in 2018-19 at an estimated expenditure of about \$28 million.

Appendix I

Details of the main bursts occurred in Yuen Long and Tuen Mun in the past two years are tabulated below –

Incident Date	Location	Type of Water Mains	Cause of Main Bursts	Time taken for Repair (hours)
18-Jan-2016	Wang Lee Street, Yuen Long	Fresh	Ground movement	7.2
29-Feb-2016	Yau Shin Street, Yuen Long	Fresh	Damaged by others	11.5*
19-Apr-2016	Wang Yip Street West, Yuen Long	Fresh	Ground movement	10.3*
05-May-2016	Sai Ching Street, Yuen Long	Fresh	Ground movement	7.8
22-May-2016	Fung Cheung Road, Yuen Long	Fresh	Ground movement	9.1*
11-Jun-2016	Shek Pai Tau Road, Tuen Mun	Fresh	Corrosion	13.1
16-Jun-2016	Lung Mun Road, Tuen Mun	Fresh	Ground movement	8.3*
01-Aug-2016	Hop Yick Road, Yuen Long	Fresh	Ground movement	6.8*
11-Aug-2016	Kung Um Road, Yuen Long.	Fresh	Ground movement	11.0*
20-Sep-2016	Leung King Street, Yuen Long	Fresh	Ground movement	7.8
15-Jan-2017	Wu Chui Road, Tuen Mun	Salt	Corrosion	10.0
17-Jan-2017	Tsing Lun Road, Tuen Mun	Salt	Corrosion	8.7
03-Mar-2017	Po Yip Street, Yuen Long	Fresh	Ground movement	10.0
07-Aug-2017	Mai Po Lung, Yuen Long	Fresh	Damaged by others	5.3
18-Apr-2017	Wu Chui Road, Tuen Mun	Salt	Ageing	11.7
19-Apr-2017	Lung Mun Road, Tuen Mun	Salt	Corrosion	29.1
13-Oct-2017	Lung Mun Road, Tuen Mun	Salt	Corrosion	12.3
15-Oct-2017	Ma Tin Road, Yuen Long	Fresh	Ground movement	13.3
19-Dec-2017	Lung Mun Road, Tuen Mun	Salt	Corrosion	18.7

Note(*): There was no water supply interruption in the case.

In the above fresh water main bursts, about half of them did not bring about water supply interruption to customers. For those fresh water main bursts causing water supply interruption, the water suspension was usually localised with only small number of customers affected.

The two salt water main bursts that occurred on 19 April 2017 and 19 December 2017 with much longer time taken for repair were isolated cases mainly due to the need to defer the repair works to avoid causing noise nuisance in the night time. For the former case, additional time was spent on locating the leakage spot and rectifying a defective control valve.

- End -

CONTROLLING OFFICER'S REPLY

DEVB(W)110

(Question Serial No. 2218)

Head: (194) Water Supplies Department

Subhead (No. & title): Not Specified

Programme: (2) Water Quality Control

Controlling Officer: Director of Water Supplies (C L WONG)

Director of Bureau: Secretary for Development

Question:

Regarding the enhanced water quality monitoring programme, please provide the following information:

1. details of the programme, including manpower for manning, resources and procedures of monitoring;
2. what is the expenditure involved in implementing the enhanced water quality monitoring programme?

Asked by: Hon MA Fung-kwok (Member Question No. (LegCo use): 69)

Reply:

1. The Water Supplies Department (WSD) commenced the Enhanced Water Quality Monitoring Programme (Enhanced Programme) in December 2017 for monitoring the drinking water quality at consumers' taps and collecting local water quality data for review of the Hong Kong Drinking Water Standards. Under the Enhanced Programme, the WSD will collect water samples from the drinking water taps of randomly selected premises to test for the contents of the six metals, namely antimony, cadmium, chromium, copper, lead and nickel that could be present in an internal plumbing system.

The WSD will send letters to the consumers of the randomly selected premises to invite them to participate in the programme. Since participation in the Enhanced Programme is non-mandatory, additional premises as back-up will also be invited to ensure that sufficient water samples are collected. Therefore, not all of the invited premises will be visited for collecting water samples.

A sampling period will be stated in the invitation letter, which will usually start two weeks after the date of issue of the invitation letter. A sampling team will visit the selected

premises on any working day during the sampling period from 9 am to 5 pm to collect water samples. The team comprises a water sampler for collection of water samples and a licensed plumber for collection of plumbing information. If consent is obtained from the occupier during the visit, water samples will be collected from one of the drinking water taps in the premises. The water samples include a Tier 1 – Random Day Time (“RDT”) water sample and a Tier 2 – 30-minute stagnation (“30MS”) water sample. The Tier 2 water sample will only be tested if exceedance is found in the Tier 1 water sample to verify the test result. The whole sampling process will take about one hour.

The WSD will inform the consumers the water sampling test result within two weeks after the collection of water samples. The test results of the water samples collected under the Enhanced Programme will also be compiled as water quality statistics and uploaded to the WSD's website on a weekly basis.

At present, the WSD deploys one Senior Waterworks Chemist, two Waterworks Chemists, three Engineering Laboratory Technicians I, six Engineering Laboratory Technicians II, two Laboratory Attendants and two Water Samplers for the implementation of the Enhanced Programme. Additional posts will be created as necessary in 2018-19 to cater for sampling and testing of additional parameters that may be included in the Enhanced Programme.

The WSD has engaged an independent consultant to select premises for invitation to participate in the Enhanced Programme. The consultant also provides licensed plumbers to serve as members of the sampling teams.

2. The estimated expenditures for implementing the Enhanced Programme for monitoring the six metals are \$0.75 million and \$2.25 million in 2017-18 and 2018-19 respectively. These figures include the expenditures on (i) chemicals and consumables for collection and analysis of water samples, (ii) engagement of the independent consultant, and (iii) promotion of the Enhanced Programme.

- End -

CONTROLLING OFFICER'S REPLY

DEVB(W)111

(Question Serial No. 2422)

Head: (194) Water Supplies Department

Subhead (No. & title): Not Specified

Programme: (3) Customer Services

Controlling Officer: Director of Water Supplies (C L WONG)

Director of Bureau: Secretary for Development

Question:

Regarding the programme of "Customer Services", would the Government advise this Committee of:

(a) the measures adopted in 2017-18 and will be adopted in 2018-19 by the Department to enforce, investigate, and prosecute cases related to the Waterworks Ordinance and Waterworks Regulations;

(b) the number of cases contravening the Waterworks Ordinance and Waterworks Regulations handled by the Department in the past 1 year and their nature (list the number of cases and their nature in tabular form); and

(c) the estimates of expenditure and staffing for enforcing the Waterworks Ordinance and Waterworks Regulations?

Asked by: Hon MAK Mei-kuen, Alice (Member Question No. (LegCo use): 41)

Reply:

(a) In 2017-18, the Water Supplies Department (WSD) continued to adopt risk-based inspections and surprise checks to detect suspected contravention cases of the Waterworks Ordinance (Cap. 102) (WWO) and Waterworks Regulations (Cap. 102A) (WWR) at target premises of higher risks based on previous records such as car parks, wet markets, etc. WSD also identified suspected contravention cases through other means, such as complaints received from the public, referrals from other departments, discoveries by WSD staff during the course of carrying out their duties, etc.

The Prosecution Unit of WSD is responsible for the investigation on the suspected cases identified. If a case is confirmed contravening the WWO and/or the WWR, as appropriate, one or more of the following enforcement actions will be made-

- Issuance of repair notices;
- Disconnection of water supply;
- Prosecution; and/or

- Suspension or cancellation of licences of concerned licensed plumbers.

In 2018-19, the WSD will be adopting similar measures against contravention of the WWO and/or the WWR.

- (b) The number of convicted cases of contravention of the WWO and the WWR in the past year is tabulated below-

Relevant Section of WWO or Regulation of WWR	Nature of Contravention	Number of convicted cases
Section 14	Construction, installation, alteration or removal of fire service or inside service without the permission of the Water Authority, or plumbing works not carried out as prescribed	42
Section 15	Construction, installation, alteration or removal of fire service or inside service not carried out by licensed plumbers	25
Section 29	Unlawful taking of water	101
Section 30	Pollution	3
Section 31	Damage to waterworks	17
Regulation 11	Hosepipe connected to inside services without passing through cistern or appliance or apparatus	8
Regulation 23	Installation or use of booster pump without the permission of the Water Authority	2
Regulation 44(b)	Contravention of condition of fishing licence	1
	Total	199

There were also five cases of suspension or cancellation of licences of licensed plumbers due to contravention of the WWO and the WWR in the past year.

- (c) In 2018-19, the estimated number of staff involved in the enforcement of the WWO and the WWR is about 190 and the associated staff cost is about \$66 million.

- End -

CONTROLLING OFFICER'S REPLY

DEVB(W)112

(Question Serial No. 2691)

Head: (194) Water Supplies Department
Subhead (No. & title): Not Specified
Programme: (1) Water Supply: Planning and Distribution
Controlling Officer: Director of Water Supplies (C L WONG)
Director of Bureau: Secretary for Development

Question:

- (a) It is learned that the consultant's report on desalination plant at Tseung Kwan O is supposed to be completed in the end of 2017. What is the latest development? Apart from seawater desalination, are there any specific and feasible measures to reduce the reliance on Dongjiang water?
- (b) Please compare the costs of water produced by desalination (per cubic metre) between Hong Kong and overseas countries (e.g. Singapore, the UK, the USA, Australia, Canada, etc.) in 2017 and explain the differences.
- (c) Please provide the estimates of expenditures on Dongjiang water (including total supply quantities, total water costs and average water costs per cubic metre) in the past 5 years and in 2018-19.
- (d) Please compare the prices of Dongjiang water (per cubic metre) paid by Hong Kong and other Mainland cities (e.g. Shenzhen, Dongguan) which also consume Dongjiang water in the past 5 years and explain the differences.
- (e) Please provide the quantities of the discharge of fresh water to the sea resulting from overflow from reservoirs and the total expenditures involved in the past 3 years.

Asked by: Hon MO Claudia (Member Question No. (LegCo use): 17)

Reply:

(a) The consultants engaged for the first stage of the proposed desalination plant at Tseung Kwan O (TKO) have completed the reference design of the plant. We have prequalified tenderers for the "Design, Build and Operate" contract for the plant in March 2018 and will invite tenders for this contract in due course. We have scheduled to brief members of the Panel on Development of the Legislative Council in April 2018, and seek funding approval of the Finance Committee subsequently with a view to commencing construction of the plant in end 2018 for its commissioning in 2022.

Currently, Hong Kong has a three-pronged water supply system, comprising rainwater from local catchments, imported Dongjiang (DJ) water from Guangdong (GD) Province and seawater for toilet flushing. To cope with the anticipated increase in water demand due to population and economic growth, and to enhance the resilience of our water sources to abate the impact of climate change, we have been implementing a number of water management measures on the supply and demand sides. The measures on the supply side include supplying reclaimed water to the north-eastern part of the New Territories for non-potable uses, and promoting wider use of grey water recycling and/or rainwater harvesting systems under suitable new government projects, apart from seawater desalination. Hong Kong will thus transform from the current three-pronged system into a six-pronged system. On the demand side, we have been extending the salt water supply networks to areas which otherwise consume fresh water for flushing. In addition, we have been striving to promote water conservation including promoting the use of water saving devices through the Water Efficiency Labelling Scheme, education on water conservation in kindergartens and primary schools, and collaboration with various stakeholders in organising activities to raise public awareness on water conservation.

(b) The estimated unit water production cost of the proposed desalination plant at TKO is about \$12-\$13 per cubic metre (m³) (at 2017 price level) including the distribution and customer services costs. If the distribution and customer services costs are excluded, the estimated unit water production cost will be about \$10.2 per m³ (at 2017 price level), which is comparable to those of other countries as set out below.

Country	Unit Production Cost (HK\$ per m³)
Spain (Carboneras)	7.4
Singapore (Singspring)	7.5
Middle East (Israel and Saudi Arabia)	3.9 to 26.3
United States of America	8.9 to 15.7
Australia	13.5 to 50.3

The above is based on information from the International Desalination Association, which excludes distribution and customer services costs. The variations in the unit production cost of the desalinated water in different countries are attributed to a number of factors including the construction cost, the energy cost, the seawater quality and temperature, and the environmental requirements.

(c) In the past five years, the annual supply ceiling in the DJ water supply agreements is 820 million m³. The annual expenditures in the past five years on purchasing DJ water are as follows:

Year	Expenditure (\$ million)	Average Unit Cost (\$ per m³)
2013	3,743.30	4.6
2014	3,959.34	4.8
2015	4,222.79	5.1
2016	4,491.52	5.5

2017	4,778.29	5.8
------	----------	-----

#The average unit cost is determined according to the annual supply ceiling of 820 million m³.

(d) We noticed there are reports stating that the DJ water prices paid by other GD cities which consume DJ water are lower than that paid by Hong Kong. We also noted that these GD cities are making other contributions to the supply and protection of DJ water (such as provision of land for the water supply infrastructures, investments on environmental protection, restricting developments for protection of water resources, etc.). It is therefore not appropriate to directly compare the DJ water prices paid by these cities to the price paid by Hong Kong.

(e) The overflow quantities from impounding reservoirs for these three years were 3.3 million m³ (2015), 28.5 million m³ (2016) and 48.4 million m³ (2017). All overflow water was locally collected rainwater naturally discharged by gravity from small and medium impounding reservoirs during or after heavy rainstorms. There was no overflow of water imported from DJ. The actual overflow quantities of each year depend on a number of factors, including rainfall intensity, rainfall distribution, frequency and duration of heavy rainstorms, etc. For example, the total rainfall in Hong Kong was 1 875 millimetres (mm) in 2015, but was more than 2 500 mm in 2016 and 2017. The collection and overflow of this locally collected rainwater did not result in any additional operation costs of the impounding reservoirs.

Every drop of water is precious. The Water Supplies Department has been exploring various means to reduce overflow from impounding reservoirs, including collaborating with the Drainage Services Department to take forward the Inter-Reservoirs Transfer Scheme. The Scheme involves building a tunnel to transfer the potential discharge from the Kowloon group of reservoirs to the Lower Shing Mun Reservoir. It achieves the dual objectives of reducing overflow into the drainage system for flood protection in the downstream urban areas and enhancing the collection of local yield.

- End -

CONTROLLING OFFICER'S REPLY

DEVB(W)113

(Question Serial No. 0486)

Head: (194) Water Supplies Department

Subhead (No. & title): Not Specified

Programme: (3) Customer Services

Controlling Officer: Director of Water Supplies (C L Wong)

Director of Bureau: Secretary for Development

Question:

Regarding the number of customers of the Water Supplies Department (WSD) and the Meter Reader grade responsible for processing the meter reading work, please provide the following information for 2015-16, 2016-17, 2017-18 and 2018-19 (estimate):

- (a). the number of water meters required reading by Meter Readers;
- (b). the establishment and strength of Meter Readers in the WSD by rank, including Chief Meter Reader, Senior Meter Reader, Meter Reader I and Meter Reader II; and
- (c). please list by rank the average number of customers handled and meters read monthly by a Meter Reader.

Asked by: Hon POON Siu-ping (Member Question No. (LegCo use): 26)

Reply:

(a) The numbers of water meters read by Meter Readers in 2015-16, 2016-17, 2017-18 and 2018-19 (estimate) are tabulated below—

Financial Year	Number of Water Meters
2015-16 (as at 31 March 2016)	2 907 100
2016-17 (as at 31 March 2017)	2 955 377
2017-18 (as at 28 February 2018)	2 985 377
2018-19 (estimate)	3 046 000

(b) The establishment (Est.) and strength (Str.) of Meter Readers, including Chief Meter Reader (CMR), Senior Meter Reader (SMR), Meter Reader I (MRI) and Meter Reader II (MRII), are tabulated below-

Rank	2015-16 (as at 31 March 2016)		2016-17 (as at 31 March 2017)		2017-18 (as at 28 February 2018)		2018-19 (estimate)	
	Est.	Str.	Est.	Str.	Est.	Str.	Est.	Str.
CMR	5	5	5	5	5	5	5	5
SMR	8	8	8	8	10	10	10	10
MRI	53	53	53	53	51	51	52	52
MRII	94	91	94	90	94	85	95	95
Total	160	157	160	156	160	151	162	162

(c) Routine water meter reading for billing is normally performed by MRII three times a year. MRI are responsible for performing special water meter reading for resolution of disputes and investigation purposes. Both CMR and SMR do not perform water meter reading.

The average number of water meters read monthly by each Meter Reader in 2015-16, 2016-17, 2017-18 and 2018-19 (estimate) are tabulated below. However, there is no monthly average of number of customers handled because the number of customers served by a water meter varies significantly.

Financial Year	Average number of water meters read monthly by each staff	
	MRI	MRII
2015-16	140	7 732
2016-17	152	7 860
2017-18	127	7 940
2018-19 (estimate)	N/A ^{Note}	8 016

Note: No estimate could be provided as it depends on the number of special water meter reading required for resolution of disputes and investigation purposes.

- End -

CONTROLLING OFFICER'S REPLY

DEVB(W)114

(Question Serial No. 2038)

Head: (194) Water Supplies Department

Subhead (No. & title): Not Specified

Programme: (2) Water Quality Control and (3) Customer Services

Controlling Officer: Director of Water Supplies (C L WONG)

Director of Bureau: Secretary for Development

Question:

The Water Supplies Department stated that during 2018-19, the Department will continue to review and enhance the control of the construction of the inside service including the review of the Waterworks Ordinance and Waterworks Regulations. Would the Department inform us the staffing responsible for the relevant work and how the work is allocated?

Asked by: Hon SHIU Ka-fai (Member Question No. (LegCo use): 49)

Reply:

In 2018-19, the Water Supplies Department will deploy two teams with a total of 13 professionals to continue to review and enhance the control of the construction of the inside service. One team, namely the Legislative Review Unit, comprising nine posts of professional rank will conduct a holistic review for legislative amendment of the Waterworks Ordinance (Cap. 102) and Waterworks Regulations (Cap. 102A) to enhance the control of the construction of the inside service. Another team comprising four posts of professional rank under the Technical Support Division will review and devise administrative measures as interim arrangement prior to the completion of legislative amendments.

- End -

CONTROLLING OFFICER'S REPLY

DEVB(W)115

(Question Serial No. 2440)

Head: (194) Water Supplies Department

Subhead (No. & title): Not Specified

Programme: (2) Water Quality Control

Controlling Officer: Director of Water Supplies (C L WONG)

Director of Bureau: Secretary for Development

Question:

The Water Supplies Department (WSD) is responsible for water quality control by taking water samples from treatment works, service reservoirs, connection points and customers' taps to ensure that water safety conforms to the standards. Would the WSD provide the information of the past 5 years regarding the maintenance work for treatment works and reservoirs, including the form of maintenance, expenditure, staffing, and number of times?

Asked by: Hon WONG Kwok-kin (Member Question No. (LegCo use): 29)

Reply:

The maintenance works carried out by Water Supplies Department (WSD) for water treatment works and service reservoirs include civil works, such as cleansing of service reservoirs and water storage tanks, replacement of treatment works filter media, repair of joint sealants, etc., as well as maintenance, fault investigation and repair of mechanical and electrical plants, telemetry and Supervisory Control and Data Acquisition equipment and fire service equipment.

These maintenance works are conducted either by the term contractor staff under the supervision of in-house staff or carried out by WSD staff directly. The staffing and expenditure for the past five years are tabulated below:

Year	Number of Staff and Associated Expenditure	Expenditure under Maintenance Term Contracts
2013	158 \$55.6 million	\$242 million
2014	156 \$57.6 million	\$266 million
2015	158 \$61.0 million	\$267 million
2016	156 \$63.0 million	\$280 million

2017	157 \$65.1 million	\$314 million
------	-----------------------	---------------

Over the past five years from 2013 to 2017, WSD on average issued about 1 430 works orders yearly to the term contractors for the maintenance works which were supervised by WSD in-house staff, and carried out about 6 400 planned maintenance works of minor nature yearly by in-house staff directly.

There are currently ten engineers, 18 waterworks inspectors, 28 assistant waterworks inspectors and 101 works supervisors in WSD involved in the supervision of and carrying out the maintenance works for the water treatment works and service reservoirs.

- End -

CONTROLLING OFFICER'S REPLY

DEVB(W)116

(Question Serial No. 1410)

Head: (194) Water Supplies Department

Subhead (No. & title): Not Specified

Programme: (3) Customer Services

Controlling Officer: Director of Water Supplies (C L WONG)

Director of Bureau: Secretary for Development

Question:

1. The Department stated that it will be enforcing the Waterworks Ordinance and Waterworks Regulations including tightening plumbing material control and commissioning requirements of new plumbing installations. What are the details of the tightening of commission requirements?

Asked by: Hon WONG Pik-wan, Helena (Member Question No. (LegCo use): 26)

Reply:

The Water Supplies Department (WSD) has implemented the following measures for tightening commissioning of new plumbing installations:

- (i) A more detailed checklist for inspection of new plumbing installations by the WSD has been devised. An enhanced point penalty system against licensed plumbers for plumbing works not carried out in accordance with requirements has also been implemented.
- (ii) Material check will be carried out for soldered pipe joints during the inspection carried out by the WSD.
- (iii) Systematic flushing will be carried out for new plumbing installations with a view to reducing metal leaching from new pipes and fittings. To ensure that the new plumbing installations have been adequately flushed, 6-hour stagnation water samples are required to be taken for testing of six metals, namely antimony, cadmium, chromium, copper, nickel and lead. This new requirement has become effective since January 2018.

- End -

CONTROLLING OFFICER'S REPLY

DEVB(W)117

(Question Serial No. 1411)

Head: (194) Water Supplies Department

Subhead (No. & title): Not Specified

Programme: (2) Water Quality Control

Controlling Officer: Director of Water Supplies (C L WONG)

Director of Bureau: Secretary for Development

Question:

1. The Department stated that there will be an increase of 33 civil service posts for enhancing drinking water safety. Please list their post titles and terms of reference.

Asked by: Hon WONG Pik-wan, Helena (Member Question No. (LegCo use): 27)

Reply:

The details of the 33 posts to be created in 2018-19 for enhancing drinking water safety are tabulated below: –

Rank	Number of Posts	Duties
Engineer/Assistant Engineer	1	To carry out the enhanced water quality monitoring programme
Waterworks Inspector	1	
Engineering Laboratory Technician II/Student Engineering Laboratory Technician	2	
Laboratory Attendant	1	
Water Sampler	3	
Engineer/Assistant Engineer	1	To promote Water Safety Plan for Buildings
Waterworks Inspector	1	(i) To conduct inspections of plumbing works during construction stage including
Assistant Waterworks Inspector	6	
Consumer Services Inspector	6	

Rank	Number of Posts	Duties
		<p>checking whether the relevant provisions under the Waterworks (Amendment) Ordinance 2018 are complied with by the designated persons (such as licensed plumbers, skill workers, etc.); and</p> <p>(ii) to handle investigations and prosecutions of non-compliance cases, which are anticipated to increase following the extension of the time limit for prosecution under the Waterworks (Amendment) Ordinance 2018.</p>
Mechanical Engineer/ Assistant Mechanical Engineer	1	To operate a new material testing laboratory to provide testing services to support the enhanced surveillance on plumbing products approved by the Water Supplies Department under the General Acceptance System.
Assistant Waterworks Inspector	1	
Works Supervisor II	1	
Artisan	3	
Workman II	2	
Clerical Assistant	1	
Engineering Laboratory Technician I	1	
Engineering Laboratory Technician II/Student Engineering Laboratory Technician	1	
Total:	33	

- End -

CONTROLLING OFFICER'S REPLY

DEVB(W)118

(Question Serial No. 2109)

Head: (194) Water Supplies Department
Subhead (No. & title): Not Specified
Programme: (1) Water Supply: Planning and Distribution
Controlling Officer: Director of Water Supplies (C L WONG)
Director of Bureau: Secretary for Development

Question:

(i) Every year the Government purchases Dongjiang water from the Guangdong authorities. What is the production cost of each step starting from raw water cost, pumping process, treatment by water treatment works to the transmission to the customers' taps?

(ii) Regarding the fresh water from local reservoirs and reclaimed water, what is the production cost of each step in their pumping process, treatment by water treatment works, and transmission to the customers' taps?

Asked by: Hon WONG Pik-wan, Helena (Member Question No. (LegCo use): 69)

Reply:

The breakdown of the unit production cost for locally collected rain water (local water) and Dongjiang (DJ) water at 2016-17 prices are as follows:-

	Unit Cost (\$ per cubic metre)	
	DJ water	Local water
Raw water cost	5.6	-
Collection and delivery to water treatment works	0.6 ¹	
Treatment by water treatment works	1.0 ¹	
Distribution and customer Services	2.9 ¹	
Total Unit Production Cost	10.1	4.5

Note 1 : There is no separate breakdown on these items for DJ water and local water.

The production cost of reclaimed water varies with the quality of treated effluent (for production of the reclaimed water) which depends on the treatment level of the sewage treatment works producing the treated effluent, as well as the extent of supply and distribution network. The estimated unit production cost of reclaimed water to be supplied to Sheung Shui and Fanling using tertiary treated effluent from Shek Wu Hui Sewage

Treatment Works from 2022 onwards for non-potable use is around \$6.4 per cubic metre at 2016-17 price level with a breakdown of \$0.5 per cubic metre and \$5.9 per cubic metre for the costs on production of reclaimed water and distribution and customer services respectively. As the supply of reclaimed water is not for human consumption purpose and the above unit cost on distribution and customer services for the reclaimed water supply for Sheung Shui and Fanling is project specific, a direct comparison with the unit cost on distribution and customer services of local water or DJ water, which is the average cost for the territory wide, is not appropriate.

- End -

CONTROLLING OFFICER'S REPLY

DEVB(W)119

(Question Serial No. 2110)

Head: (194) Water Supplies Department

Subhead (No. & title): Not Specified

Programme: (3) Customer Services

Controlling Officer: Director of Water Supplies (C L WONG)

Director of Bureau: Secretary for Development

Question:

Would the Water Supplies Department provide the number of cases and the total amount of arrears of water charges in the past 5 years by District Council district?

Asked by: Hon WONG Pik-wan, Helena (Member Question No. (LegCo use): 70)

Reply:

The number of cases and the total amount of arrears of water charges in the past five years are tabulated below.

	2013-14	2014-15	2015-16	2016-17	2017-18 (up to 28 February 2018)
Number of Cases	12 257	10 692	11 608	11 611	11 635
Total Amount of Arrears (\$ million)	5.7	5.2	6.0	6.0	5.6

We have no breakdown of such cases by district.

- End -

CONTROLLING OFFICER'S REPLY

DEVB(W)164

(Question Serial No. 5609)

Head: (194) Water Supplies Department

Subhead (No. & title): Not Specified

Programme: (1) Water Supply: Planning and Distribution

Controlling Officer: Director of Water Supplies (C L WONG)

Director of Bureau: Secretary for Development

Question:

1) Please advise on the Government expenditures on and prices for purchasing Dongjiang (DJ) water in the past 5 years; the Government expenditure on and price for purchasing DJ water in 2017-18; the expiry date of the current contract for purchasing DJ water; whether the Government holds regular discussions with the Mainland on the quantity and price of DJ water purchased, and if yes, the details.

2) What is the estimated expenditure on the study of the construction of desalination facilities in 2018-19? If the study findings show that the cost of seawater desalination is lower than that of purchasing DJ water, will the Government immediately review the sources of water supply in Hong Kong and construct the desalination facilities?

Asked by: Hon CHAN Tanya (Member Question No. (LegCo use): 140)

Reply:

1. The expenditures on purchasing Dongjiang (DJ) water in the past five years including 2017 are tabulated below:-

Year	Expenditure on purchasing DJ water (\$ million)	Average Unit Purchase Price[#] (\$/cubic metres)
2013	3,743.30	4.6
2014	3,959.34	4.8
2015	4,222.79	5.1
2016	4,491.52	5.5
2017	4,778.29	5.8

[#]The average unit price is determined according to the annual supply ceiling of 820 million cubic metres.

The current agreement for supply of DJ water commenced on 1 January 2018 and will expire on 31 December 2020. As the current “package deal lump sum” payment approach has been adopted in the DJ water supply agreements for more than ten years since its first application in 2006, it is considered an appropriate time to review the approach. We have thus set up a working group with the Guangdong authorities to take forward the review. The review is expected to be completed before the negotiation for the next supply agreement in 2020.

2. In November 2015, the Water Supplies Department (WSD) commissioned consultants for the design of the first stage of the proposed desalination plant at Tseung Kwan O (TKO). The estimated expenditure of the consultancy study in 2018-19 is \$20.0 million. Although the estimated unit water production cost of the desalination plant is higher than that of using DJ water, desalinated water is not susceptible to climate change (such as unforeseen drought condition) and is unaffected by the keen competition for DJ water resource in the Mainland arising from rapid economic development. We are going to build the first stage of the desalination plant at TKO and will keep under constant review the water supply and demand management measures, including the composition of the various water resources, namely rainwater from local catchment, DJ water, seawater for flushing, desalinated water, reclaimed water and grey water recycling / rainwater harvesting, to ensure water security in Hong Kong.

- End -

CONTROLLING OFFICER'S REPLY

DEVB(W)165

(Question Serial No. 5623)

Head: (194) Water Supplies Department

Subhead (No. & title): Not Specified

Programme: (1) Water Supply: Planning and Distribution

Controlling Officer: Director of Water Supplies (C L WONG)

Director of Bureau: Secretary for Development

Question:

Please advise on the Government expenditures on and prices for purchasing Dongjiang (DJ) water in the past 5 years; the Government expenditure on and price for purchasing DJ water in 2018-2019; the expiry date of the current contract for purchasing DJ water; whether the Government holds regular discussions with the Mainland on the quantity and price of DJ water purchased, and if yes, the details.

What is the estimated expenditure on the study of the construction of desalination facilities in 2018-2019? If the study findings show that the cost of seawater desalination is lower than that of purchasing DJ water, will the Government immediately review the sources of water supply in Hong Kong and construct the desalination facilities?

Asked by: Hon CHAN Tanya (Member Question No. (LegCo use): 154)

Reply:

The expenditures on purchasing (DJ) water in the past five years are tabulated below:-

Year	Expenditure on purchasing DJ water (\$ million)	Average Unit Purchase Price[#] (\$/cubic metre)
2013	3,743.30	4.6
2014	3,959.34	4.8
2015	4,222.79	5.1
2016	4,491.52	5.5
2017	4,778.29	5.8

[#]The average unit price is determined according to the annual supply ceiling of 820 million cubic metres.

The estimated expenditure on purchasing DJ water in 2018 is \$4,792.59 million. The estimated average unit price, determined according to the annual supply ceiling of 820 million cubic metres, is \$5.8 per cubic metre.

The current supply agreement for DJ water commenced on 1 January 2018 and will expire on 31 December 2020. As the current “package deal lump sum” payment approach has been adopted in the DJ water supply agreements for more than ten years since its first application in 2006, it is considered an appropriate time to review the approach. We have thus set up a working group with the Guangdong authorities to take forward the review. The review is expected to be completed before the negotiation for the next supply agreement in 2020.

In November 2015, the Water Supplies Department commissioned consultants for the design of the first stage of the proposed desalination plant at Tseung Kwan O (TKO). The estimated expenditure of the consultancy study in 2018-19 is \$20.0 million. Although the estimated unit water production cost of the desalination plant is higher than that of using DJ water, desalinated water is not susceptible to climate change (such as unforeseen drought condition) and is unaffected by the keen competition for DJ water resource in the Mainland arising from rapid economic development. We are going to build the first stage of the desalination plant at TKO and will keep under constant review the water supply and demand management measures, including the composition of the various water resources, namely rainwater from local catchment, DJ water, seawater for flushing, desalinated water, reclaimed water and grey water recycling / rainwater harvesting, to ensure water security in Hong Kong.

- End -

CONTROLLING OFFICER'S REPLY

DEVB(W)166

(Question Serial No. 5624)

Head: (194) Water Supplies Department

Subhead (No. & title): Not Specified

Programme: (2) Water Quality Control

Controlling Officer: Director of Water Supplies (C L WONG)

Director of Bureau: Secretary for Development

Question:

In 2018-19, will the Government conduct study on the control of prefabricated modular building units with pipes from China to ensure that no harmful substances such as heavy metals exist in the pipes of the units? If yes, what are the details and expenditures involved?

Will the Government review the effectiveness of the Water Safety Plan in 2018-2019? If yes, what are the details and expenditures involved?

Will the Government follow the example of the United Kingdom and establish a Water Regulation Authority for holistic monitoring of Hong Kong's waterworks, including reviewing operation of water suppliers, continuous improvement of waterworks laws and ensuring the compliance of water quality with World Health Organization's guidelines in 2018-2019?

Asked by: Hon CHAN Tanya (Member Question No. (LegCo use): 155)

Reply:

1. The Water Supplies Department (WSD) is conducting an in-house study to formulate a mechanism for inspection and approval of plumbing works in modular building units to be prefabricated outside Hong Kong to ensure their compliance with the requirements in the Waterworks Regulations. It is expected that the study will be completed by end-2018. As in-house professional/technical staff members have been deployed to undertake the study as part of their daily duties, we do not have separate breakdown for the expenditures on the study.

2. The WSD has incorporated the Water Safety Plan (WSP) for WSD in the newly established Drinking Water Quality Management System of WSD (DWQMS), which has been implemented since July 2017. A steering group comprising directorate staff of WSD

will conduct annual review of the DWQMS to take into account findings of regular audits of the DWQMS and experience in overseas and local water safety incidents, and recommend improvement measures to the DWQMS as and when necessary.

The WSD has also launched the Quality Water Supply Scheme for Buildings – Fresh water (Management System) (QMS) since November 2017 to encourage building owners or property management agents to develop and implement WSPs to safeguard water quality in their buildings based on risk management. As the QMS was launched only recently, WSD will review the effectiveness of the WSP for Buildings based on the implementation experience of QMS at an appropriate time with a view to improving the guidelines and templates of the WSP continually.

3. The Government will set up a dedicated team led by a Principal Government Engineer (PGE), the post of which is yet to be created, for monitoring WSD's performance in respect of drinking water safety in an independent manner. Subject to approval of the Finance Committee of the Legislative Council, we plan to create the proposed PGE post in 2018-19.

The dedicated team will carry out its own regular audits and surprise checks, and arrange additional external audits through engaging independent auditing firms, as and when necessary, on WSD's quality system for supplying potable water.

Development Bureau commenced in April 2018 a detailed study on a drinking water safety regulatory regime suitable for Hong Kong. It is expected that the detailed study will take about 18 months to complete. Subject to further development of the regulatory regime, Development Bureau will review the final set-up of the dedicated team in due course.

- End -

CONTROLLING OFFICER'S REPLY

DEVB(W)167

(Question Serial No. 5657)

Head: (194) Water Supplies Department
Subhead (No. & title): Not Specified
Programme: (1) Water Supply: Planning and Distribution
Controlling Officer: Director of Water Supplies (C L WONG)
Director of Bureau: Secretary for Development

Question:

What were the specific expenditures on purchasing Dongjiang (DJ) water and the specific quantities of DJ water purchased in the past 5 years? What were the specific expenditures on treating DJ water in the past 5 years? What were the quantities and values of DJ water discharged into the sea without being used in the past 5 years? What are the estimated expenditure on purchasing DJ water and the estimated quantity of DJ water to be purchased in 2018-2019? What is the estimated expenditure on treating DJ water?

Asked by: Hon CHAN Tanya (Member Question No. (LegCo use): 188)

Reply:

In the past five years, the annual supply ceiling in Dongjiang (DJ) water supply agreements was 820 million cubic metres and the expenditures on purchasing DJ water are tabulated as follows:-

	2013	2014	2015	2016	2017
Expenditure on purchasing DJ water (\$ million)	3,743.30	3,959.34	4,222.79	4,491.52	4,778.29

Raw water entering water treatment works includes both locally collected rain water (local water) and imported DJ water, and they are treated together. Therefore, there is no separate breakdown on the expenditures for the treatment of DJ water. The expenditures on treating raw water in water treatment works in the past five years are tabulated as follows:-

	2013-14	2014-15	2015-16	2016-17	2017-18 (up to Feb 2018)
Recurrent expenditure on treating raw water in water treatment works (\$ million)	256.0	268.2	271.0	280.6	230.5

There was no discharge of DJ water into the sea in the past five years.

In 2018, the estimated expenditure on purchasing DJ water is \$4,792.59 million and the annual supply ceiling in the DJ water supply agreement is 820 million cubic metres.

In 2018-19, it is expected that there will be no major change in the operation mode as well as the recurrent expenditure to be incurred in treating raw water in water treatment works. As explained above, there is also no separate breakdown on the estimated expenditure for treating DJ water alone.

- End -

CONTROLLING OFFICER'S REPLY**DEVB(W)168****(Question Serial No.4498)**Head: (194) Water Supplies DepartmentSubhead (No. & title): Not SpecifiedProgramme: (1) Water Supply: Planning and DistributionControlling Officer: Director of Water Supplies (C L WONG)Director of Bureau: Secretary for DevelopmentQuestion:

Please provide the respective frequency of "water suspension", its duration and reasons in the 18 districts over the past 5 years in table format.

Asked by: Hon CHEUNG Chiu-hung, Fernando (Member Question No. (LegCo use): 628)Reply:

Water supply interruptions caused by operation of the Water Supplies Department are usually due to repair of Government water main bursts and leaks. Such water supply interruptions by districts in the past five years are tabulated below.

District	Fresh Water					Salt Water				
	2013	2014	2015	2016	2017	2013	2014	2015	2016	2017
Central & Western	326	235	242	214	213	171	156	129	106	146
Eastern	218	182	263	247	186	199	140	228	229	183
Islands	283	317	237	326	378	1	0	0	0	1
Southern	267	260	291	289	277	79	56	104	71	83
Wan Chai	312	176	38	56	134	206	137	53	53	132
Kowloon City	264	253	275	231	145	239	177	231	214	167
Kwun Tong	286	231	154	155	106	206	182	122	146	142
Sham Shui Po	151	123	130	108	91	127	121	105	97	68
Wong Tai Sin	76	73	62	61	64	74	72	69	67	61
Yau Tsim Mong	202	218	198	194	172	219	217	182	170	111
North	404	371	505	633	501	0	2	1	1	2
Sai Kung	475	390	428	446	387	33	28	45	31	29
Sha Tin	264	252	256	230	170	98	112	90	64	54
Tai Po	284	314	338	284	195	45	46	47	39	26

District	Fresh Water					Salt Water				
	2013	2014	2015	2016	2017	2013	2014	2015	2016	2017
Kwai Tsing	216	189	187	199	179	163	159	113	165	140
Tuen Mun	325	186	248	165	130	96	53	42	45	66
Tsuen Wan	199	254	243	235	214	116	135	121	145	136
Yuen Long	1 490	1 560	1 525	1 321	1 336	1	1	4	6	19
Total	6 042	5 584	5 620	5 394	4 878	2 073	1 794	1 686	1 649	1 566

The numbers of fresh water supply interruptions that lasted for three hours or less and those lasted for more than three hours in the past five years are tabulated below.

Duration of Fresh Water Supply Interruption	2013	2014	2015	2016	2017
Three hours or less	4 944	4 561	4 593	4 425	3 960
More than three hours	1 098	1 023	1 027	969	918
Total	6 042	5 584	5 620	5 394	4 878

- End -

CONTROLLING OFFICER'S REPLY

DEVB(W)169

(Question Serial No. 4499)

Head: (194) Water Supplies Department

Subhead (No. & title): Not Specified

Programme: (1) Water Supply: Planning and Distribution

Controlling Officer: Director of Water Supplies (C L WONG)

Director of Bureau: Secretary for Development

Question:

Please provide more on the details and implementation timetable of the “Action Plan on Enhancing Drinking Water Safety in Hong Kong”.

Asked by: Hon CHEUNG Chiu-hung, Fernando (Member Question No. (LegCo use): 629)

Reply:

The Government announced the Action Plan for Enhancing Drinking Water Safety in Hong Kong (Action Plan) on 21 September 2017 with a view to safeguarding the drinking water quality in Hong Kong. The Action Plan comprises five components, including (i) drinking water standards and enhanced water quality monitoring programme (Enhanced Programme), (ii) plumbing material control and commissioning requirements for new plumbing installations, (iii) Water Safety Plans (WSP), (iv) publicity and public education, and (v) water safety regulatory regime.

The details of the Action Plan are available on the website of the Water Supplies Department (WSD) (<http://wsd.gov.hk/en/actionplan>). The salient measures of the Action Plan are given below.

The Government has established the Hong Kong Drinking Water Standards which currently adopt the guideline values/provisional guideline values of the World Health Organization's Guidelines for Drinking-water. The WSD commenced the Enhanced Programme in December 2017 to monitor the drinking water quality at consumers' taps and collect local water quality data for review of the Hong Kong Drinking Water Standards for six metals, namely antimony, cadmium, chromium, copper, lead and nickel that could be present in an internal plumbing system.

The WSD has implemented measures to enhance plumbing material control including enhancing its General Acceptance system which pre-approves plumbing products that can meet the statutory material standards. Moreover, the WSD has tightened up the commissioning of new plumbing installations. In the inspection of new plumbing

installations, material check will be conducted for soldered pipe joints. In addition, the WSD introduced in July 2017 a systematic flushing protocol for new plumbing installations with a view to reducing metal leaching from the new pipes and fittings. Furthermore, with effect from January 2018, 6-hour stagnation water samples are required to be taken for testing the content of the six metals mentioned above to ensure that the new plumbing installations have been adequately flushed.

In promoting the WSP for Buildings to building owners and property management agents with a view to preventing the contamination of the internal plumbing systems during their operation, the WSD has developed guidelines and templates to assist building owners and property management agents to develop and implement WSP for their buildings. Also, the WSD launched the Quality Water Supply Scheme for Buildings – Fresh Water (Management System) in November 2017 to encourage building owners and property management agents to participate in the scheme.

The WSD has enhanced publicity and public education on the safe use of water through various channels such as dedicated webpages, leaflets, posters, television and radio Announcements in the Public Interest, public seminars and briefings to different users/stakeholder groups including property management agents and operators of specific premises such as kindergartens, welfare units, schools etc. The WSD will continue with the above publicity and public education measures.

On the front of developing the drinking water safety regime, the Development Bureau (DEVB) commenced a study in April 2018 on a drinking water safety regulatory regime suitable for Hong Kong. Besides, DEVB set up the Drinking Water Safety Advisory Committee in January 2018 with members comprising academics and experts of related fields to give advice to the DEVB on various drinking water safety issues.

- End -

CONTROLLING OFFICER'S REPLY

DEVB(W)170

(Question Serial No. 4307)

Head: (194) Water Supplies Department
Subhead (No. & title): Not Specified
Programme: (2) Water Quality Control
Controlling Officer: Director of Water Supplies (C L WONG)
Director of Bureau: Secretary for Development

Question:

Regarding the Action Plan on Enhancing Drinking Water Safety in Hong Kong, since its implementation up to now, please tabulate: the number of samples tested and their test results, the name list of the public housing estates involved, and the number of the units involved.

Asked by: Hon KWOK Ka-ki (Member Question No. (LegCo use): 261)

Reply:

Since we launched the enhanced water quality monitoring programme (Enhanced Programme) in December 2017, we have collected water samples from 177 premises (up to March 2018) including domestic (in both public and private housing) premises and non-domestic premises. The test results of all the water samples collected complied with the Hong Kong Drinking Water Standards which currently adopt the corresponding guideline values/provisional guideline values of the World Health Organization's Guidelines for Drinking-water Quality. The weekly statistics of the water sampling test results are uploaded to the website of the Water Supplies Department.

Participation in the Enhanced Programme is non-mandatory. In order to avoid any adverse effect to the participation in the Programme, we will not reveal the address of the premises with water samples collected unless there is explicit permission from the relevant parties or protection of public health prevails.

- End -

CONTROLLING OFFICER'S REPLY

DEVB(W)171

(Question Serial No. 4308)

Head: (194) Water Supplies Department

Subhead (No. & title): Not Specified

Programme: (1) Water Supply: Planning and Distribution

Controlling Officer: Director of Water Supplies (C L WONG)

Director of Bureau: Secretary for Development

Question:

Would the Department reply to the following:

- (1) What were the specific expenditures on purchasing Dongjiang (DJ) water and the specific quantities of DJ water purchased in the past 5 years?
- (2) What were the quantities and values of DJ water discharged into the sea without being used in the past 5 years?
- (3) What are the estimated expenditure on purchasing DJ water and the estimated quantity of DJ water to be purchased in 2018-2019?

Asked by: Hon KWOK Ka-kai (Member Question No. (LegCo use): 262)

Reply:

- (1) In the past 5 years, the annual supply ceiling in the Dongjiang (DJ) water supply agreements was 820 million cubic metres and the expenditures on purchasing DJ water were tabulated as follows:-

DJ water	2013	2014	2015	2016	2017
Purchase price (\$ million)	3,743.30	3,959.34	4,222.79	4,491.52	4,778.29

- (2) There was no discharge of DJ water into the sea in the past five years.
- (3) In 2018, the estimated expenditure on purchasing DJ water is \$4,792.59 million and the annual supply ceiling in the DJ water supply agreement is maintained at 820 million cubic metres.

- End -

CONTROLLING OFFICER'S REPLY

DEVB(W)172

(Question Serial No. 4319)

Head: (194) Water Supplies Department

Subhead (No. & title): Not Specified

Programme: (1) Water Supply: Planning and Distribution

Controlling Officer: Director of Water Supplies (C L Wong)

Director of Bureau: Secretary for Development

Question:

During 2018-19, the Water Supplies Department will continue to establish the Water Intelligent Network (WIN). In this regard, please inform this Committee of:

1. the progress of establishing WIN in the 18 districts (in tabular format);
2. whether there is any delay in the relevant works; if yes, the details;
3. the involved expenditure on and staff establishment for establishing WIN;
4. the frequency of main bursts or leakage identified by WIN.

Asked by: Hon KWOK Ka-ki (Member Question No. (LegCo use): 294)

Reply:

1. The Water Supplies Department (WSD) is progressively establishing the Water Intelligent Network (WIN) by setting up District Metering Areas (DMAs) with monitoring and sensing equipment in the fresh water supply distribution networks. Under the WIN, there will be a total of about 2 000 DMAs in the territory. Among them, 1 400 DMAs are either established or being established under other projects to be linked up with the WIN while the remaining 600 DMAs are being implemented in stages. In addition, we are procuring an Intelligent Network Management System (INMS) for continuous monitoring and analysis of the vast amount of network data collected from the DMAs. We aim to commission the INMS by the end of 2019.

As at January 2018, the numbers of DMAs established by districts are tabulated below:

District	Number of DMA established	Total number of DMA
Central & Western	33	41
Eastern	42	47

District	Number of DMA established	Total number of DMA
Southern	83	118
Wan Chai	27	39
Kowloon City	32	56
Kwun Tong	35	118
Sham Shui Po	36	52
Yau Tsim Mong	27	31
Wong Tai Sin	23	45
Islands	24	92
Kwai Tsing	93	120
North	106	171
Sai Kung	236	268
Shatin	51	218
Tai Po	81	120
Tsuen Wan	94	136
Tuen Mun	94	136
Yuen Long	29	192
Total	1 146	2 000

2. The establishment of the 600 DMAs of the WIN began in 2016-17 after WSD obtained funding for setting up 85 DMAs and the procurement of the INMS as stage 1 of the “Implementation of WIN” project. WSD plans to seek funding approval of the Finance Committee (FC) of the Legislative Council in 2018-19 for setting up a further 275 DMAs. Funding approval for the remaining 240 DMAs will be sought from the FC at a later stage. The overall progress of the WIN project is satisfactory.

3. WSD has engaged consultants for the establishment of the 600 DMAs mentioned in paragraph 2 and deployed six in-house staff for the administration and supervision of the consultants and procurement of the INMS. For the on-going establishment of 85 DMAs, the actual expenditure in 2017-18 and the estimated expenditure in 2018-19 are \$25.4 million and \$35 million respectively. Subject to funding approval of the FC, WSD will commence establishing another 275 DMAs and targets to spend an additional \$50 million in 2018-19.

4. By using the established DMAs under the WIN, WSD has detected around 240 water mains leaks in 2017.

- End -

CONTROLLING OFFICER'S REPLY**DEVB(W)173****(Question Serial No. 4321)**Head: (194) Water Supplies DepartmentSubhead (No. & title): Not SpecifiedProgramme: (1) Water Supply: Planning and DistributionControlling Officer: Director of Water Supplies (C L WONG)Director of Bureau: Secretary for DevelopmentQuestion:

The Water Supplies Department is responsible for the operation and maintenance of water supply systems. In this regard, please inform this Committee of:

1. the statistics of frequency of main bursts and leakage in the 18 districts of Hong Kong in the past 5 years: year (2017, 2016, 2015, 2014, 2013)/district, the frequency of bursts, the frequency of leakage;
2. the Replacement and Rehabilitation Programme of Water Mains being carried out / planned in the 18 districts of Hong Kong.

Asked by: Hon KWOK Ka-ki (Member Question No. (LegCo use): 296)Reply:

1. The numbers of water main bursts and leaks in the past 5 years by districts are tabulated below –

District	Burst					Leak				
	2013	2014	2015	2016	2017	2013	2014	2015	2016	2017
Central & Western	7	5	7	3	5	698	566	519	532	556
Eastern	10	3	6	11	12	513	424	589	567	421
Islands	0	6	3	9	2	329	346	306	357	422
Southern	0	3	3	4	2	443	381	458	401	427
Wan Chai	10	4	1	3	8	648	402	114	135	305
Kowloon City	29	15	25	18	5	585	553	605	523	370
Kwun Tong	11	28	6	9	6	584	486	381	384	325

Sham Shui Po	19	6	5	4	3	353	318	312	256	267
Wong Tai Sin	5	5	6	0	2	193	187	163	169	154
Yau Tsim Mong	19	19	17	7	4	522	522	443	422	342
North	1	4	7	2	0	921	816	792	817	791
Sai Kung	28	4	6	6	3	875	670	747	706	603
Sha Tin	16	18	8	6	6	454	441	436	443	358
Tai Po	25	16	15	8	3	529	556	525	467	460
Kwai Tsing	46	17	14	10	14	403	380	336	411	355
Tuen Mun	3	4	7	2	6	603	483	464	384	454
Tsuen Wan	4	4	3	6	4	387	418	388	390	361
Yuen Long	24	12	6	8	3	1 991	1 882	1 832	1 595	1 541
Total	257	173	145	116	88	11 031	9 831	9 410	8 959	8 512

2. The Replacement and Rehabilitation of Water Mains programme, which covered about 3 000 kilometres of water mains in the territory, was implemented in stages starting from 2000 and was substantially completed in end 2015. The outstanding works remaining include some connections of the newly replaced/rehabilitated water mains to the customers and a few sections of mainlaying works with difficult site conditions due to heavy traffic, congested underground utilities or noise restriction. They are anticipated to be completed within 2018.

- End -

CONTROLLING OFFICER'S REPLY

DEVB(W)174

(Question Serial No. 4322)

Head: (194) Water Supplies Department

Subhead (No. & title): Not Specified

Programme: (1) Water Supply: Planning and Distribution

Controlling Officer: Director of Water Supplies (C L WONG)

Director of Bureau: Secretary for Development

Question:

The Water Supplies Department is responsible for the operation and maintenance of water supply systems. In this regard, please inform this Committee of:

1. the information of occasions of urgent water suspension in Tsing Yi district in the past 5 years including the dates, time of onset, time of supply resumption, locations, types of water supply and the areas affected (in tabular format);
2. the current water mains replacement / rehabilitation works in progress or in planning in Tsing Yi district;
3. the current inspection works for pumping stations in progress or in planning in Tsing Yi district; and
4. the progress of establishing the Water Intelligent Network in the supply network of Tsing Yi district.

Asked by: KWOK Ka-ki (Member Question No. (LegCo use): 297)

Reply:

1. Details of the emergency suspension of water supply in the Tsing Yi district in the past five years are tabulated in Appendix I. The majority of the cases involved small diameter water mains and/or affected localized areas. Besides, the duration of suspension for about 69% of the cases affecting fresh water supply was less than three hours.
2. The programme of replacement and rehabilitation (the programme) of about 3 000 kilometres aged water mains was implemented in stages starting from 2000. All stages of the programme were substantially completed by the end of 2015. Given the much improved condition of the water supply network after completion of the programme, the Water Supplies Department considers it more effective to sustain the healthiness of the

network by a continuous risk-based assessment of the water mains to determine the need for improvement works including re-provisioning. The risk-based assessment comprises a review of the consequence and probability of failure of the water mains taking into account various factors, such as population and customers served, location, material, age, failure record, pipe size, etc. Based on the risk-based assessment, water mains at Tsing Yi Road and Ching Hong Road near Mayfair Gardens in Tsing Yi district will be re-provisioned in 2018-19.

3. Regular inspections and routine maintenance are carried out for all pumping stations in the Tsing Yi district. Emergency maintenance will be carried out as and when required.

4. Under the Water Intelligent Network, there will be a total of 38 District Metering Areas (DMAs) in the Tsing Yi district. 35 DMAs have been completed and the remaining three are expected to be completed progressively by 2021.

(A) Fresh Water Supply Suspensions in Tsing Yi due to Emergency Repair of Water Mains from 2013 to 2017

No.	Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
1	16/1/2013	16/1/2013 13:35	16/1/2013 14:05	11 Tsing Yi Heung Sze Wui Road	11 Tsing Yi Heung Sze Wui Road
2	21/1/2013	21/1/2013 17:10	21/1/2013 18:20	9 Fung Shue Wo Village	9 Fung Shue Wo Village
3	29/1/2013	29/1/2013 15:50	29/1/2013 16:30	No.17-18 Chung Mei Lo Uk Village	No.17 Chung Mei Lo Uk Village
4	1/2/2013	2/2/2013 11:30	2/2/2013 16:00	15 Tsing Yi Road	15 Tsing Yi Road
5	6/2/2013	7/2/2013 12:30	7/2/2013 13:00	Cheung Hang Road near Lamp Post FA6481	Cheung Hang Village No.26-45 and Refuse Collect Point
6	7/2/2013	7/2/2013 15:35	7/2/2013 16:35	Tsing Yi Road near Lamp Post TS0964	29-33 Tsing Yi Road
7	4/3/2013	5/3/2013 14:00	5/3/2013 14:45	86 Tai Wong Ha Resite Area	87 Tai Wong Ha Resite Area
8	23/3/2013	23/3/2013 15:00	23/3/2013 16:00	Cheung Hang Village near Lamp Post FA6482	Cheung Hang Village No. 3-6 and Refuse Collection Point
9	15/5/2013	15/5/2013 15:30	15/5/2013 16:00	Tsing Yi Road near Lamp Post BC0033	Esso Petrol Filling Station
10	29/5/2013	29/5/2013 14:50	29/5/2013 16:00	Tam Kon Shan Road Interchange near Lamp Post FC0587	Irrigation supply
11	6/6/2013	6/6/2013 19:35	6/6/2013 21:45	90B Tai Wong Ha Resite Area	90B Tai Wong Ha Resite Area
12	8/6/2013	8/6/2013 11:30	8/6/2013 13:15	No. 31 St. Paul's Village	No. 19-36 St. Paul's Village
13	10/6/2013	10/6/2013 13:00	10/6/2013 13:30	No.19 Tsing Yu New Village	No.19 Tsing Yu New Village
14	4/7/2013	4/7/2013 13:00	4/7/2013 14:00	No.138 Chung Mei Lo Uk Village	No.138 Chung Mei Lo Uk Village
15	4/7/2013	4/7/2013 14:35	4/7/2013 17:50	No.25 Chung Mei Lo Uk Village	No.25 Chung Mei Lo Uk Village
16	5/7/2013	5/7/2013 19:00	5/7/2013 19:30	No.25 Chung Mei Lo Uk Village	No.17-28 Chung Mei Lo Uk Village

No.	Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
17	8/7/2013	9/7/2013 14:40	9/7/2013 15:10	No.7 Tai Wong Ha Resite Village	No.7 Tai Wong Ha Resite Village
18	8/7/2013	12/7/2013 13:10	12/7/2013 13:40	No.21 San Uk Tsuen	No.21 San Uk Tsuen
19	8/7/2013	9/7/2013 10:00	9/7/2013 10:30	No.99 Tai Wong Ha Resite Village	No.99 Tai Wong Ha Resite Village
20	10/7/2013	11/7/2013 10:00	11/7/2013 10:40	81 Tai Wong Ha Resite Area	81 Tai Wong Ha Resite Area
21	12/7/2013	12/7/2013 16:00	12/7/2013 17:30	No.47 Lam Tin Resite Village	No.47 Lam Tin Resite Village
22	14/7/2013	14/7/2013 21:30	15/7/2013 07:40	Sai Tso Wan Road near Lamp Post FB0714	Sai Tso Wan Road, Tsing Tim Street
23	15/7/2013	15/7/2013 18:40	15/7/2013 21:45	Sai Tso Wan Road near Lamp Post FB0714	Sai Tso Wan Road, Tsing Tin Road
24	2/9/2013	2/9/2013 15:15	2/9/2013 18:30	Cheung Tat Road near Lamp Post W1677	Part of Tsing Yi Industrial Centre, Phase 2
25	6/9/2013	6/9/2013 19:00	6/9/2013 20:45	No.89 Tam Kon Shan Road	No.67-77, 79, 83-81, 85 and 87 Tam Kon Shan Road and Public Toilet
26	29/9/2013	29/9/2013 21:05	29/9/2013 21:45	No.29 Lam Tin Resite Village	No.29 of Lam Tin Resite Village
27	4/10/2013	4/10/2013 19:00	4/10/2013 20:30	Tsing Ko Road near Lamp Post AC4512	Tsing Ko Road
28	2/11/2013	3/11/2013 10:30	3/11/2013 12:30	66 Tam Kon Shan Road	66 Tam Kon Shan Road
29	11/11/2013	12/11/2013 10:30	12/11/2013 15:30	Near No.31 St. Paul's Village, Tsing King Road	No.31-36 St. Paul's Village
30	11/11/2013	11/11/2013 23:30	12/11/2013 06:00	No.11 Tsing Yi Heung Sze Wui Road	Tsing Yi Fire Station
31	18/11/2013	19/11/2013 10:00	19/11/2013 11:15	No.58 Chung Mei Lo Uk Village	No.58 Chung Mei Lo Uk Village
32	25/11/2013	25/11/2013 15:30	25/11/2013 17:00	No.20 Tai Wong Ha Resite Village	No.20 Tai Wong Ha Resite Village
33	7/12/2013	7/12/2013 14:00	7/12/2013 16:30	12-14 Yim Tin Kok Village	12-14 Yim Tin Kok Village
34	7/12/2013	7/12/2013 20:00	7/12/2013 21:00	No.20 Lim Tin Resite Village	No.20 Lim Tin Resite Village

No.	Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
35	12/12/2013	12/12/2013 14:30	12/12/2013 16:00	Backlane of No.23 Tai Wong Ha Resite Village	No.23 Tai Wong Ha Resite Village
36	13/12/2013	13/12/2013 15:30	13/12/2013 16:30	Chung Mei Road near Lamp Post W0416	Tsing Yi North Substation
37	14/12/2013	14/12/2013 15:10	14/12/2013 17:00	62 Chung Mei Road	62 Chung Mei Road
38	28/12/2013	30/12/2013 09:35	30/12/2013 11:30	Backlane of No.85 Tai Wong Ha Resite Village	No.85 Tai Wong Ha Resite Village
39	14/1/2014	14/1/2014 14:30	14/1/2014 22:45	Ching Hong Road near Tsing Chin Street	Ching Shing Court, Trade Association School, Po Leung Kuk 1983 School, Po Leung Kuk Mrs. Chan Pak Leung School, Tung Wah Group School
40	27/1/2014	29/1/2014 14:00	29/1/2014 16:00	No.35-36 Tsing Fai San Tsuen	No.35-36 Tsing Fai San Tsuen
41	27/1/2014	28/1/2014 15:30	28/1/2014 16:45	No.10 Tai Wong Ha Resite Village	No.10 Tai Wong Ha Resite Village
42	5/2/2014	5/2/2014 19:40	5/2/2014 23:00	7 Chung Mei Lo Uk Village	7 Chung Mei Lo Uk Village
43	11/2/2014	12/2/2014 15:45	12/2/2014 16:40	5 Fung Shue Wo Village	1-9 Fung Shue Wo Village
44	15/2/2014	15/2/2014 14:00	15/2/2014 17:00	24 & 28 Chung Mei Lo Uk Village	24 & 28 Chung Mei Lo Uk Village
45	13/3/2014	13/3/2014 20:30	14/3/2014 00:30	39 Tsing Yi Road	28-38 Tsing Yi Road
46	28/4/2014	29/4/2014 09:00	29/4/2014 10:50	No.41 Lam Tin Resite Village	No.41 Lam Tin Resite Village
47	18/5/2014	18/5/2014 13:00	18/5/2014 14:00	76 Tai Wong Ha Resite Area	76 Tai Wong Ha Resite Area
48	24/5/2014	24/5/2014 14:30	24/5/2014 15:05	No.E2 Fishermen Village	No.E2 Fishermen Village
49	4/6/2014	5/6/2014 10:00	5/6/2014 12:30	88 Tai Wong Ha Village	88 Tai Wong Ha Village
50	12/6/2014	13/6/2014 15:30	13/6/2014 16:10	45 Cheung Mei Lo Uk Village	37-48 Cheung Mei Lo Uk Village
51	10/7/2014	10/7/2014 17:45	10/7/2014 20:45	62 Chung Mei Road	62 Chung Mei Road

No.	Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
52	12/7/2014	12/7/2014 12:10	12/7/2014 14:00	65 Chung Mei Lo Uk Village	65 Chung Mei Lo Uk Village
53	19/7/2014	19/7/2014 14:30	19/7/2014 17:00	No.16 Chung Mei Village	No.16 Chung Mei Village
54	8/8/2014	9/8/2014 14:00	9/8/2014 16:00	Near No.2B Liu To Village	4 Houses of Liu To Village
55	11/8/2014	11/8/2014 22:00	12/8/2014 05:00	Tsing Nam Street near Tsing Yi Road	Tsing Yi South Fresh Water Service Reservoir
56	12/8/2014	12/8/2014 05:10	12/8/2014 09:00	30 Tsing Yu New Village	Part of Tsing Yu New Village
57	23/8/2014	23/8/2014 11:00	23/8/2014 12:15	68 Chung Mei Lo Uk Village	68 Chung Mei Lo Uk Village
58	21/9/2014	21/9/2014 12:30	21/9/2014 13:30	No.30 Tai Wong Ha Resite Village	No.30 Tai Wong Ha Resite Village
59	24/9/2014	24/9/2014 20:00	25/9/2014 01:00	No.3 Tsing Yu New Village	No.1-4 Tsing Yu New Village
60	18/10/2014	18/10/2014 19:00	18/10/2014 20:30	37 Tsing Yu New Village	33-38 Tsing Yu New Village
61	3/11/2014	3/11/2014 15:25	3/11/2014 15:40	No.24 Tai Wong Ha Resite Village	No.13-24 Tai Wong Ha Resite Village
62	4/11/2014	4/11/2014 21:35	4/11/2014 22:20	16 Tai Wong Ha Resite Area	16 Tai Wong Ha Resite Area
63	15/11/2014	15/11/2014 13:35	15/11/2014 14:05	58 Chung Mei Lo Uk Village	58 Chung Mei Lo Uk Village
64	3/12/2014	3/12/2014 22:30	4/12/2014 03:00	Tsing Yi Road near Lamp Post FB3353	Tsing Yi South Fresh Water Service Reservoir
65	3/12/2014	3/12/2014 17:30	3/12/2014 23:15	No.67 Lam Tin Resite Village	No.45-67 Lam Tin Resite Village
66	4/12/2014	4/12/2014 19:00	4/12/2014 20:30	Tsing Yi Road near Lamp Post FC3396	Tsing Yi South Fresh Water Service Reservoir
67	18/12/2014	18/12/2014 13:35	18/12/2014 15:30	No.25 Fung Shue Wo Resite Village	No.25-28 Fung Shue Wo Resite Village
68	1/1/2015	2/1/2015 09:20	2/1/2015 11:05	No.133 Chung Mei Lo Uk Village	No.133 Chung Mei Lo Uk Village
69	4/1/2015	4/1/2015 14:05	4/1/2015 16:05	No.21 Fung Shue Wo Village	No.17-24 Fung Shue Wo Village
70	14/1/2015	15/1/2015 10:35	15/1/2015 13:05	No.156 Chung Mei Lo Uk Village	No.149-156 Chung Mei Lo Uk Village
71	23/1/2015	23/1/2015 09:30	23/1/2015 20:30	Tsing Yi Road near Lamp Post AC0779	No.1 Tsing Yi Road

No.	Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
72	27/1/2015	27/1/2015 10:15	27/1/2015 12:00	Tsing Yi Hong Wan Road near Lamp Post AC4481	Hong Wan Road Lot No.3678
73	28/1/2015	28/1/2015 14:30	28/1/2015 17:00	No.27 Fung Shue Wo Resite Village	No.27-28 Fung Shue Wo Resite Village
74	2/2/2015	2/2/2015 15:05	2/2/2015 16:00	No.12 Tam Kon Shan Road	No.12 Tam Kon Shan Road
75	5/2/2015	5/2/2015 17:30	5/2/2015 19:00	Tsing Yi Hui Village No.28	Tsing Yi Hui No.25-38
76	16/2/2015	16/2/2015 15:20	16/2/2015 16:05	No.24 Lam Tin Resite Village	No.24 Lam Tin Resite Village
77	17/2/2015	17/2/2015 16:30	17/2/2015 18:05	No.34 Yim Tin Kok Resite Village	No.34 Yim Tin Kok Resite Village
78	19/2/2015	19/2/2015 16:25	19/2/2015 20:00	Cheung Fai Road near Lamp Post W0565	Tsing Yi Salt Water Pumping Station
79	11/3/2015	12/3/2015 13:35	12/3/2015 14:35	No.29 Tai Wong Ha Resite Village	No.30 Tai Wong Ha Resite Village
80	21/3/2015	21/3/2015 17:30	21/3/2015 19:05	No.1 Kau Wa Keng San Village	No.1 Kau Wa Keng San Village
81	24/3/2015	24/3/2015 11:15	24/3/2015 12:45	No.11 Tai Wong Ha Resite Village	No.11 Tai Wong Ha Resite Village
82	28/3/2015	28/3/2015 14:00	28/3/2015 17:30	Sai Tso Wan Road near PH 1857	Kowloon Motor Bus Depot
83	8/4/2015	8/4/2015 11:10	8/4/2015 14:00	No.56 Chung Mei Lo Uk Village	No.56 Chung Mei Lo Uk Village
84	13/4/2015	15/4/2015 09:50	15/4/2015 10:30	No.25 Lam Tin Resite Village	No.25 Lam Tin Resite Village
85	30/4/2015	30/4/2015 10:00	30/4/2015 12:00	No.35 Yim Tin Kok Resite Village	No.35 Yim Tin Kok Resite Village
86	30/4/2015	30/4/2015 15:15	30/4/2015 16:35	No.29 Tai Wong Ha Resite Village	29 Tai Wong Ha Resite Village
87	1/5/2015	1/5/2015 10:00	1/5/2015 18:45	Chung Mei Road near Lamp Post U7277	Cheung Hong Estate, Ching Yeung House, Ching Mui House, Part of Chung Mei Lo Uk Village
88	4/5/2015	4/5/2015 11:00	4/5/2015 12:00	No.88 Tai Wong Ha Resite Village	No.88 Tai Wong Ha Resite Village
89	4/5/2015	4/5/2015	4/5/2015	No.32 Lam Tin	No.21-32 Lam Tin

No.	Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
		15:00	16:30	Resite Village	Resite Village
90	6/5/2015	6/5/2015 14:55	6/5/2015 15:45	Backlane of No.38 Chung Mei Lo Uk Village	No.37-48 Chung Mei Lo Uk Village
91	7/5/2015	7/5/2015 16:00	7/5/2015 16:35	No.10 Lam Tin Resite Village	No.10 Lam Tin Resite Village
92	15/5/2015	15/5/2015 03:30	15/5/2015 19:15	Chung Mei Road near Lamp Post U7279	Part of Chung Mei Lo Uk Village, Tsing Yi Ambulance Depot, Cheung Ching Estate (Ching Mui House, Ching Yeung House), Cheung Hong Estate (Hong Wing Estate, Hong Wah House, Hong Fu House, Hong Kwai House, Hong Wo House and Hong Tai House)
93	21/5/2015	27/5/2015 10:05	27/5/2015 11:05	Sai Tso Wan Road near Tsing Tim Street	Construction Site Office at Sai Tso Wan Road
94	12/6/2015	12/6/2015 10:10	12/6/2015 10:45	No.28 Fung Shue Wo Village	No.28 Fung Shue Wo Village
95	17/6/2015	17/6/2015 10:25	17/6/2015 13:00	No.29 Fung Shue Wo Village	No.29 Fung Shue Wo Village
96	18/6/2015	18/6/2015 15:00	18/6/2015 15:30	No.15 San Uk Resite Village	No.9-21 San Uk Resite Village
97	18/6/2015	18/6/2015 18:00	18/6/2015 18:35	Cheung Fai Road near Tsing Yi Industrial Building	Tsing Yi Industrial Building Block C
98	26/6/2015	26/6/2015 15:05	26/6/2015 16:05	Tsing Nam Street near Fire Hydrant 5050	Part of Tsing Nam Street
99	30/6/2015	30/6/2015 14:30	30/6/2015 15:30	No.35 Tai Wong Ha Resite Village	No.35 Tai Wong Ha Resite Village
100	30/6/2015	30/6/2015 10:00	30/6/2015 11:30	No.83 Tai Wong Ha Resite Village	No.83 Tai Wong Ha Resite Village
101	4/7/2015	4/7/2015 11:00	4/7/2015 11:45	No.1 Tsing Fai San Tsuen	No.1-7 Tsing Fai San Tsuen
102	4/7/2015	4/7/2015 14:00	4/7/2015 15:30	No.3 Tsing Fai San Tsuen	No.1-7 Tsing Fai San Tsuen

No.	Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
103	14/7/2015	15/7/2015 16:30	15/7/2015 20:00	Tsing Yi Industrial Centre Phase 1, Cheung Fai Road	Tsing Yi Industrial Centre phase 1, Cheung Fai Road
104	20/7/2015	21/7/2015 11:45	21/7/2015 13:00	No.11 Chung Mei Village	No.11 Chung Mei Village
105	25/7/2015	25/7/2015 10:30	25/7/2015 12:00	No.1 Tai Wong Ha Resite Village	No.1 Tai Wong Ha Resite Village
106	25/7/2015	25/7/2015 15:30	25/7/2015 16:00	No.21a San Uk Resite Village	No.21a San Uk Resite Village
107	6/8/2015	6/8/2015 18:50	6/8/2015 21:30	No.7 Fung Shue Wo Resite Village	No.5-8 Fung Shue Wo Resite Village
108	10/8/2015	11/8/2015 01:00	11/8/2015 04:30	Cheung Wan Street near Cheung Ho Street	Cheung Wan Street, Cheung Ho Street, Cheung Fai Road, Cheung Tat Road
109	14/8/2015	19/8/2015 09:35	19/8/2015 11:50	No.36 Chung Mei Lo Uk Village	No.36 Chung Mei Lo Uk Village
110	19/8/2015	19/8/2015 01:00	19/8/2015 12:30	Chung Mei Road near Lamp Post U7276	12 Chung Mei Road
111	19/8/2015	19/8/2015 19:00	19/8/2015 23:30	No.21 Chung Mei Road near Lamp Post U7276	No.12 Chung Mei Road
112	21/9/2015	21/9/2015 14:00	21/9/2015 15:00	Sheung Ko Tan Street near Lamp Post U7344	Sheung Ko Tan Street Refuse Collection Point, Hydrant SN1017
113	7/10/2015	7/10/2015 18:00	7/10/2015 19:30	No.62 Fung Shue Wo Resite Village	No.62 Fung Shue Wo Resite Village
114	29/10/2015	29/10/2015 11:15	29/10/2015 13:40	No.62 Tai Wong Ha Resite Village	No.62 Tai Wong Ha Resite Village
115	30/10/2015	3/11/2015 14:00	3/11/2015 15:10	No.21 San Uk Resite Village	No.21 San Uk Resite Village
116	30/10/2015	3/11/2015 10:30	3/11/2015 11:30	No.23 Fung Shue Wo Resite Village	No.21-24 Fung Shue Wo Resite Village
117	30/10/2015	2/11/2015 10:30	2/11/2015 14:00	No.19 Tai Wong Ha Resite Village	No.19 Tai Wong Ha Resite Village
118	13/11/2015	13/11/2015 18:30	13/11/2015 19:20	Liu To Village near Lamp Post V3771	Part of Liu To Village
119	27/11/2015	27/11/2015 16:00	27/11/2015 20:55	Tsing Yi Heung Sze Wui Road	No.13-15 Tsing Yi Heung Sze Wui Road
120	27/11/2015	27/11/2015	28/11/2015	Tsing Yi Heung Sze	No.13-15 Tsing Yi

No.	Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
		21:55	07:30	Wui Road	Heung Sze Wui Road
121	10/12/2015	10/12/2015 11:45	10/12/2015 16:30	No.60 Tsing Yu Street	No.60 Tsing Yu Street
122	12/12/2015	12/12/2015 18:30	12/12/2015 22:30	Tsing Yi Road West near Lamp Post FC4221	Tsing Ma Control Area
123	28/12/2015	28/12/2015 17:00	29/12/2015 10:00	Tsing King Road near Lamp Post FC2249	Po Leung Kuk Castar Primary School, Tsing Yi Park, Tsing Yi Sports Ground, Tsing Yi Swimming Pool
124	4/1/2016	5/1/2016 23:30	6/1/2016 09:30	Tsing Yi Road near Sai Tso Wan Road	Sai Tso Wan Road
125	7/1/2016	7/1/2016 13:45	7/1/2016 15:15	No.59 Tam Kon Shan Road	No.55-65 Tam Kon Shan Road
126	13/2/2016	13/2/2016 11:30	13/2/2016 12:45	Sheung Ko Tan Street near Lamp Post U7344	Refuse Collection Point of Chung Mei Lo Uk Village
127	23/2/2016	23/2/2016 12:30	23/2/2016 15:20	No.14-18 Tsing Tim Street	No.14-18 Tsing Tim Street
128	1/4/2016	1/4/2016 15:30	1/4/2016 17:45	No.53 Lam Tin Resite Village	No.45-67 Lam Tin Resite Village
129	14/4/2016	14/4/2016 17:30	14/4/2016 18:45	Tam Ko Shan Road near Lamp Post AC1725	Hong Kong Cement Tsing Yi Plant
130	20/4/2016	20/4/2016 13:45	20/4/2016 18:30	Chung Mei Road near Lamp Post U7276	No.12 Chung Mei Road
131	15/5/2016	15/5/2016 16:30	15/5/2016 18:30	No.1 San Uk Resite Village	No.1 San Uk Resite Village
132	25/5/2016	25/5/2016 15:15	25/5/2016 17:15	No.15 Fung Shue Wo Resite Village	No.13-16 Fung Shue Wo Resite Village
133	1/6/2016	1/6/2016 10:30	1/6/2016 15:30	Hong Wan Road near Lamp Post AC4481	Open Storage
134	2/6/2016	2/6/2016 20:30	3/6/2016 01:00	Tsing Yi Hong Wan Road near Lamp Post AC4481	Tsing Yi Hong Wan Road
135	8/6/2016	8/6/2016 18:30	8/6/2016 21:10	No.57 Fung Shue Wo Village	No.57 Fung Shue Wo Village

No.	Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
136	19/6/2016	19/6/2016 18:15	19/6/2016 19:00	Cheung Fai Road near Lamp Post FB6122	Tsing Yi Salt Water Pumping Station
137	23/6/2016	27/6/2016 17:20	27/6/2016 19:00	Tsing Yi Heung Sze Wui Road near Lamp Post W4878	Tsing Yi Fire Station
138	4/7/2016	5/7/2016 03:35	5/7/2016 06:00	Tsing Sheung Road near Tsing Yi Road	Tsing Sheung Road
139	11/7/2016	12/7/2016 11:40	12/7/2016 13:00	No.2G Tsing Yi Fishermen Village near Lamp Post VA2473	No.1D-2G Fishermen Village
140	12/7/2016	13/7/2016 09:30	13/7/2016 11:15	No.22-23 Tam Kon Shan Road	No.22-23 Tam Kon Shan Road
141	13/7/2016	13/7/2016 18:00	13/7/2016 23:30	No.18-19 Tam Kon Shan Road	No.8-30 Tam Kon Shan Road
142	16/7/2016	16/7/2016 15:30	16/7/2016 17:00	No.26 Tsing Yi Hui	26-32, 36, 37 Tsing Yi Hui
143	27/7/2016	27/7/2016 15:30	27/7/2016 16:40	No.35 Tsing Yi Hui	No.35 Tsing Yi Hui
144	31/7/2016	31/7/2016 16:30	31/7/2016 21:30	No.28 Tsing Yi Hui	No.28 Tsing Yi Hui
145	3/8/2016	3/8/2016 14:00	3/8/2016 15:00	No.2G Tsing Yi Fishermen Village	No.1D-2G Tsing Yi Fishermen Village
146	15/8/2016	15/8/2016 10:30	15/8/2016 17:30	Chung Mei Road near Lamp Post W4015	Chung Mei Road Setting-out Area
147	22/8/2016	24/8/2016 13:45	24/8/2016 16:00	No.31 Fung Shue Wo Resite Village	No.25-38 Fung Shue Wo Resite Village
148	28/8/2016	28/8/2016 17:45	28/8/2016 20:15	No.28 Fung Shue Wo Village	No.28 Fung Shue Wo Village
149	29/8/2016	30/8/2016 10:00	30/8/2016 12:00	No.3 Fung Shue Wo Resite Village	No.3 Fung Shue Wo Resite Village
150	30/8/2016	2/9/2016 10:00	2/9/2016 11:30	No.7 Tsing Fai San Tsuen	No.1-7 Tsing Fai San Tsuen
151	18/9/2016	18/9/2016 17:15	18/9/2016 19:00	F1 Fishermen Village	D - I Fishermen Village
152	3/10/2016	5/10/2016 09:00	5/10/2016 11:35	No.29 Fung Shue Wo Village	No.29 Fung Shue Wo Village
153	20/10/2016	24/10/2016 11:00	24/10/2016 12:30	Cheung Hang Village near Lamp Post S/CH/2X/071	Part of Cheung Hang Village
154	23/10/2016	24/10/2016	24/10/2016	No.34 Tai Wong Ha	No.34 Tai Wong Ha

No.	Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
		09:00	12:15	Resite Village	Resite Village
155	26/10/2016	26/10/2016 15:30	26/10/2016 16:45	No.32 Tsing Yi Hui	No.25-32 Tsing Yi Hui
156	8/11/2016	8/11/2016 16:45	8/11/2016 17:30	No.23 Tai Wong Ha Resite Village	No.23 Tai Wong Ha Resite Village
157	8/11/2016	9/11/2016 16:00	9/11/2016 19:45	No.15 Tsing Yi Hui	No.13-20 Tsing Yi Hui
158	13/11/2016	13/11/2016 08:00	13/11/2016 11:30	No.21 Tsing Fai San Tsuen	No.21 Tsing Fai San Tsuen
159	13/11/2016	13/11/2016 14:40	13/11/2016 20:30	No.31 Tai Wong Ha Resite Village	No.13-24 Tai Wong Ha Resite Village
160	13/11/2016	13/11/2016 23:00	14/11/2016 03:15	Tsing Sum Street near Lamp Post FA6869	Tai Wong Ha Resite Village
161	14/11/2016	14/11/2016 14:30	14/11/2016 16:30	No.81 Tai Wong Ha Resite Village	No.81 Tai Wong Ha Resite Village
162	14/11/2016	15/11/2016 09:45	15/11/2016 12:15	No.30 Lam Tin Resite Village	No.30 Lam Tin Resite Village
163	14/11/2016	16/11/2016 11:00	16/11/2016 20:30	No.31-33 Cheung Tat Road	Tsing Yi Industrial Centre Phase II
164	18/11/2016	18/11/2016 10:05	18/11/2016 12:10	No.15 Lam Tin Resite Village	No.15 Lam Tin Resite Village
165	18/11/2016	18/11/2016 13:05	18/11/2016 16:10	No.85 Tai Wong Ha Resite Village	No.85 Tai Wong Ha Resite Village
166	21/11/2016	21/11/2016 12:30	21/11/2016 16:45	No.7 San Uk Resite Village	No.5-8 San Uk Resite Village
167	23/11/2016	23/11/2016 18:20	23/11/2016 20:10	No.62 Lam Tin Resite Village	No.62 Lam Tin Resite Village
168	27/11/2016	27/11/2016 10:35	27/11/2016 18:00	No.4 Tai Wong Ha Resite Village	No.1-4 Tai Wong Ha Resite Village
169	4/12/2016	4/12/2016 08:55	4/12/2016 12:45	No.34 Tai Wong Ha Resite Village	No.13-24 Tai Wong Ha Resite Village
170	8/12/2016	9/12/2016 10:00	9/12/2016 16:45	No.32 Tsing Yi Hui	No.25-32 Tsing Yi Hui
171	12/12/2016	12/12/2016 15:50	12/12/2016 20:40	No.9-10 Tai Wong Ha Resite Village	No.9-10 Tai Wong Ha Resite Village
172	14/12/2016	14/12/2016 17:20	14/12/2016 20:50	No.11 Tai Wong Ha Resite Village	No.5-11 Tai Wong Ha Resite Village
173	19/12/2016	20/12/2016 10:05	20/12/2016 11:45	No.35 Yim Tin Kok Resite Village	No.42-35 Yim Tin Kok Resite Village
174	30/12/2016	30/12/2016 16:00	30/12/2016 19:30	No.87 Tai Wong Ha Resite Village	No.87-90 Tai Wong Ha Resite Village

No.	Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
175	1/1/2017	1/1/2017 21:00	2/1/2017 00:01	No.17-18 Tai Wong Ha Resite Village	No.17-18 Tai Wong Ha Resite Village
176	2/1/2017	2/1/2017 16:30	2/1/2017 22:30	No.15-16 Tai Wong Ha Resite Village	No.15-16 Tai Wong Ha Resite Village
177	7/1/2017	8/1/2017 20:15	8/1/2017 21:30	No.20 Tai Wong Ha Resite Village	No.13-24 Tai Wong Ha Resite Village
178	7/1/2017	7/1/2017 04:55	7/1/2017 12:30	No.86 Tai Wong Ha Resite Village	No.86-79 Tai Wong Ha Resite Village
179	19/1/2017	20/1/2017 14:00	20/1/2017 15:00	No.58 Fung Shue Wo Resite Village	No.57-59 Fung Shue Wo Resite Village
180	19/1/2017	20/1/2017 10:15	20/1/2017 10:45	No.11 Tsing Yu New Village	No.9-16, No.25-38, Tsing Yu New Village
181	21/1/2017	21/1/2017 13:00	21/1/2017 15:30	No.60 Lam Tin Resite Village	No.60 Lam Tin Resite Village
182	21/1/2017	21/1/2017 13:30	21/1/2017 15:00	No.32 Lam Tin Resite Village	No.32 Lam Tin Resite Village
183	23/1/2017	23/1/2017 11:00	23/1/2017 15:15	No.64 Lam Tin Resite Village	No.64 Lam Tin Resite Village
184	23/1/2017	25/1/2017 08:45	25/1/2017 12:15	No.60 Tai Wong Ha Resite Village	No.49-60 Tai Wong Ha Resite Village
185	4/2/2017	4/2/2017 15:00	4/2/2017 17:00	46A Yau Kom Tau Tsuen	Yau Kom Tau Tsuen
186	1/3/2017	1/3/2017 13:00	1/3/2017 16:00	No.19 Tai Wong Ha Resite Village	No.19 Tai Wong Ha Resite Village
187	1/3/2017	2/3/2017 09:30	2/3/2017 11:30	No.63 Tam Kon Shan Road	No.63 Tam Kon Shan Road
188	18/3/2017	18/3/2017 17:00	18/3/2017 19:00	No.62 Lam Tin Resite Village	No.62 Lam Tin Resite Village
189	21/3/2017	21/3/2017 09:00	21/3/2017 12:15	No.15A Tsing Fai San Tsuen	No.15A Tsing Fai San Tsuen
190	1/4/2017	1/4/2017 11:05	1/4/2017 14:00	Tsing Yi Hong Wan Road near Lamp Post AC4459	T9 bare chassis lane, HIT Tsing Yi Hong Wan Depot
191	18/4/2017	18/4/2017 16:30	18/4/2017 18:30	No.24 Tam Kon Shan Road	No.20-25 Tam Kon Shan Road
192	22/4/2017	22/4/2017 19:30	22/4/2017 23:00	Refuse Collection Point at Tsing Fai San Tsuen	Refuse Collection Point at Tsing Fai San Tsuen
193	24/4/2017	24/4/2017 18:30	24/4/2017 20:00	Lam Tin Resite Village near Lamp	Lam Tin Resite Village Ancestral

No.	Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
				Post BC1981	Hall
194	24/4/2017	24/4/2017 15:00	24/4/2017 20:15	No.24 Tai Wong Ha Resite Village	No.24 Tai Wong Ha Resite Village
195	10/5/2017	10/5/2017 22:00	10/5/2017 22:30	No.31 Lam Tin Resite Village	No.21-32 Lam Tin Resite Village
196	18/5/2017	19/5/2017 16:10	19/5/2017 18:20	Tsing Keung Street near Lamp Post FA4091	China Merchants Container Service Limited
197	19/5/2017	20/5/2017 11:30	20/5/2017 20:00	Tsing Yi North High Level Fresh Water and Salt Water Pumping Station	Cheung Wang Estate, Cheung Hang Estate, Mount Haven, Liu To Tsuen, Ching Wah Court, Tsing Ma Control Area
198	22/5/2017	22/5/2017 15:35	22/5/2017 17:15	No.84 Chung Mei Lo Uk Village	No.84 Chung Mei Lo Uk Village
199	25/5/2017	29/5/2017 13:45	29/5/2017 15:10	No.60 Lam Tin Resite Village	No.60 Lam Tin Resite Village
200	27/5/2017	29/5/2017 09:30	29/5/2017 11:30	No.17 Lam Tin Resite Village	No.17 Lam Tin Resite Village
201	23/6/2017	27/6/2017 11:15	27/6/2017 14:15	No.59 Chung Mei Lo Uk Village	No.59 Chung Mei Lo Uk Village
202	3/7/2017	3/7/2017 18:45	3/7/2017 22:00	No.25 Lam Tin Resite Village	No.25 Lam Tin Resite Village
203	8/7/2017	8/7/2017 13:45	8/7/2017 18:15	No.23 Tai Wong Ha Resite Village	No.23 Tai Wong Ha Resite Village
204	15/7/2017	15/7/2017 14:00	15/7/2017 17:00	No.40 Tsing Fai San Tsuen	No.32-52 Tsing Fai San Tsuen
205	18/7/2017	19/7/2017 14:00	19/7/2017 15:15	No.35 Fung Shue Wo Village .	No.33-36 Fung Shue Wo Village
206	25/7/2017	26/7/2017 15:00	26/7/2017 17:30	No.5 Tsing Yi Hui Village	No.1-8 Tsing Yi Hui Village
207	28/7/2017	28/7/2017 16:42	28/7/2017 19:40	No.7 Tsing Fai San Tsuen	No.7 Tsing Fai San Tsuen
208	28/7/2017	29/7/2017 10:30	29/7/2017 13:30	No.4 Tsing Yi Hui Village	No.1-4 Tsing Yi Hui Village
209	5/8/2017	5/8/2017 17:30	5/8/2017 21:40	No.26 Fung Shue Wo Tsuen	No.25-29, 37 and 38 Fung Shue Wo Tsuen
210	15/8/2017	16/8/2017 10:26	16/8/2017 17:15	No.48 Fung Shue Wo Village	43-54 Fung Shue Wo Village

No.	Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
211	4/9/2017	4/9/2017 17:30	4/9/2017 18:30	No.82 Tai Wong Ha Resite Village	No.82 Tai Wong Ha Resite Village
212	5/9/2017	7/9/2017 14:00	7/9/2017 14:45	No.60 Tsing Yu New Village	No.60-62 Tsing Yu New Village
213	7/9/2017	7/9/2017 16:25	7/9/2017 18:50	No.59 Tsing Yu New Village	No.59 Tsing Yu New Village
214	8/9/2017	8/9/2017 20:30	9/9/2017 00:01	No.59 Tam Kon Shan Road	No.55-63 Tam Kon Shan Road
215	16/9/2017	17/9/2017 09:45	17/9/2017 11:00	Ngong Wan Road near Lamp Post BC0144	Part of Ngong Wan Road
216	18/10/2017	18/10/2017 10:15	18/10/2017 11:45	No. 1 Yim Tin Kok Resite Village	No.1 Yim Tin Kok Resite Village
217	27/10/2017	27/10/2017 13:25	27/10/2017 22:30	Tsing Yi Road near Lamp Post AC 0781	Cheung Ching Estate
218	31/10/2017	31/10/2017 11:00	31/10/2017 11:45	No.1-10 St Paul's Village	No.1-10 St Paul's Village
219	14/11/2017	14/11/2017 12:05	15/11/2017 13:30	No.11 Tsing Yi Heung Sze Wui Road	No.11 Tsing Yi Heung Sze Wui Road
220	4/12/2017	4/12/2017 13:35	4/12/2017 14:35	No.18 Chung Mei Lo Uk Village	No.18 Chung Mei Lo Uk Village
221	8/12/2017	8/12/2017 13:55	8/12/2017 17:05	No.2 Chung Mei Lo Uk Village	No.2 Chung Mei Lo Uk Village
222	24/12/2017	24/12/2017 07:20	24/12/2017 11:00	No.124 Chung Mei Village	No.124 Chung Mei Village

(B) Flushing Water Supply Suspensions in Tsing Yi due to Emergency Repair of Water Mains from 2013 to 2017

No.	Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
1	01-01-2013	01-01-2013 07:30	01-01-2013 14:30	Tsing King Road near Lamp Post FC0526	Tsing King Road Bus Terminus Toilet
2	17-01-2013	17-01-2013 04:00	17-01-2013 17:45	Ching Hong Road near Lamp Post W4002	Ching Shing Court
3	24-01-2013	24-01-2013 10:30	24-01-2013 18:30	Fung Shue Wo Road near Tsing Yi Estate and Lamp Post W4064	Tsing Yi Hui, San Uk Tsuen and Tsing Yu New Village
4	29-01-2013	29-01-2013 18:45	30-01-2013 09:30	Tsing Yi Road west near Tsing Chin Street and Lamp Post FC4222	Ching Wah Court
5	03-02-2013	03-02-2013 13:05	03-02-2013 17:20	38 Yim Tin Kok Resite Area	38 Yim Tin Kok Resite Area
6	10-02-2013	10-02-2013 07:50	10-02-2013 17:30	Lin To Road near Lamp Post FA5099	Lin To Road, Tsing Chin Street, Cheung Wang Estate, Cheung Hang Estate, Mount Haven and Ching Wah Court
7	10-02-2013	10-02-2013 18:45	11-02-2013 05:00	Tsing Chin Street near Lamp Post FA4624	Ching Wah Court
8	19-02-2013	19-02-2013 19:00	19-02-2013 20:30	No.36 Tsing Fai San Tsuen	No.32-38 Tsing Fai San Tsuen
9	01-03-2013	01-03-2013 06:40	01-03-2013 14:00	Cheung Wan Street near Lamp Post W4723	Golden Resources Centre, Vigor Industrial Building, Epoch Industrial Building
10	23-03-2013	23-03-2013 18:05	23-03-2013 19:00	No.42 Tsing Yi Hui Village	No.25-38 Tsing Yi Hui Village
11	25-03-2013	25-03-2013 13:05	25-03-2013 14:30	No.39 Tsing Yi Hui Village	No.39-42, No.63 Tsing Yi Hui Village
12	19-04-2013	19-04-2013 09:30	19-04-2013 16:00	Tsing Chin Street near Lamp Post AC0374	Po Leung Kuk Mr & Mrs Chan Pak Keung, Tsing Yi School, Ching Shing

No.	Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
					Court, Po Leung Kuk, 980 Broad of Director College
13	16-05-2013	16-05-2013 12:15	16-05-2013 18:00	No.22 Chung Mei Lo UK Village	No.14-28 Chung Mei Lo UK Village
14	20-05-2013	23-05-2013 10:05	23-05-2013 11:00	Tsing Yi Road West near Lamp Post W3553	53-67 Tsing Yi Road
15	08-06-2013	08-06-2013 16:00	08-06-2013 17:00	No.111 Chung Mei Village	No.111-114 Chung Mei Village
16	10-06-2013	10-06-2013 11:30	10-06-2013 17:45	No.19 Tsing Yu New Village	No.17-24 Tsing Yu New Village
17	08-07-2013	08-07-2013 14:00	08-07-2013 16:00	No.52-62 Tsing Yi Road	No.52-62 Tsing Yi Road
18	12-07-2013	12-07-2013 15:45	12-07-2013 18:45	No.82 Tai Wong Ha Resite Village	No.71-99 Tai Wong Ha Resite Village
19	12-08-2013	12-08-2013 17:00	12-08-2013 21:40	No.20 Fung Shue Wo Village	No.17-24 Fung Shue Wo Village
20	13-08-2013	13-08-2013 16:40	14-08-2013 21:30	Chung Mei Road near Lamp Post U7276	12 Chung Mei Road (PCCW Sub-station)
21	14-08-2013	14-08-2013 11:05	15-08-2013 00:30	Cheung Wan Street near Lamp Post W1685	Grand Horizon and 2-10 Cheung Fai Road
22	19-08-2013	20-08-2013 23:15	21-08-2013 01:30	Tsing King Road near Lamp Post FC2251	Tsing King Road, Tsing Luk Street
23	21-08-2013	21-08-2013 10:20	21-08-2013 19:00	Tsing Sum Street near Lamp Post FA6869	Tai Wong Ha Resite Area, Yin Tin Kok Resite Area, San Uk Resite Area, Ham Tin Resite Area
24	29-08-2013	29-08-2013 13:00	29-08-2013 19:30	Tsing King Road near Lamp Post FC0564	Tierra Verde at Tsing King Road
25	15-09-2013	15-09-2013 15:40	15-09-2013 23:50	Tsing King Road near Tsing Luk Street	No.2-188 Tsing King Road, No.1-30 Tsing Luk Street
26	15-09-2013	16-09-2013 00:20	16-09-2013 13:50	Tsing King Road near Tsing Luk Street	No.2-188 Tsing King Road, No.1-30 Tsing Luk Street
27	05-10-2013	05-10-2013 23:30	06-10-2013 07:30	Fung Shue Wo Road near Tsing Sum Street	Tsing Yi North salt water Service Reservoir, Lam Tin

No.	Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
					Village, Tai Wong Ha Village, Yim Tin Village, San Uk Village
28	05-10-2013	05-10-2013 17:30	05-10-2013 23:00	Fung Shue Wo Road near Tsing Sum Street	Tsing Yi North Salt Water Service Reservoir, Lam Tin Village, Tai Wong Ha Village, Yim Tin Village, San Uk Village
29	24-10-2013	24-10-2013 10:15	24-10-2013 19:00	Cheung Lung Street near Lamp Post W0572	Part of Cheung Fai Road, Public Toilet
30	02-11-2013	02-11-2013 13:00	02-11-2013 19:30	17 Yim Tin Kok Resite Village	Yim Tin Kok Resite Village
31	03-11-2013	03-11-2013 03:15	03-11-2013 19:00	Fung Shue Wo Road near Lamp Post FB5451	Serene Garden
32	03-11-2013	03-11-2013 13:45	04-11-2013 07:30	Ching Hong Road near Lamp Post W4600	Cheung Ching Estate, Mayfair Gardens, IVE, Parts of Tsing Yi Road
33	04-12-2013	04-12-2013 18:45	05-12-2013 09:00	No.38 Yim Tin Kok Resite Village	No.37-38 Yim Tin Kok Resite Village
34	05-01-2014	05-01-2014 15:15	05-01-2014 20:15	Tsing Luk Street near Tsing Yi Estate Bus Terminus	No.1-45 Tsing Luk Street
35	07-01-2014	07-01-2014 07:40	07-01-2014 11:50	13 San Uk Resite Area	13-16 San Uk Resite Area
36	19-01-2014	20-01-2014 09:10	20-01-2014 11:00	30 Yim Tin Kok Resite Area	30 Yim Tin Kok Resite Area
37	27-01-2014	28-01-2014 10:00	28-01-2014 12:00	No.12-14 San Uk Resite Village	No.10-18 San Uk Resite Village
38	27-02-2014	27-02-2014 17:00	27-02-2014 18:30	48 Lam Tin Resite Area	45-55 Lam Tin Resite Area
39	01-03-2014	02-03-2014 11:00	02-03-2014 13:30	No.44 Tai Wong Ha Resite Village	No.44 Ta Wong Ha Resite Area
40	08-03-2014	08-03-2014 10:30	08-03-2014 13:00	No.41 Chung Mei Lo Uk Village	No.37-48 Chung Mei Lo Uk Village
41	11-03-2014	11-03-2014 18:00	11-03-2014 20:05	Chung Mei Lo Uk Village near Lamp Post W2447	No.67-74 Chung Mei Lo Uk Village
42	11-03-2014	12-03-2014	12-03-2014	17 Yim Tin Kok	Yim Tin Kok Resite

No.	Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
		11:00	12:10	Resite Area	Area
43	13-03-2014	13-03-2014 14:00	13-03-2014 19:00	16 Yim Tin Kok Resite Area	Yim Tin Kok Resite Area
44	25-03-2014	26-03-2014 03:00	26-03-2014 06:30	Cheung Fai Road near Lamp Post W0564	No.30-99 Cheung Fai Road
45	31-03-2014	31-03-2014 18:15	31-03-2014 19:35	No.144 Chung Mei Lo Uk Village	No.141-144 Chung Mei Lo Uk Village
46	11-04-2014	11-04-2014 04:00	12-04-2014 00:30	77 Tsing King Road	Serene Garden, Greenfield Garden
47	23-04-2014	23-04-2014 02:45	23-04-2014 15:45	1 Fung Shue Wo Road	Part of Greenfield Garden, Serene Garden
48	11-05-2014	11-05-2014 11:30	11-05-2014 12:35	40 Fung Shue Wo Village	Part of Fung Shue Wo Village
49	12-05-2014	12-05-2014 10:00	12-05-2014 23:30	Chung Mei Road near Lamp Post W4014	Chung Mei Lo Uk Village, Cheung Hong Estate, Ching Shing Court
50	17-05-2014	17-05-2014 16:00	17-05-2014 20:00	No.28 Lam Tin Resite Village	No.21-32 Lam Tin Resite Village
51	19-05-2014	19-05-2014 17:10	19-05-2014 20:00	No.57-58 Chung Mei Lo Uk Village	No.57-58 Chung Mei Lo Uk Village
52	30-05-2014	30-05-2014 19:30	30-05-2014 20:30	4 San Uk Resite Area	4 San Uk Resite Area
53	07-06-2014	07-06-2014 11:20	07-06-2014 18:00	No.60 Lam Tin Resite Village	No.60-61 Lam Tin Resite Village
54	26-06-2014	26-06-2014 04:00	26-06-2014 10:00	39 Tsing Yi Road	29-51 Tsing Yi Road
55	30-06-2014	30-06-2014 09:50	30-06-2014 18:00	62 Chung Mei Road	62 Chung Mei Road
56	06-07-2014	06-07-2014 23:15	07-07-2014 16:15	2 Tsing Chin Street	Tsing Wah Court
57	12-07-2014	12-07-2014 21:00	12-07-2014 22:30	Chung Mei Road near Lamp Post W0421	Chung Mei Lo Uk Village
58	22-07-2014	22-07-2014 14:00	22-07-2014 15:05	No.61 Chung Mei Village	Chung Mei Village
59	25-07-2014	25-07-2014 19:00	26-07-2014 00:30	Tsing Luk Street near Lamp Post FB0979	No.1-30 Tsing Luk Street
60	11-08-2014	11-08-2014 16:05	11-08-2014 17:00	No.30 Chung Mei Lo Uk Village	No.29-36 Chung Mei Lo Uk Village

No.	Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
61	19-08-2014	19-08-2014 04:00	19-08-2014 18:30	Ching Hong Road near Lamp Post W4650	Ching Yung House
62	22-10-2014	22-10-2014 22:10	23-10-2014 15:50	47 Fung Shue Wo Village	47-54 Fung Shue Wo Village
63	25-10-2014	25-10-2014 16:30	26-10-2014 06:45	Tsing Yu Street near Lamp Post CC0897	Tsing Yu Sum Village, Fung Shue Wo Village, Tai Wong Ha Resite Village, Yam Tin Kok Village
64	29-10-2014	29-10-2014 07:10	29-10-2014 12:00	No.48 Fung Shue Wo Resite Village	No.47-54 Fung Shue Wo Resite Village
65	18-11-2014	18-11-2014 13:30	19-11-2014 09:30	No.32 Lam Tin Resite Village	No.21-32 Lam Tin Resite Village
66	03-12-2014	03-12-2014 04:30	03-12-2014 14:45	Tsing King Road near Lamp Post FC3095	Villa Esplanada
67	04-12-2014	04-12-2014 10:15	04-12-2014 16:30	No.62 Lam Tin Resite Village	No.58-67 Lam Tin Resite Village
68	08-12-2014	08-12-2014 04:30	08-12-2014 16:30	Tsing Luk Street near Lamp Post W4086	Tsing Yi Garden
69	14-12-2014	14-12-2014 13:00	14-12-2014 16:30	Tsing Yi Road near Lamp Post FC3396	No. 33 Tsing Yi Road (Tierra Verde)
70	14-12-2014	14-12-2014 21:30	15-12-2014 20:30	No.66 Tai Wong Ha Resite Village	No.66-70 Tai Wong Ha Resite Village
71	22-12-2014	22-12-2014 13:55	22-12-2014 14:30	No.155 Chung Mei Village	No.149-156 Chung Mei Village
72	24-12-2014	24-12-2014 07:00	24-12-2014 23:30	Fung Shue Wo Road near Lamp Post W4064	Tsing Yi Estate
73	09-01-2015	09-01-2015 10:30	09-01-2015 20:20	No.9 Lam Tin Resite Village	No.9 Lam Tin Resite Village
74	18-01-2015	18-01-2015 15:00	18-01-2015 16:30	No.16 Chung Mei Lo Uk Village	No.9-16 Chung Mei Lo Uk Village
75	21-01-2015	22-01-2015 09:30	22-01-2015 14:05	No.78 Tai Wong Ha Resite Village	No.75-78 Tai Wong Ha Resite Village
76	28-01-2015	28-01-2015 17:45	29-01-2015 09:00	No.27 Fung Shue Wo Resite Village	No.27-38 Fung Shue Wo Resite Village
77	04-02-2015	04-02-2015 15:45	04-02-2015 22:30	Tam Kon Road near Lamp Post FA5028	Part along Tam Kon Shan Road

No.	Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
78	14-02-2015	14-02-2015 13:30	14-02-2015 14:30	D2, St. Paul's Village	D1, D2, E1, E2, F1, F2, G1 and G2 St. Paul's Village
79	21-03-2015	22-03-2015 15:30	22-03-2015 21:30	Liu To Road near Lamp Post FA3540	Part area of Liu To Road, Ching Hong Road and Tsing Yi Road West
80	02-05-2015	02-05-2015 23:30	03-05-2015 07:30	Liu To Road near Lamp Post AC3763	Part area of Liu To Road, Tsing Yi Road West and Tsing Chin Street
81	04-05-2015	04-05-2015 14:30	04-05-2015 18:30	Chung Mei Road near Lamp Post W4019	No.62 Chung Mei Road
82	15-05-2015	18-05-2015 10:10	18-05-2015 21:00	Ching Hong Road near Lamp Post W4651	Cheung Ching Estate
83	13-06-2015	14-06-2015 13:00	14-06-2015 19:30	Tsing Yi Heung Sze Wui Road near Lamp Post W3472	Cheung Wan Street, Cheung Fai Road, Cheung Lung Street, Cheung Tat Road, Cheung Ho Street
84	18-07-2015	18-07-2015 18:30	18-07-2015 22:15	Cheung Fai Road near Lamp Post W0685	Cheung Fai Road, Cheung Tat Road, Cheung Lung Street
85	26-07-2015	26-07-2015 20:00	26-07-2015 22:00	No.16 Tsing Fai San Tsuen	No.16 Tsing Fai San Tsuen
86	08-08-2015	08-08-2015 16:00	08-08-2015 19:30	Cheung Lung Street near Lamp Post W0572	No.11 Cheung Wan Street; No.8-28 Cheung Fai Road; and No.2-28 Cheung Tat Road
87	19-08-2015	19-08-2015 01:10	19-08-2015 14:10	Chung Mei Road near Lamp Post U7276	No.10 Chung Mei Road
88	27-09-2015	27-09-2015 11:50	27-09-2015 17:00	Fung Shue Wo Road near Lamp Post W4056	Sheung Ko Tan Village, Tsing Fai San Tsuen
89	05-10-2015	05-10-2015 18:15	06-10-2015 09:15	No.12 San Uk Resite Village	No.9-12, San Uk Resite Village
90	14-10-2015	14-10-2015 02:35	14-10-2015 17:30	Fung Shue Wo Road near Lamp Post W4100	No.1 Fung Shue Wo Road

No.	Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
91	20-11-2015	20-11-2015 15:30	20-11-2015 17:30	Tsing Luk Street near Lamp Post W4081	No.5 Tsing Luk Street
92	27-11-2015	27-11-2015 22:00	28-11-2015 08:30	Tsing Yi Heung Sze Wui Road	Tsing Yi Heung Sze Wui Road
93	29-01-2016	30-01-2016 10:45	30-01-2016 12:45	St. Paul's Village outside D1 slope	St. Paul's Village D1-D5
94	30-01-2016	30-01-2016 14:30	30-01-2016 17:30	No.54 Chung Mei Lo Uk Village	No.49-58 Chung Mei Lo Uk Village
95	07-03-2016	07-03-2016 18:45	07-03-2016 20:30	Fung Shue Wo Village	No.1-8 Fung Shue Wo Village
96	08-03-2016	08-03-2016 12:35	08-03-2016 16:45	No.115 Chung Mei Lo Uk Village	No.115 Cheung Mei Lo Uk Village
97	14-03-2016	14-03-2016 16:30	14-03-2016 19:00	Tam Kon Shan Road near Lamp Post FB0685	Tam Kon Shan Road No.1 Public Toilet
98	31-03-2016	31-03-2016 14:00	31-03-2016 23:45	Tam Kon Shan Road near Lamp Post FA5023	Tam Kon Shan Road
99	19-04-2016	19-04-2016 01:55	19-04-2016 20:30	Liu To Road near Tsing Yi Road West	Ching Wah Court, Tsing Chin Street
100	01-06-2016	01-06-2016 10:30	01-06-2016 17:30	Fung Shue Wo Road near Lamp Post W4120	Tower 5-10 Greenfield Garden
101	03-06-2016	03-06-2016 21:30	04-06-2016 07:00	Tsing Hong Road near Lamp Post W4660	Tsing Yi East Salt Water Service Reservoir, Part of Ching Hong Road, Sai Shan Road
102	17-06-2016	17-06-2016 20:00	18-06-2016 08:00	Tsing Chin Street near Lamp Post FA4625	Tsing Chin Street, Ching Wah Court
103	24-06-2016	25-06-2016 10:00	25-06-2016 18:30	Ching Hong Road near Lamp Post W2536	Ching Hong Road, Tsing Yi Road, Tsing Hung Road, Hong Wan Road, Sai Shan Road, Tsing Sheung Lane
104	25-06-2016	25-06-2016 13:15	27-06-2016 06:45	Tsing King Road near Lamp Post FC0559	Tierra Verde, Tsing Yi Swimming Pool, Tsing Yi Sport Ground, Tivoli Garden, Serene Garden

No.	Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
105	04-07-2016	04-07-2016 16:40	05-07-2016 08:00	Tsing Sheung Road near Tsing Yi Road	Tsing Sheung Road
106	08-07-2016	08-07-2016 14:00	08-07-2016 20:30	Ha Ko Tan Street near Lamp Post FA5259	Chung Mei Lo Uk Village
107	08-07-2016	08-07-2016 16:45	08-07-2016 23:30	Fung Shue Wo Road near Lamp Post W4101	Greenfield Garden
108	10-07-2016	10-07-2016 14:00	10-07-2016 20:15	Tsing King Road near Lamp Post FC0562	Tierra Verde, Tsing Yi Sports Ground, Tivoli Garden, Serene Garden
109	12-07-2016	13-07-2016 09:00	13-07-2016 11:30	Tam Kon Shan Road near Lamp Post FD0659	No.37-10 Tam Kon Shan Road
110	02-08-2016	02-08-2016 07:25	02-08-2016 19:30	Tsing Luk Street near Lamp Post FC2256	Tsing Yi Municipal Services Building, Tsing Yi Town Clinic and Po Leung Kuk Castar Primary School
111	05-08-2016	05-08-2016 11:00	05-08-2016 13:00	Outside No.20 Tsing Luk Street	No.30 Tsing Luk Street
112	26-08-2016	26-08-2016 15:30	27-08-2016 00:30	Ching Hong Road near Lamp Post W4651	Mei King, Cheung Ching Estate, Tsing Yi Road
113	08-09-2016	08-09-2016 11:15	09-09-2016 09:00	No.7 Tsing Yi Hui	No.1-8 Tsing Yi Hui
114	28-09-2016	28-09-2016 02:20	28-09-2016 18:30	No.3 Tsing Yi Hui	No.1-3 Tsing Yi Hui
115	04-10-2016	06-10-2016 11:30	06-10-2016 15:50	Tam Kon Shan Road near Lamp Post FB0685	No.132 Tam Kon Shan Road
116	06-10-2016	06-10-2016 17:30	06-10-2016 19:00	No.37 Tsing Yi Hui	No.27-38 Tsing Yi Hui
117	20-10-2016	20-10-2016 08:05	20-10-2016 21:15	Cheung Fai Road near Lamp Post W0572	Tsing Yi Fireboat Fire Station
118	28-10-2016	28-10-2016 06:00	28-10-2016 12:45	No.1 Fung Shue Wo Road	No.1 Fung Shue Wo Road
119	29-10-2016	01-11-2016 22:45	02-11-2016 07:30	Tsing Yi Road near Lamp Post AC0785	Sai Shan Road, Tsing Yi Road, Hong Wan Road,

No.	Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
					Tsing Sheung Road, Tsing Hung Road
120	12-11-2016	12-11-2016 21:15	13-11-2016 11:00	Junction of Tsing Yi Road and Tsing Hung Road	Tsing Hung Road
121	15-11-2016	15-11-2016 12:45	15-11-2016 18:00	No.92 Chung Mei Lo Uk Village	No.91-100 Chung Mei Lo Uk Village
122	28-11-2016	28-11-2016 18:45	28-11-2016 23:30	Tam Kon Shan Road near Lamp Post FB0659	No.1 Toilet of Tam Kon Shan Road
123	29-11-2016	29-11-2016 03:25	29-11-2016 23:30	Fung Shue Wo Road near Lamp Post W4064	Tsing Yi Estate, Fung Shue Wo Road
124	04-12-2016	04-12-2016 20:20	05-12-2016 23:00	Chung Mei Road near Lamp Post W0418	Sheung Ko Tan Street, Ha Ko Tan Street, Cheung Hong Estate, Cheung Ching Estate, Ching Shing Court, Chung Mei Lo Uk Village
125	08-12-2016	08-12-2016 19:00	08-12-2016 21:00	No.51 Lam Tin Resite Village	No.45-52 Lam Tin Resite Village
126	12-12-2016	12-12-2016 14:00	12-12-2016 21:45	Tsing Yi Road near Lamp Post AC0818	No.29-51 Tsing Yi Road
127	30-12-2016	30-12-2016 21:15	31-12-2016 05:00	Chung Mei Road near Lamp Post U7285	Chung Mei Lo Uk Village, Cheung Hong Estate, Ching Yeung House, Ching Mui House
128	03-01-2017	03-01-2017 09:40	03-01-2017 20:30	No.1 Tai Wong Ha Resite Village	Tai Wong Ha Resite Village, Lam Tin Resite Village, San Uk Resite Village, Yim Tin Kok Resite Village
129	04-01-2017	04-01-2017 02:35	05-01-2017 00:30	Chung Mei Road near Lamp Post U7285	Cheung Hong Estate
130	06-01-2017	07-01-2017 22:30	08-01-2017 06:00	Junction of Cheung Tat Road and Cheung Ho Street	Cheung Wan Street, Cheung Ho Street, Cheung Tat Road, Cheung Lung Street

No.	Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
131	13-01-2017	15-01-2017 11:00	15-01-2017 19:30	Fung Shue Wo Road near Lamp Post W4095	Serene Garden, Tivoli Garden, Tsing Yi Sports Ground, Swimming Pool, Tierra Verde
132	07-02-2017	08-02-2017 00:05	08-02-2017 19:45	Tsing King Road near Lamp Post FA5753	Greenfield Garden, Serene Garden, toilet near Tsing Yi Ferry Terminus, Tivoli Garden, Tsing Yi Park, Tsing Yi Sports Ground, Tsing Yi Swimming Pool, Tierra Verde
133	22-02-2017	22-02-2017 16:05	22-02-2017 19:40	No.37 Tsing Yi Hui	No.37-38 Tsing Yi Hui
134	15-03-2017	15-03-2017 13:15	16-03-2017 08:15	No.1 Fung Shue Wo Road	Greenfield Garden
135	18-05-2017	18-05-2017 10:40	18-05-2017 17:15	No.77 Tai Wong Ha Resite Village	No.75 Tai Wong Ha Resite Village
136	22-06-2017	22-06-2017 09:55	22-06-2017 23:30	Tsing Yi Road near Lamp Post AC0779	Rambler Crest, Petrol Filling Station
137	25-06-2017	25-06-2017 08:10	26-06-2017 09:00	Fung Shue Wo Road near Lamp Post FC1909	Fung Shue Wo Sports Centre, Tsing Yi Estate
138	02-07-2017	02-07-2017 09:15	03-07-2017 09:30	Tsing King Road near Lamp Post AC0607	Tsing Yi Municipal Services Building, Tierra Verde, Tsing Yi Swimming Pool, Tivoli Garden, Tsing Yi Sports Ground
139	14-08-2017	14-08-2017 21:30	15-08-2017 07:30	Ching Hong Road near Lamp Post W3998	Ching Shing Court, Cheung Hong Estate
140	25-08-2017	25-08-2017 15:35	25-08-2017 22:30	Tsing Yi Road near Lamp Post W3552	Tien Chu Industrial Centre
141	29-08-2017	29-08-2017 17:35	30-08-2017 09:00	No.34 Tsing Yu New Village	No.34 Tsing Yu New Village
142	29-08-2017	30-08-2017 11:20	30-08-2017 13:30	Cheung Fai Road near Cheung Lung Street	Cheung Fai Road Public Toilet, Cheung Lung Street, Cheung Tat Road, Cheung Wan Street, part of Grand

No.	Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
					Horizon
143	03-10-2017	03-10-2017 13:40	03-10-2017 19:00	No.24 Tai Wong Ha Resite Village	No.13-24 Tai Wong Ha Resite Village
144	16-10-2017	16-10-2017 19:00	16-10-2017 21:15	No.130 Chung Mei Lo Uk Village	No.126-136 Chung Mei Lo Uk Village
145	17-10-2017	18-10-2017 13:50	18-10-2017 14:45	No.127 Chung Mei Lo Uk Village	No.125-130 Chung Mei Lo Uk Village
146	19-10-2017	19-10-2017 20:00	19-10-2017 20:55	No.128 Chung Mei Lo Uk Village	No.128-136 Chung Mei Lo Uk Village
147	04-11-2017	04-11-2017 12:30	04-11-2017 13:30	No.7 Chung Mei Lo Uk Village	No.1-8 Chung Mei Lo Uk Village
148	07-11-2017	07-11-2017 09:10	08-11-2017 11:35	Tsing Chin Street near Lamp Post FA4625	Wah Woon House, Wah Suen House, Ching Wah Court
149	25-11-2017	25-11-2017 17:00	26-11-2017 00:30	Tsing Yi Road near Lamp Post AC0779	Rambler Crest
150	07-12-2017	07-12-2017 04:00	08-12-2017 23:30	Liu To Road near Lamp Post FA5102	Cheung Wang Estate, Cheung Hang Estate

- End -

CONTROLLING OFFICER'S REPLY

DEVB(W)175

(Question Serial No. 4323)

Head: (194) Water Supplies Department

Subhead (No. & title): Not Specified

Programme: (1) Water Supply : Planning and Distribution

Controlling Officer: Director of Water Supplies (C L WONG)

Director of Bureau: Secretary for Development

Question:

The Water Supplies Department is responsible for the operation and maintenance of water supply systems. In this regard, please inform this Committee of:

1. the information of occasions of urgent water suspension in Tung Chung district in the past 5 years including the dates, time of onset, time of supply resumption, locations, types of water supply and the areas affected (in tabular format);
2. the current water mains replacement / rehabilitation works in progress or in planning in Tung Chung district;
3. the current inspection works for pumping stations in progress or in planning in Tung Chung district; and
4. the progress of establishing the Water Intelligent Network in the supply network of Tung Chung district.

Asked by: Hon KWOK Ka-ki (Member Question No. (LegCo use): 298)

Reply:

1. Details of the emergency suspension of water supply in the Tung Chung district in the past five years are tabulated in Appendix I. The majority of the cases involved small diameter water mains and/or affected localized areas. Besides, the duration of suspension for about 77% of the cases affecting fresh water supply was less than three hours.
2. The programme of replacement and rehabilitation (the programme) of about 3 000 kilometres aged water mains was implemented in stages starting from 2000. All stages of the programme were substantially completed by the end of 2015. Given the much improved condition of the water supply network after completion of the programme, the Water Supplies Department considers it more effective to sustain the healthiness of the

network by a continuous risk-based assessment of the water mains to determine the need for improvement works including re-provisioning. The risk-based assessment comprises a review of the consequence and probability of failure of the water mains taking into account various factors, such as population and customers served, location, material, age, failure record, pipe size, etc. Based on the risk-based assessment, a section of water mains near the junction of Cheung Tung Road and Tung Chung Waterfront Road in the Tung Chung district will be re-provisioned in 2018-19.

3. Regular inspections and routine maintenance are carried out for all pumping stations in the Tung Chung district. Emergency maintenance will be carried out as and when required.

4. Under the Water Intelligent Network, there will be a total of 15 District Metering Areas (DMAs) in Tung Chung district. Two DMAs have been completed and the remaining thirteen are expected to be completed progressively by 2023.

(A) Fresh Water Supply Suspensions in Tung Chung due to Emergency Repair of Water Mains from 2013 to 2017

No.	Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
1	4/2/2013	4/2/2013 18:55	4/2/2013 20:30	Near No. 18, Lung Tseng Tau Tsuen	No.18, Lung Tseng Tau Tsuen
2	11/3/2013	11/3/2013 13:42	11/3/2013 15:20	Near Lamp Post VA5133, Shek Lau Po Village	Lam Che Tsuen
3	11/5/2013	11/5/2013 15:15	11/5/2013 16:30	Near No. 29, Ngau Kwu Long Tsuen	No. 26-29, Ngau Kwu Long Tsuen
4	19/7/2013	19/7/2013 16:15	19/7/2013 17:05	Near Lamp Post VA 4240, Shek Lau Po Tsuen	No. 37-38, Shek Lau Po Tsuen
5	6/9/2013	7/9/2013 09:40	7/9/2013 11:22	Near No.10, Chek Lap Kok New Village	No. 1-8, Chek Lap Kok New Village
6	19/10/2013	19/10/2013 05:00	19/10/2013 07:00	Near No. 96, Ma Wan Chung Tsuen	All premises in Tai Wai Hang Village
7	24/10/2013	24/10/2013 19:00	24/10/2013 19:40	Near No.101, Shek Mun Kap Tsuen	No. 101, Shek Mun Kap Tsuen
8	27/10/2013	27/10/2013 18:05	27/10/2013 20:50	Near No. 10D, Shek Mun Kap Village	No. 10D, Shek Mun Kap Village
9	15/1/2014	15/1/2014 14:20	15/1/2014 15:00	Near No. 32, Ngan Au Tsuen	No. 32, Ngan Au Tsuen
10	27/2/2014	27/2/2014 12:40	27/2/2014 16:00	Near Lamp Post FC1968, Tung Chung Waterfront Road	Tung Chung Waterfront Road (HyD's Site)
11	27/4/2014	27/4/2014 18:10	27/4/2014 19:30	Near No. 70, Shek Mun Kap Tsuen	No. 70, Shek Mun Kap Tsuen
12	29/4/2014	29/4/2014 23:20	29/4/2014 23:59	Near No. 89, Ma Wan Chung Tsuen	No. 89, Ma Wan Chung Tsuen
13	19/5/2014	19/5/2014 13:15	19/5/2014 14:30	At Block 21, Ma Wan New Village	Block 16-28, Ma Wan New Village
14	4/8/2014	4/8/2014 18:00	4/8/2014 19:00	Near Lamp Post BC2500, Tai Wai Hang Tsuen	Tai Wai Hang Tsuen
15	6/8/2014	6/8/2014 14:40	6/8/2014 16:55	Near Lamp Post FC2338, Chung Mun Road	Ngau Au Tsuen
16	27/8/2014	27/8/2014 14:29	27/8/2014 18:33	Near No.16, Lung Tseng Tau Tsuen	Ha Ling Pei, Lung Tseng Tau, Wong Ka Wai

No.	Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
17	30/9/2014	30/9/2014 18:50	30/9/2014 19:40	Near No. 124, Ma Wan Chung Tsuen	Near No. 124, Ma Wan Chung Tsuen
18	21/10/2014	21/10/2014 11:35	21/10/2014 13:15	Near No. 24, Ha Ling Pei Tsuen	Ha Ling Pei, Lung Tseng Tau, Wong Ka Wai
19	29/10/2014	29/10/2014 14:50	29/10/2014 18:10	Near Lamp Post FC2327, Chung Yat Street	YMCA of Hong Kong Christian Collage & Caritas Charles Vath College
20	5/1/2015	5/1/2015 09:45	5/1/2015 11:00	Near No. 61B, Ma Wan Chung Tsuen	No. 61-63 Ma Wan Chung Tsuen
21	14/2/2015	14/2/2015 18:00	14/2/2015 22:00	Near No. 5 Chek Lap Kok New Village	No.1-6 Chek Lap Kok New Village
22	27/2/2015	27/2/2015 16:15	27/2/2015 20:15	Near No. 29 Ha Ling Pei Tsuen	No.28, 28A-31 & 31A, Ha Ling Pei Tsuen
23	12/5/2015	12/5/2015 13:53	12/5/2015 19:19	Near Lamp Post FB3502, Ma Wan Chung Tsuen	1-20 Ma Wan Chung Tsuen
24	18/5/2015	18/5/2015 15:00	18/5/2015 15:40	Near No. 11A, Sheung Ling Pei	Lot No. 2543-2546, Sheung Ling Pei
25	29/5/2015	29/5/2015 17:45	29/5/2015 19:45	Near No. 48, Ma Wan Chung Tsuen	No. 42, Ma Wan Chung Tsuen
26	25/7/2015	25/7/2015 11:05	25/7/2015 13:15	Near Lamp Post FB7318, Cheung Tung Road	Fire Hydrants PH266 & PH267 at Cheung Tung Road
27	4/8/2015	4/8/2015 12:40	4/8/2015 15:25	Near Fire Hydrant PH493, Cheung Tung Road	Fire Hydrants PH302, PH493 & Sunny Bay Sewage Pumping Station
28	27/9/2015	27/9/2015 14:35	27/9/2015 17:50	At 1, Ma Wan Tsuen	1 Ma Wan Tsuen, Tung Chung
29	2/11/2015	2/11/2015 15:05	2/11/2015 16:15	Near No.101 Shek Mun Kap Tsuen	No. 101 Shek Mun Kap Tsuen
30	10/12/2015	10/12/2015 09:35	10/12/2015 11:10	Near No. 47, Mok Ka Tsuen	No. 42-47, Mok Ka Tsuen
31	13/12/2015	13/12/2015 16:00	13/12/2015 18:05	Near Lamp Post V4167 Chap Mun Tau, Mok Ka Tsuen	34, 35 & 36 Chap Mun Tau
32	1/2/2016	1/2/2016 14:25	1/2/2016 17:25	Near No. 32C, Ha Ling Pei	Ha Ling Pei
33	6/2/2016	6/2/2016 12:50	6/2/2016 19:40	Near Lamp Post FB8318, On Tung Street	Lantau North Police Station

No.	Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
34	1/3/2016	1/3/2016 12:03	1/3/2016 14:40	Near No. 12, Sheung Ling Pei Tsuen	No.12, Sheung Ling Pei Tsuen
35	20/5/2016	20/5/2016 10:50	20/5/2016 12:35	Near No. 106A, Ma Wan Chung Tsuen	No. 98, Ma Wan Chung Tsuen
36	16/7/2016	16/7/2016 18:35	16/7/2016 20:15	At 3, Ma Wan Chung	3, Ma Wan Chung
37	26/7/2016	27/7/2016 00:00	27/7/2016 06:00	Near Tung Chung Pipe Bridge	No. 1, Ma Wan New Village
38	28/7/2016	28/7/2016 11:00	28/7/2016 13:35	Near No. 1, Ma Wan New Village	Whole Tung Chung Area
39	8/9/2016	9/9/2016 00:00	9/9/2016 04:00	Near Yu Tung Road, City Bus Depot	Yat Tung Estate, North Lantau Hospital, Ma Wan Chung, Ngau Au, San Tau Village, Sheung Ling Pei, Ha Ling Pei, Wong Ka Wai, Tseng Tau Village, Mok Ka Tsuen, Shek Mun Kap, Chek Lap Kok New Village, Shek Lau Po
40	11/9/2016	11/9/2016 19:45	11/9/2016 21:00	No. 33A, Ha Ling Pei Village	No. 32-40A Ha Ling Pei Village
41	23/9/2016	23/9/2016 10:15	23/9/2016 12:05	Near No. 116A, Ma Wan Chung Tsuen	No. 116A, Ma Wan Chung Tsuen
42	23/9/2016	23/9/2016 10:45	23/9/2016 12:30	Near No. 124, Ma Wan Chung Tsuen	No. 124, Ma Wan Chung Tsuen
43	2/11/2016	2/11/2016 13:57	2/11/2016 16:53	Near No. 15, Lung Tseng Tau Tsuen	Ha Ling Pei, Lung Tseng Tau, Wong Ka Wai
44	7/12/2016	7/12/2016 14:15	7/12/2016 16:15	Near No. 101, Shek Mun Kap Tsuen	No. 115, Shek Mun Kap Tsuen
45	14/12/2016	14/12/2016 14:20	14/12/2016 15:20	Near No. 18, Lung Tseng Tau	No. 13, 15-18 & 20 Lung Tseng Tau
46	20/12/2016	20/12/2016 11:20	20/12/2016 12:35	Near No. 36, Ha Ling Pei	No. 37, Ha Ling Pei
47	22/12/2016	22/12/2016 13:20	22/12/2016 14:00	Near No. 56, Ha Ling Pei	No.55-56, Ha Ling Pei
48	30/12/2016	30/12/2016 15:30	31/12/2016 16:00	Near Chung Mun Road Sewage Pumping Station	DSD pumping Station at Chung Mun Road

No.	Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
49	7/1/2017	7/1/2017 16:00	7/1/2017 19:05	Near Lamp Post YO 404, Cheung Tung Road	DSD Pumping Station
50	10/2/2017	10/2/2017 16:00	10/2/2017 18:00	Near No. 16, Lung Tseng Tau	No.13, Lung Tseng Tau
51	28/2/2017	28/2/2017 14:00	28/2/2017 15:15	Near No. 3, Pak Mong Tsuen	No. 1-3, Pak Mong Tsuen
52	6/3/2017	6/3/2017 16:49	6/3/2017 19:31	Near AMS Tung Chung Office, Ha Ling Pei	Ha Ling Pei, Lung Tseng Tau, Wong Ka Wai
53	13/3/2017	13/3/2017 16:20	13/3/2017 17:20	Near No. 66, Shek Mun Kap Tsuen	No. 65-70, Shek Mun kap Tsuen
54	16/4/2017	16/4/2017 18:10	16/4/2017 20:32	Near 75. Sheung Ling Pei Tsuen	Part of Sheung Ling Pei
55	29/4/2017	29/4/2017 13:32	29/4/2017 15:32	At 55, Sheung Ling Pei Tsuen	55 Sheung Ling Pei Tsuen
56	17/5/2017	17/5/2017 13:10	17/5/2017 16:40	Near No. 66 Shek Mun Kap	No.65-70, Shek Mun Kap
57	18/5/2017	18/5/2017 10:00	18/5/2017 14:25	Near Lamp Post DC1531 Cheung Tung Road Site	Pak Mong Village
58	25/5/2017	25/5/2017 11:40	25/5/2017 13:10	Near No. 123, Ma Wan Chung Tsuen	No. 123, Ma Wan Chung Tsuen
59	31/5/2017	31/5/2017 10:30	31/5/2017 14:00	Near Fire Hydrant PH493, Cheung Tung Road	Sunny Bay Sewage Pumping Station
60	5/6/2017	5/6/2017 18:05	5/6/2017 20:25	Near No. 10A, Ngau Au Tsuen	No. 10A, Ngau Au Tsuen
61	23/6/2017	23/6/2017 14:25	23/6/2017 16:00	Near No.1, Shek Lau Po Tsuen	No.1, Shek Lau Po Tsuen
62	25/7/2017	25/7/2017 17:55	25/7/2017 18:55	Near No. 37, Shek Lau Po	No. 37, Shek Lau Po
63	1/8/2017	1/8/2017 13:40	1/8/2017 15:25	Near Lamp Post FB8147, Pa Mei Road	No.15, Pa Mei Tsuen
64	23/8/2017	24/8/2017 00:08	24/8/2017 04:00	Near PetroChina, Chung Yan Road	PetroChina, Chung Yan Road
65	24/8/2017	24/8/2017 21:12	24/8/2017 22:20	Near No. 9C, Ha Ling Pei	No.8 & 9C, Ha Ling Pei

No.	Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
66	5/10/2017	5/10/2017 08:45	5/10/2017 10:35	Near Lamp Post V4167, Shek Mun Kap Tsuen	No, 11, Shek Mun Kap Tsuen
67	15/10/2017	15/10/2017 18:30	15/10/2017 22:10	Near No. 13, Wong Ka Wai Tsuen	No. 12 - 15, Wong Ka Wai Tsuen
68	17/10/2017	17/10/2017 20:18	17/10/2017 22:46	Near 122, Shek Mun Kap Village	122, Shek Mun Kap Village
69	17/10/2017	17/10/2017 09:45	17/10/2017 11:30	Near No. 13, Sheung Ling Pei	No. 12,12F-12H &13, Sheung Ling Pei
70	18/10/2017	18/10/2017 15:45	18/10/2017 16:30	Near Lamp Post VA4238, Shek Lau Po	No. 39, Shek Lau Po
71	27/10/2017	27/10/2017 20:30	27/10/2017 22:00	Near No.28, Wong Ka Wai Tsuen	No. 28 Wong Ka Wai Tsuen
72	31/10/2017	31/10/2017 20:08	31/10/2017 21:42	Near Lamp Post AC0871, Shek Lau Po Tsuen	Part of Shek Lau Po Tsuen
73	9/11/2017	9/11/2017 19:10	9/11/2017 20:20	Near Fire Hydrant PH326, Man Tung Road	Public Works Regional Laboratory
74	16/11/2017	16/11/2017 17:45	16/11/2017 19:40	Near No. 24, Ha Ling Pei	No. 23-24, Ha Ling Pei

(B) Flushing Water Supply Suspensions in Tung Chung due to Emergency Repair of Water Mains from 2013 to 2017

No.	Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
1	16/12/2013	16/12/2013 21:00	17/12/2013 05:45	Near Lamp Post FB7220, Cheung Tung Road	Penny's Bay
2	5/1/2015	5/1/2015 11:45	5/1/2015 13:00	1 Sham Fung Road, Siu Ho Wan, Bus Depot	1 Sham Fung Road, Siu Ho Wan, Bus Depot
3	20/1/2015	20/1/2015 12:15	21/1/2015 16:45	Near Lamp Post FC3057, Cheung Tung Road	Cheung Tung Road Refuse Collection Point, Tung Chung Sewage Pumping Station, Tung Chung Wan Telephone Exchange
4	19/10/2015	19/10/2015 18:10	19/10/2015 21:15	Near Lamp Post FC2324, Chung Yat Street	YMCA of Hong Kong Christian College

No.	Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
5	19/4/2016	19/4/2016 12:30	19/4/2016 14:10	Near No. 10, Wong Nai Uk	No. 10, Wong Nai Uk
6	22/11/2016	22/11/2016 21:00	14/12/2016 01:15	Near Lamp Post FC1957, Tung Chung Waterfront Road	Fire Hydrants PH2011, PH2013 & PH2015 at Man Tung Road Park
7	7/6/2017	7/6/2017 12:15	7/6/2017 16:30	Near Lamp Post DC0958, Man Tung Road	Tung Chung North Park
8	25/8/2017	25/8/2017 12:30	25/8/2017 17:30	Near No. 29, Man Tung Road	Tung Chung North Park
9	8/12/2017	8/12/2017 13:50	9/12/2017 09:00	Near Lamp Post FC2065, Man Tung Road	Tung Chung North Park
10	12/12/2017	12/12/2017 18:05	12/12/2017 19:30	Near Lamp Post FC2064, Man Tung Road	Tung Chung North Park

- End -

CONTROLLING OFFICER'S REPLY

DEVB(W)176

(Question Serial No. 4324)

Head: (194) Water Supplies Department

Subhead (No. & title): Not Specified

Programme: (1) Water Supply: Planning and Distribution

Controlling Officer: Director of Water Supplies (C L WONG)

Director of Bureau: Secretary for Development

Question:

The Water Supplies Department is responsible for the operation and maintenance of water supply systems. In this regard, please inform this Committee of:

1. the information of occasions of urgent water suspension in Tsuen Wan district in the past 5 years including the dates, time of onset, time of supply resumption, locations, types of water supply and the areas affected (in tabular format);
2. the current water mains replacement / rehabilitation works in progress or in planning in Tsuen Wan district;
3. the current inspection works for pumping stations in progress or in planning in Tsuen Wan district; and
4. the progress of establishing the Water Intelligent Network in the supply network of Tsuen Wan district.

Asked by: KWOK Ka-ki (Member Question No. (LegCo use): 299)

Reply:

1. Details of the emergency suspension of water supply in the Tsuen Wan district in the past five years are tabulated in Appendix I. The majority of the cases involved small diameter water mains and/or affected localised areas. Besides, the duration of suspension for about 79% of the cases affecting fresh water supply was less than three hours.
2. The programme of replacement and rehabilitation (the programme) of about 3 000 kilometres aged water mains was implemented in stages starting from 2000. All stages of the programme were substantially completed by the end of 2015. Given the much improved condition of the water supply network after completion of the programme, the Water Supplies Department considers it more effective to sustain the healthiness of the

network by a continuous risk-based assessment of the water mains to determine the need for improvement works including reprovisioning. The risk-based assessment comprises a review of the consequence and probability of failure of the water mains taking into account various factors, such as population and customers served, location, material, age, failure record, pipe size, etc. Based on the risk-based assessment, water mains at Castle Peak Road (Tsuen Wan) near Fuk Loi Estate in Tsuen Wan district will be reprovisioned in 2018-19.

3. Regular inspections and routine maintenance are carried out for all pumping stations in the Tsuen Wan district. Emergency maintenance will be carried out as and when required.

4. Under the Water Intelligent Network, there will be a total of 136 District Metering Areas (DMAs) in the Tsuen Wan district. 94 DMAs have been completed and the remaining 42 are expected to be completed progressively by 2023.

(A) Fresh Water Supply Suspensions in Tsuen Wan due to Emergency Repair of Water Mains from 2013 to 2017

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
1/1/2013	1/1/2013 15:45	1/1/2013 23:30	Near No.30 Chai Wan Kok Street	No.30 Chai Wan Kok Street (2030-2330)
5/1/2013	6/1/2013 10:45	6/1/2013 12:05	No.138 Tsing Lung Tau Village	No.134,138 Tsing Lung Tau Village
6/1/2013	6/1/2013 18:00	6/1/2013 20:20	No.135 Lo Wai Tsuen	No.129,130,132,135A,136,136A Lo Wai Tsuen
8/1/2013	8/1/2013 09:30	8/1/2013 13:30	No.208 Tsuen King Circuit	Tsuen Tak Garden
9/1/2013	9/1/2013 11:30	9/1/2013 12:15	No.1 Sha Tsui Road	No.515-503 Castle Peak Road Winner Godown Building
10/1/2013	10/1/2013 13:30	10/1/2013 16:00	No.10 Yi Pei Square	No.65 Ho Pui Street
14/1/2013	14/1/2013 22:00	15/1/2013 02:00	Near No.10 Tsuen Wan Market Street	Tsuen Wan Market Street, Chuen Lung Street, Shiu Wo Street, Tai Ho Road
14/1/2013	14/1/2013 13:31	14/1/2013 13:45	Near Sham Tseng Temporary Playground, Sham Tseng Tsuen Road	Sham Tseng Temporary Playground
21/1/2013	21/1/2013 14:55	21/1/2013 15:25	Wo Yi Hop Road near Lamp Post FA9981, Kwai Chung	Wo Yi Hop Road CLP Substation & Sitting-out Area
21/1/2013	21/1/2013 16:30	21/1/2013 17:45	Near No.32B Sham Tseng Kau Tsuen	No.62 Sham Tseng Kau Tsuen
25/1/2013	25/1/2013 23:00	26/1/2013 04:30	No.20 Tsuen Wan Market Street	Tsuen Wan Market Street, Chuen Lung Street, Shiu Wo Street, Tai Ho Road
3/2/2013	3/2/2013 13:45	3/2/2013 20:30	Near No.21 Tsuen Wan Market Street	No.14-18 Chuen Lung Street
4/2/2013	4/2/2013 09:50	4/2/2013 12:31	370 Sham Tseng San Tsuen	No.15A-61 Sham Tseng San Tsuen
4/2/2013	4/2/2013 16:25	4/2/2013 19:30	Back Lane of No.72 Texaco Road	72-76 Texaco Road
7/2/2013	7/2/2013 08:55	7/2/2013 10:30	No.102 Kwan Mun Hau Tsuen	No.102 Kwan Mun Hau Tsuen
14/2/2013	14/2/2013 15:15	14/2/2013 16:15	Back Lane of No.101 Chuen Lung Street	No.101-123 Chuen Lung St, 10-32 Yi Pei Square

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
25/2/2013	25/2/2013 13:15	25/2/2013 15:30	Near No.25 Fu Cheong Path	Part of Fu Cheong Path
26/2/2013	26/2/2013 16:05	26/2/2013 18:30	Near Fire Hydrant 3722 Route Twisk	Part of Kwong Pan Tin Tsuen
27/2/2013	27/2/2013 15:30	27/2/2013 16:30	No.499 Pun Shan Tsuen	No.499 Pun Shan Tsuen
1/3/2013	2/3/2013 10:45	2/3/2013 15:00	Texaco Road near Lamp Post FB3146, Kwai Chung	Lung Shing Factory Building
2/3/2013	2/3/2013 20:00	3/3/2013 05:30	4A Chai Wan Kok Street	Chai Wan Kok Street Public Toilet
2/3/2013	2/3/2013 20:00	2/3/2013 22:00	No.271 Wo Yi Hop Road Back Lane	No.249-335 Wo Yi Hop Road, No.1-17 Lei Shu Road
2/3/2013	2/3/2013 16:00	2/3/2013 20:00	Near No.82 Hau Tei Square Back Lane	No.207-211 Sha Tsui Road & No.80-84 Hau Tei Square
4/3/2013	4/3/2013 15:30	4/3/2013 16:05	7 Sham Hong Road Back Lane	7-12 Sham Hong Road
8/3/2013	8/3/2013 14:30	8/3/2013 15:05	No.6-28 Chai Wan Kok Street	No.30-40 Chai Wan Kok Street
11/3/2013	11/3/2013 10:30	11/3/2013 11:30	Near Swan Neck 5230 Ha Fa Shan	No.2 House of Ha Fa Shan
11/3/2013	11/3/2013 14:15	11/3/2013 15:15	No.47 Sam Tung Uk Resite Village	No.47 Sam Tung Uk Resite Village
12/3/2013	12/3/2013 17:35	12/3/2013 19:40	Near No.28-29 Hoi Pa Village South Terrace	No.28-29 Hoi Pa Village South Terrace
14/3/2013	14/3/2013 17:05	14/3/2013 18:30	Near Lamp Post VC1139 Shing Mun Catchwater Jogging Trail	Chuen Lung
15/3/2013	15/3/2013 16:00	15/3/2013 17:10	No.103 Chuen Lung Street Back Lane	No.103-105 Chuen Lung Street, 12-14 Yi Pei Square
18/3/2013	18/3/2013 09:25	18/3/2013 10:00	Near No.271 Sha Tsui Road Back Lane	No.271 Sha Tsui Road
18/3/2013	18/3/2013 15:52	18/3/2013 16:10	Near Tsuen Wan South Substation, Wong Tak Street	Tsuen Wan South Substation
19/3/2013	19/3/2013 14:17	19/3/2013 14:40	Near Fire Hydrant 590, Route Twisk	Sham Yuen Site Office
19/3/2013	19/3/2013 14:05	19/3/2013 16:05	Near Sai Chuk Lam, Ha Fa Shan	Ha Fa Shan Village
21/3/2013	21/3/2013	21/3/2013	No.51B Lo Wai Tsuen	No.51A-B Lo Wai Tsuen

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
	09:37	11:00		
21/3/2013	21/3/2013 08:00	21/3/2013 14:55	Near Bayview Garden Castle Peak Road	Greenview Court, Yau Kom Tau Village, Hon Man Tsuen
23/3/2013	23/3/2013 15:30	23/3/2013 16:00	Near Lamp Post VA3694 Yuen Tsuen Ancient Trail	3 small houses at Yuen Tsuen Ancient Trail
24/3/2013	24/3/2013 14:00	24/3/2013 17:00	No.8 Muk Min Ha Tsuen	No.8 Muk Min Ha Tsuen
24/3/2013	24/3/2013 10:05	24/3/2013 12:00	No.1 Hoi Pa Tsuen South Terrace	No.1 Hoi Pa Tsuen South Terrace
26/3/2013	26/3/2013 09:45	26/3/2013 10:45	Near No.170 Sha Tsui Road Back Lane	No.170-174 Sha Tsui Road T.W
27/3/2013	27/3/2013 15:05	27/3/2013 18:00	No.19C Lo Wai Village	Part of Lo Wai Village
27/3/2013	27/3/2013 15:25	27/3/2013 16:50	Near Lamp Post VA0889 at Lo Wai Lane	Part of Lo Wai Lane
28/3/2013	28/3/2013 22:30	29/3/2013 01:40	Yau Kom Tau Fresh Water Pumping Station	Yau Kom Tau Treatment Works Staff Quarters
28/3/2013	29/3/2013 00:01	29/3/2013 05:45	Near No.24-30 Wang Lung Street at Ma Kok Lane	No.24-30, 32-40, 42-46 Wang Lung Street and No.218-264, Texaco Road
30/3/2013	30/3/2013 13:40	30/3/2013 14:30	Near No.23B Sham Tseng San Tsuen	No.23A, 23B, 24, 25 & 25A Sham Tseng San Tsuen
3/4/2013	3/4/2013 14:15	3/4/2013 15:00	Near No.36 Hoi Pa Village	No.36 Hoi Pa Village
3/4/2013	3/4/2013 13:45	3/4/2013 15:30	Near No.42 Hoi Pa Village	No.42 Hoi Pa Village
5/4/2013	6/4/2013 09:00	6/4/2013 11:30	No.45 Hoi Pa Resite Village Back Lane	No.45 Hoi Shing Resite Village
8/4/2013	8/4/2013 10:55	8/4/2013 11:30	Near Lamp Post SWYH/0/0005 at Wo Yi Hop Lane	Part of Wo Yi Hop Village
10/4/2013	11/4/2013 02:00	11/4/2013 03:10	No.90 Heung Wo Street Back Lane	No.66-98 Heung Wo Street
12/4/2013	12/4/2013 21:30	12/4/2013 23:25	No.87A Sham Tseng Sam Tsuen	No.88B Sham Tseng Sam Tsuen
15/4/2013	15/4/2013 15:28	15/4/2013 16:15	Near No.104 Sam Tung Uk Resite Village	No.104 Sam Tung Uk Resite Village
16/4/2013	16/4/2013 18:09	16/4/2013 19:35	Near Tsuen Fung Centre Castle Peak Road	Irrigation Supply

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
19/4/2013	19/4/2013 17:30	19/4/2013 21:00	Tung Po Tor near Fire Hydrant 838	Tung Po Tor Monastery
19/4/2013	19/4/2013 22:30	19/4/2013 23:30	No.3 Chung Kwai Chung Tsuen Back Lane	No.1-6 Chung Kwai Chung Tsuen
22/4/2013	22/4/2013 11:15	22/4/2013 22:15	Near No.415 Castle Peak Road	Fire service supply to No. 407-411 Castle Peak Road
22/4/2013	22/4/2013 20:30	22/4/2013 22:00	Near Lamp Post VA9424 Sham Tseng West Village	No.2 House of Sham Tseng West Village
25/4/2013	25/4/2013 14:00	25/4/2013 17:05	Wo Yi Hop Road near Li Ping Secondary School	Sheng Kung Hui Li Ping Secondary School, Ho Fung College Sponsored by Sik Sik Yuen, Cheung Shan Estate
26/4/2013	26/4/2013 11:50	26/4/2013 14:30	No.3 Ting Kau Village	No.3 Ting Kau Village
30/4/2013	30/4/2013 13:30	30/4/2013 14:50	Near No.63 Chung On Street Back Lane	No.57-63 Chung On Street
3/5/2013	3/5/2013 18:00	3/5/2013 19:15	Near No.6-28 Chai Wan Kok Street Site	No.6-28 Chai Wan Kok Street Site
4/5/2013	4/5/2013 13:30	4/5/2013 19:00	Near Sham Tseng Commercial New Village	Sham Tseng Commercial New Village
8/5/2013	8/5/2013 10:30	8/5/2013 12:00	No.1 Ting Kau Tsuen Backlane	No.1 Ting Kau Tsuen
10/5/2013	10/5/2013 10:50	10/5/2013 11:10	Near No.303 Wo Yi Hop Road	No.303 Wo Yi Hop Road
10/5/2013	10/5/2013 09:22	10/5/2013 09:40	No.27-33 Chung On Street Back Lane	No.27-33 Chung On Street
16/5/2013	16/5/2013 14:50	16/5/2013 16:35	Near No.17D Ting Kau Village	No.17D Ting Kau Village
17/5/2013	17/5/2013 21:00	18/5/2013 01:35	No.18 Hoi Pui Village	Part of Hoi Pui Tsuen
17/5/2013	17/5/2013 17:30	17/5/2013 20:00	No.6 Chung Kwai Chung Tsuen	No.6 Chung Kwai Chung Village
21/5/2013	21/5/2013 19:01	21/5/2013 19:45	19A Sham Tseng San Tsuen Back Lane	Sham Tseng San Tsuen
23/5/2013	23/5/2013 13:40	23/5/2013 17:10	Tsuen Yip Street near No.2-6, Ma Kok Street	No.2-6 and No.8-12 Ma Kok Street
27/5/2013	27/5/2013 13:30	27/5/2013 15:30	Near No.20B Sham Tseng Kau Tsuen Back Lane	3 Houses of Sham Tseng Kau Tsuen

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
30/5/2013	30/5/2013 10:15	30/5/2013 12:15	No.64 Hoi Pa Resite Village Back Lane	No.64 Hoi Pa Resite Village
31/5/2013	31/5/2013 10:50	31/5/2013 12:00	No.81 Ho Pui Street Back Lane	No.81 Ho Pui Street
3/6/2013	3/6/2013 09:30	3/6/2013 10:00	Near lamp post FL0214 at Fu Yung Shan San Tsuen	No. 27-35 Fu Yung Shan San Tsuen
3/6/2013	3/6/2013 10:25	3/6/2013 11:30	No.45 Sam Tung Uk Resite Village	No.45 Sam Tung Uk Resite Village
4/6/2013	4/6/2013 16:00	4/6/2013 17:00	No.17 Yeung Uk Tsuen Back Lane	No.17 Yeung Uk Tsuen
5/6/2013	5/6/2013 15:10	5/6/2013 21:45	Near No.109, Chuen Lung Street Back Lane	No.51-59 Ho Pui Street, No.18 Yi Pei Square
7/6/2013	7/6/2013 10:00	7/6/2013 11:40	No.109 Chuen Lung Street Back Lane	No.101-123 Chuen Lung Street and No.10-32 Yi Pei Square
7/6/2013	7/6/2013 10:00	7/6/2013 11:30	Near No.113 Chuen Lung Street Back Lane	No.101-127 Chuen Lung Street, No.10-32 Yi Pei Square, No.45-65 Ho Pui Street
10/6/2013	10/6/2013 14:00	10/6/2013 15:17	Near No.88 Sam Tung Uk Resite Village	No.88 Sam Tung Uk Resite Village
11/6/2013	11/6/2013 11:30	11/6/2013 15:45	Near No.86 Heung Wo Street Back Lane	No.64-90 Heung Wo Street
13/6/2013	13/6/2013 09:00	13/6/2013 14:00	No.21 Kwan Mun Hau Tsuen	No.21 Kwan Mun Hau Tsuen
14/6/2013	15/6/2013 10:45	15/6/2013 13:00	No.20 Kwan Mun Hau Tsuen Back Lane	No.20 Kwan Mun Hau Tsuen
14/6/2013	14/6/2013 02:10	14/6/2013 18:30	No.200 Texaco Road Back Lane	No.220-248, 250-264 Texaco Road
19/6/2013	19/6/2013 09:45	19/6/2013 11:20	No.52 Sham Tseng Commercial New Village	No.22-24 Sham Tseng Commercial New Village
22/6/2013	22/6/2013 11:45	22/6/2013 15:15	No.364-372 Castle Peak Road	No.364-380 Castle Peak Road
26/6/2013	26/6/2013 10:30	26/6/2013 13:00	No.47 Yuen Tun Village, Tsing Lung Tau	Yuen Tun Village
27/6/2013	27/6/2013 17:05	27/6/2013 20:30	Castle Peak Road near Tsuen Fung Centre	Planter
27/6/2013	27/6/2013 16:00	27/6/2013 21:00	No.19 Ho Pui Tsuen Back Lane	No.17-20 Ho Pui Tsuen
28/6/2013	28/6/2013 14:30	28/6/2013 15:00	Near No.123 Chuen Lung Street Back Lane	No.101-127 Chuen Lung Street, No.45-65 Ho Pui

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
				Street and No.10-32 Yi Pei Square
28/6/2013	28/6/2013 07:40	28/6/2013 12:00	Castle Peak Road near Tsuen Fung Centre Lamp Post DC0279	Planter
2/7/2013	2/7/2013 10:00	2/7/2013 11:30	No.106 Kwan Mun Hau Tsuen	No.106 Kwan Mun Hau Tsuen
2/7/2013	3/7/2013 23:00	4/7/2013 02:30	Near No.36D Sham Hong Road, Sham Tseng	Sham Tseng Commercial New Village and part of Sham Tseng San Tsuen
4/7/2013	4/7/2013 10:15	4/7/2013 15:30	No.17-20 Ho Pui Tsuen Back Lane	No.13-20 Ho Pui Tsuen
6/7/2013	6/7/2013 17:30	6/7/2013 19:00	Near House No.32 Lo Wai Tsuen Wan	House No.32 and 34 Lo Wai Tsuen Wan
7/7/2013	7/7/2013 09:10	7/7/2013 11:00	No.31A Chung Kuk Terrace, Fu Yung Shan Road	No.31A, 33- 39 of Chung Kuk Terrace
8/7/2013	8/7/2013 09:45	8/7/2013 11:30	No.63 Tai Pa Street Back Lane	No.53-75 Tai Pa Street
10/7/2013	10/7/2013 15:00	10/7/2013 15:30	Near Choi Yuen Tsuen Fresh Water Pump House	Choi Yuen Tsuen
13/7/2013	13/7/2013 18:40	13/7/2013 22:00	Near Fire Hydrant 592 Fu Yung Shan Road	Part of Fu Yung Shan Tsuen
19/7/2013	19/7/2013 17:40	19/7/2013 18:45	Near No.63 Tai Ho Road	No.57-63 Tai Ho Road
19/7/2013	19/7/2013 16:00	19/7/2013 17:00	No.24A Ting Kau Tsuen, Ting Kau	No.24A Ting Kau Tsuen
21/7/2013	21/7/2013 11:30	21/7/2013 12:50	No.20B Sham Tseng Kau Tsuen	No.15B & 21B Sham Tseng Kau Tsuen
21/7/2013	21/7/2013 14:30	21/7/2013 15:30	No.41A Sham Tseng San Tsuen	No.41A Sham Tseng San Tsuen
25/7/2013	25/7/2013 10:00	25/7/2013 11:30	Near No.64 Fu Yung Shan Road	No.64 Fu Yung Shan Road
26/7/2013	26/7/2013 07:10	26/7/2013 12:00	No.11 Tsuen Lok Street,	Tsuen Lok Building
29/7/2013	29/7/2013 09:50	29/7/2013 11:00	Lot 301 Castle Peak Road , Ting Kau	Lot 301 Castle Peak Road ,Ting Kau
31/7/2013	31/7/2013 18:20	31/7/2013 21:30	No.16 Yuen Tun Village, Tsing Lung Tau	Yuen Tun Village
31/7/2013	31/7/2013 17:10	31/7/2013 23:00	No.18 Ma Kok Street, Tsuen Wan	No.120 Texaco Road
1/8/2013	1/8/2013	1/8/2013	No.6 Yuen Tun Village	No.6-7 Yuen Tun Village

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
	15:00	16:10	Tsing Lung Tau Back Lane	
5/8/2013	5/8/2013 00:45	5/8/2013 03:30	No.23 Heung Che Street	No.2-6 Tso Kung Street, No.2-36 Tso Kung Square, No.23-25 Heung Che Street, No.2-32 Hoi Pa Street
5/8/2013	5/8/2013 16:50	5/8/2013 19:00	No.62 Hau Tei Square Back Lane	No.32-68 Hau Tei Square
9/8/2013	9/8/2013 22:00	10/8/2013 18:30	Near Lot 1363 Lo Wai Road	Wing Wah Terrace and Chuen Yin Terrace
9/8/2013	9/8/2013 13:30	9/8/2013 15:00	No.118 Sam Tung Uk Village Back Lane	No. 118 Sam Tung Uk Village
9/8/2013	9/8/2013 11:30	9/8/2013 18:30	Near Lamp Post FA4650, Ma Kok Lane	No. 250-264 Texaco Road
10/8/2013	10/8/2013 14:00	10/8/2013 16:30	Near Fire Hydrant 4006, Castle Peak Road, Sham Tseng	Sham Tseng East Village
12/8/2013	12/8/2013 18:05	12/8/2013 19:45	Near Lamp Post U7558, Lo Wai Road	Refuse Collection Point of Lo Wai Road
16/8/2013	16/8/2013 20:15	16/8/2013 22:30	Near Fire Hydrant 592, Fu Yung Shan Road	Part of Fu Yung Shan Tsuen, Chuk Lam Sim Yuen
18/8/2013	18/8/2013 10:30	18/8/2013 11:30	No.15 Hoi Pa South Terrace	No.15 Hoi Pa South Terrace
20/8/2013	20/8/2013 09:30	20/8/2013 12:15	No.225, Wo Yi Hop Road Back Lane	No.225, Wo Yi Hop Road
21/8/2013	21/8/2013 16:05	21/8/2013 19:50	Near No.84 Wo Yi Hop Village	No.84, 86, 79 Wo Yi Hop Village
23/8/2013	23/8/2013 14:40	23/8/2013 16:00	Near Lamp Post V9364, Wan Lung Village, Chuen Lung	Part of Wan Lung Village
24/8/2013	24/8/2013 15:20	24/8/2013 18:00	No.103, Kwan Mun Hau Tsuen	No.103, Kwan Mun Hau Tsuen
25/8/2013	25/8/2013 09:25	25/8/2013 10:30	No.24, Sam Pei Square	No.96-142 Chang On Street, No.2-30 Sam Pei Square, No.71-81 Hau Ti Street
26/8/2013	26/8/2013 18:40	26/8/2013 22:00	Near. Lamp Post DG0277, Castle Peak Road	Planter along Castle Peak Road

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
26/8/2013	26/8/2013 22:00	27/8/2013 02:00	Near No.71, Chuen Lung Tsuen, Tsuen Wan	Chuen Lung Tsuen
27/8/2013	27/8/2013 14:25	27/8/2013 15:50	No.10 Shu On Terrace, Sham Tseng	No.1-18 Shu On Terrace, Sham Tseng
27/8/2013	27/8/2013 14:30	27/8/2013 18:30	Back Lane of No.104 Chung On street	No.102-104 Chung On Street
28/8/2013	28/8/2013 11:20	28/8/2013 12:20	Near No.86, Pai Min Kok Tsuen	Part of Pai Min Kok Tsuen
29/8/2013	29/8/2013 14:40	29/8/2013 20:30	Junction of Lo Wai Road. & Sheng Kok Shan Road	Care & Attention home for the Aged
2/9/2013	2/9/2013 10:00	2/9/2013 11:00	Near No.133 Lo Wai Tsuen, Yi Pei Chun	No.133, Lo Wai Tsuen, Yi Pei Chun
2/9/2013	2/9/2013 14:05	2/9/2013 15:30	Near Lot No.305, Castle Peak Road, Ting Kau	Lot No.305, 307, 309, Castle Peak Road, Ting Kau
8/9/2013	8/9/2013 10:30	8/9/2013 11:30	Near Lamp Post W2421 Ma Sim Pai Road	Refuse Collection Point of Pak Tin Pa Tsuen
13/9/2013	13/9/2013 21:40	14/9/2013 01:30	No.611-619, Castle Peak Road	No.611-619 Castle Peak Road
14/9/2013	14/9/2013 15:30	14/9/2013 16:30	No.75 Tai Ho Road	Planter
15/9/2013	15/9/2013 09:50	15/9/2013 15:00	Near Lamp Post A/C1986, Tsuen Wan Market Street	No.117-133 Castle Peak Road
16/9/2013	16/9/2013 14:10	16/9/2013 17:30	Near Lamp Post FB4759, Castle Peak Road	Airport Core Programme Exhibition Centre
17/9/2013	17/9/2013 14:40	17/9/2013 15:20	No.13 Tai Pak Tin Village	No.13 Tai Pak Tin Village
25/9/2013	25/9/2013 19:10	25/9/2013 22:30	No.100 Sai Lau Kok Road	No.100 Sai Lau Kok Road
26/9/2013	26/9/2013 23:40	27/9/2013 03:00	Near Lamp Post BC1911, Castle Peak Road, Tsing Lung Tau	No.131-133 Castle Peak Road, Tsing Lung Tau
2/10/2013	2/10/2013 13:00	2/10/2013 14:30	No.68 Chuen Lung Village, Route Twisk	No.68-101 Chuen Lung Village, Route Twisk
7/10/2013	7/10/2013 13:00	7/10/2013 14:00	House No.121 Sam Tung Uk Resite Village	House No.121 Sam Tung Uk Resite Village
8/10/2013	8/10/2013 17:32	8/10/2013 17:50	No.22 Ma Wan Main Street Village, Ma Wan	22. Ma Wan Main Street, Village, Ma Wan
16/10/2013	16/10/2013 14:20	16/10/2013 15:30	Back Lane of No.185-187 Castle Peak	No.185-187, Castle Peak Road

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
			Road	
18/10/2013	18/10/2013 14:30	18/10/2013 16:00	No.54-68, Hau Tei Square	No.54-68, Hau Tei Square
18/10/2013	18/10/2013 14:50	18/10/2013 16:40	Back Lane of No.55 Ho Pui Street	No.55 Ho Pui Street
19/10/2013	19/10/2013 11:30	19/10/2013 14:00	No.18-20 Pun Shan Street	No.1-32, Pun Shan Street
21/10/2013	21/10/2013 09:57	21/10/2013 10:24	No.40 Sham Tseng Tsuen, Sham Tseng	No.40 Sham Tseng Tsuen
21/10/2013	21/10/2013 17:30	21/10/2013 21:00	Ma Kok Lane Junction of Lung Tak Street	No.210-218, Texaco Road
25/10/2013	25/10/2013 10:00	25/10/2013 11:15	Near Lamp Post VA 5858 , Tai Kiu Village	Part of Tai Kiu Village
25/10/2013	25/10/2013 11:15	25/10/2013 15:00	No.147 Lo Wai Village	Part of Lo Wai Village
26/10/2013	26/10/2013 15:30	26/10/2013 22:00	No.88 Chung Lung Street	No.88 Chung Lung Street and No.1 Tai Uk Street
30/10/2013	30/10/2013 09:10	30/10/2013 11:00	Back Lane of No.114 Chung On Street	No.114 Chung On Street
30/10/2013	30/10/2013 16:00	30/10/2013 17:25	No.7 Hoi Pa Resite Village	No.2-9 Hoi Pa Resite Village
31/10/2013	31/10/2013 13:20	31/10/2013 17:00	Near 2A Sham Tseng San Tsuen	Part of Sham Tseng San Tsuen
6/11/2013	6/11/2013 15:00	6/11/2013 15:30	Near No.14 Ting Kau Tsuan, Ting Kau	No.14 Ting Kau Tsuan, Ting Kau
11/11/2013	11/11/2013 14:10	11/11/2013 15:10	No.120-140 Tsuen Wan Market Street	No.120-140 Tsuen Wan Market Street
13/11/2013	13/11/2013 14:30	13/11/2013 17:00	Near No.55 Lo Wai Tsuen	Part of Lo Wai Tsuen
17/11/2013	17/11/2013 09:10	17/11/2013 12:00	No.20 Pak Tin Pai Tsuen	Part of Pak Tin Pai Tsuen
18/11/2013	18/11/2013 13:30	18/11/2013 15:00	Sai Hau Kok Road	Block 1 Ho Fai Commercial Centre
19/11/2013	19/11/2013 13:35	19/11/2013 15:00	No.218-220 Saw Hau Kok Road	Ho Fai Commercial Centre (Block B)
27/11/2013	27/11/2013 10:15	27/11/2013 11:00	Near Fire Hydrant 301, Wang Lung Street	No.19-31, Ma Tau Pau Road
27/11/2013	27/11/2013 14:50	27/11/2013 15:40	Near No.28 Sham Tseng Village	No.28 Sham Tseng Village
27/11/2013	27/11/2013 13:25	27/11/2013 14:10	Near No.33D Sham Tseng San Tsuen, Sham Tseng	No.33D Sham Tseng San Tsuen
28/11/2013	28/11/2013 15:00	28/11/2013 17:00	Near No.38 Hon Man Tsuen	No.38-40 Hon Man Tsuen

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
28/11/2013	28/11/2013 09:20	28/11/2013 10:10	Back Lane of No.35 Wang Lung Street	No.35 Wang Lung Street
30/11/2013	30/11/2013 15:00	30/11/2013 15:30	Phase II, Kwong Pan Tin Village	Phase II, Kwong Pan Tin Village
30/11/2013	30/11/2013 10:30	30/11/2013 11:40	Near No.164 Lo Wai Tsuen	No.164 Lo Wai Tsuen
4/12/2013	4/12/2013 18:30	4/12/2013 20:45	Near No.11 Sham Tseng Tung Village	No.12-20 Sham Tseng Tung Village
5/12/2013	5/12/2013 10:00	5/12/2013 13:10	No.303-313 Castle Peak Road	No.303-313 Castle Peak Road
5/12/2013	5/12/2013 14:16	5/12/2013 14:30	Back Lane of No.39 Tsuen Wan Market Street	No.27-59 Tsuen Wan Market Street, Shiu Wo Street, No.13-23 Chung On Street
9/12/2013	9/12/2013 22:30	10/12/2013 05:30	Back Lane of No. 23 Wo Tik Street	No.23-33 Wo Tik Street
10/12/2013	10/12/2013 19:00	10/12/2013 20:00	Near Fire Hydrant 4066 Castle Peak Road	Sham Tseng Tung Village
10/12/2013	11/12/2013 01:00	11/12/2013 03:30	Back Lane of No.27 Wo Tik Street	No.23-33 Wo Tik Street
11/12/2013	11/12/2013 17:10	11/12/2013 19:00	Back Lane of No.125 Sha Tsui Road	No.105-139 Sha Tsui Road, No.1-37 Tso Kung Square
11/12/2013	11/12/2013 13:05	11/12/2013 16:00	Wai Tsuen Road J/O Shek Wai Kok Road	Tin Hau Temple Park, Wai Tsuen Road
12/12/2013	12/12/2013 20:00	12/12/2013 21:00	Section II Kwong Pan Tin Village, Route Twisk	Section II Kwong Pan Tin Village, Route Twisk
13/12/2013	13/12/2013 19:45	13/12/2013 20:45	No.101 Route Twisk	Kwong Pan Tin Area along Route Twisk
16/12/2013	16/12/2013 18:40	16/12/2013 20:30	No.144-172 Castle Peak Road	Watering Point at Caslte Peak Road
18/12/2013	18/12/2013 15:30	18/12/2013 16:50	No.107 Hoi Pa Street	No.105-111 Hoi Pa Street
19/12/2013	19/12/2013 16:10	19/12/2013 17:05	Near Lamp Post FA5508 Kwong Pan Tin Tsuen	Upper Kwong Pan Tin Tsuen
19/12/2013	19/12/2013 11:30	19/12/2013 15:30	Near Lamp Post FA 5844 Wai Tsuen Road	No.47-51 Wai Tsuen Road
22/12/2013	22/12/2013 17:30	22/12/2013 18:50	Near No. 35B Sham Tseng San Tsuen, Sham Tseng	No.35B Sham Tseng San Tsuen
23/12/2013	23/12/2013 13:10	23/12/2013 14:45	Back Lane of No.101 Chuen Lung Street	No.10 Yi Pei Square

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
23/12/2013	23/12/2013 16:10	23/12/2013 17:05	Back Lane of No. 11 Hoi Pa Village Northeast Terrace	No.1-12, No.17-18 Hoi Pa Village
27/12/2013	27/12/2013 17:30	27/12/2013 21:30	Back Lane of No.10 Yi Pei Square	No.65 Ho Pui Street
29/12/2013	29/12/2013 10:00	29/12/2013 11:30	Near No. 51B Lo Wai Tsuen	No.51A & B Lo Wan Tsuen
30/12/2013	30/12/2013 09:05	30/12/2013 10:40	Back Lane of No.138 Chung On Street	No.138 Chung On Street
30/12/2013	30/12/2013 19:10	30/12/2013 23:30	No.130-142 Castle Peak Road	No.130-142 Castle Peak Road
1/1/2014	1/1/2014 18:10	1/1/2014 20:00	Section 4 Kwong Pan Tin Village, Route Twisk	Section 4 Kwong Pan Tin Village
3/1/2014	3/1/2014 09:35	3/1/2014 11:15	Back Lane of No.66 Hoi Pa Sun Tsuen	No.65-66 Hoi Pa Sun Tsuen
4/1/2014	4/1/2014 16:35	4/1/2014 17:30	Back Lane of No.99 Chuen Lung Street	No.93-99 Chuen Lung Street, No.2-4 Yi Pei Square
6/1/2014	6/1/2014 21:30	7/1/2014 00:15	No.16 Yuen Tun Tsuen, Tsing Lung Tau	Yuen Tun Tsuen, Tsing Lung Tau
8/1/2014	8/1/2014 16:40	8/1/2014 22:00	No.8 Tai Ho Road	Red Cross Blood Donor Centre, Tai Ho Road
8/1/2014	8/1/2014 18:45	8/1/2014 19:55	Near Lamp Post W1528, Shing Mun	Pumping Station Wai Tsuen Road
9/1/2014	9/1/2014 15:30	9/1/2014 16:40	Back Lane of No. 19-21, Tso Kung Square	No.19-21, Tso Kung Square
10/1/2014	10/1/2014 17:15	10/1/2014 19:30	Back Lane of No. 323 Sha Tsui Road	No. 323 Sha Tsui Road
14/1/2014	14/1/2014 16:15	14/1/2014 17:15	No. 38 Yuen Tun Village, Tsing Lung Tau	Yuen Tun Village
20/1/2014	20/1/2014 13:50	20/1/2014 16:15	No.68 Sha Tsui Road	No.30-68 , Sha Tsui Road
20/1/2014	20/1/2014 18:30	20/1/2014 19:05	Near Lamp Post V3825, Lo Wai Village	Tung Kwok Monastery
22/1/2014	22/1/2014 14:30	22/1/2014 17:15	Section I Kwong Pan Tin Village	Section I. Kwong Pan Tin Village
22/1/2014	22/1/2014 09:20	22/1/2014 15:30	Back Lane of No. 31 Wo Tik Street	No. 23-33 Wo Tik Street
24/1/2014	24/1/2014 12:45	24/1/2014 14:10	Near Tung Kwok Monastery, Lo Wai Village	Tung Kwok Monastery
27/1/2014	27/1/2014 13:50	27/1/2014 14:30	No.37, Yuen Tun Village ,Tsing Lung Tau	No.36-39, Yuen Tun Village ,Tsing Lung Tau

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
2/2/2014	2/2/2014 21:30	3/2/2014 04:00	Near No. 36-48 Tsuen Wah Street	No.1-21 Tsuen Fu Street , No.12-22 Texaco Road, No.36-38 Tusen Wan Street, No.2-16 Tsuen Kwai Street
4/2/2014	4/2/2014 23:00	5/2/2014 01:10	Back Lane of No.29 Wo Fik Street	No.23-33 Wo Tik Street
5/2/2014	5/2/2014 14:00	5/2/2014 21:30	Junction of Chai Wan Kok Street and Tai Chung Road	No.83-95 Chai Wan Kok Street
5/2/2014	5/2/2014 18:05	5/2/2014 18:25	Near Lamp Post FB2846, Ting Fung Street	Refuse Collection Point Ting Fung Street
11/2/2014	11/2/2014 09:30	11/2/2014 23:30	Near Po Fung Terrace, Po Fung Road	Ha Fa Shan Village, Pan Shan Village, Hon Man Village and Yau Kom Tau Village
11/2/2014	11/2/2014 14:00	11/2/2014 15:30	Miu Kong Street near Garden	No.8 Shing Mun Road
11/2/2014	11/2/2014 18:00	11/2/2014 18:40	Near No. 58 Chung Kwai Chung Tsuen	No.58 Chung Kwai Chung Tsuen
13/2/2014	13/2/2014 09:30	13/2/2014 11:30	No.21 Section II, Kwong Pan Tin Tsuen, Route Twisk	Section II, Kwong Pan Tin Tsuen, Route Twisk
13/2/2014	13/2/2014 22:30	13/2/2014 23:30	Near Lamp Post FC 4596, Sham Hong Road, Sham Tseng	Sham Tseng San Tsuen & Sham Tseng Commercial New Village
14/2/2014	14/2/2014 14:30	14/2/2014 15:30	No.49 Sham Tseng San Tsuen, Sham Tseng	No.35-49, Sham Tseng San Tsuen
15/2/2014	15/2/2014 18:00	15/2/2014 20:15	Near Lamp Post FB 5806 Ma Wan Fisherman Village	Ma Wan Fisherman Village
17/2/2014	17/2/2014 20:00	17/2/2014 22:30	No. 355 Castle Peak Road, Ting Kau	No. 355 Castle Peak Road, Ting Kau
18/2/2014	18/2/2014 10:30	18/2/2014 10:45	No.24 Sham Tseng Commercial Village Sham Tseng	No.24 Sham Tseng Commercial New Village, Sham Tseng
19/2/2014	19/2/2014 14:00	19/2/2014 15:20	Near No. 1B Fu Yung Shan Village	Fu Yung Shan Village
19/2/2014	19/2/2014 02:00	19/2/2014 13:30	Ma Kok Street Junction of Tsuen Yip Street	No.120 Texaco Road
23/2/2014	23/2/2014 15:00	23/2/2014 16:30	Near Fire Hydrant 3744 Shing Mun Road	Tsuen Wan Raw Water Pumping Station
25/2/2014	25/2/2014	25/2/2014	Near entrance of Ma	Ma Wan Tung Wan

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
	15:00	16:30	Wan Tung Wan Beach Ma Wan	Services Building
27/2/2014	27/2/2014 09:45	27/2/2014 11:10	No.6 Hoi Pa Village, Northeast Terrace	No.6 Hoi Pa Village, Northeast Terrace
28/2/2014	28/2/2014 19:45	28/2/2014 21:45	Back Lane of No. 227 Wo Yi Hop Road	No.225-227 Wo Yi Hop Road
2/3/2014	2/3/2014 09:30	2/3/2014 10:20	Near Lamp Post V1982, Pai Min Kok Tsuen, Sham Tseng	No. 11 Pai Min Kok Tsuen, Sham Tseng
5/3/2014	5/3/2014 21:00	6/3/2014 00:30	No.42 Pak Tin Par Tsuen, Route Twisk	Pak Tin Par Tsuen, Route Twisk
5/3/2014	5/3/2014 17:45	5/3/2014 19:00	Near No.118 Lo Wai Tsuen	No.118-135 Lo Wai Tsuen
6/3/2014	6/3/2014 09:20	6/3/2014 10:00	18A, Lo Wai Tsuen	No.18, 18A ,18B, 18C, Lo Wai Tsuen
7/3/2014	7/3/2014 20:00	7/3/2014 21:30	Near Public Toilet, Pak Tin Par San Tsuen	Pak Tin Par San Tsuen
7/3/2014	7/3/2014 19:00	7/3/2014 20:20	Back Lane No.29 Hoi Pa Village, Northeast Terrace	No.29 Hoi Pa Village, Northeast Terrace
7/3/2014	7/3/2014 16:50	7/3/2014 17:15	Back Lane of No. 272 Yau Ma Hom Resite Village	No.272 Yau Ma Hom Resite Village
9/3/2014	9/3/2014 11:40	9/3/2014 14:45	Near Fire Hydrant 3738 Route Twisk	Part of Kwong Pan Tin Tsuen
10/3/2014	10/3/2014 11:50	10/3/2014 13:45	Back Lane of No. 225 Wo Yi Hop Road	No.225-227 Wo Yi Hop Road
11/3/2014	11/3/2014 19:35	11/3/2014 20:55	8 Tai Ho Road	Tsuen Wan Blood Donor Centre
12/3/2014	12/3/2014 18:30	12/3/2014 19:30	1B Fu Yung Shan Tsuen	Fu Yung Shan Tsuen
13/3/2014	13/3/2014 18:40	13/3/2014 19:30	No. 68 Sha Tsui Road	No.40-68 Sha Tsui Road
13/3/2014	13/3/2014 14:30	13/3/2014 15:45	Near Lamp Post 9316 Ham Tin Village	Part of Ham Tin Village
16/3/2014	16/3/2014 11:00	16/3/2014 12:10	Near Playground Tsuen Wing Street	Tsuen Wing Street Playground, Young Ya Industrial Building
16/3/2014	16/3/2014 15:30	16/3/2014 20:30	Back Lane of Luen Yan Street Near Refuse Collection Point	Luen Yan Street Refuse Collection Point
21/3/2014	21/3/2014 11:15	21/3/2014 11:50	Back Lane of No.200 Yau Ma Hom Resite Village	No.200 Yau Ma Hom Resite Village

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
21/3/2014	21/3/2014 15:25	21/3/2014 16:05	No.274 Yau Ma Hom Resite Village	No.274 Yau Ma Hom Resite Village
31/3/2014	31/3/2014 18:35	1/4/2014 00:30	Near Lamp Post W1528 Shing Mun Road	Part of Shing Mun Road
6/4/2014	6/4/2014 15:00	6/4/2014 17:25	Near No.107 Lo Wai Tsuen	No.81, 107, 117, 116 Lo Wai Tsuen
6/4/2014	6/4/2014 10:50	6/4/2014 11:30	Back Lane of No.97 Kwan Mun Hau Tsuen	No.97 Kwan Mun Hau Tsuen
7/4/2014	7/4/2014 22:00	7/4/2014 23:00	Shing Mun Road, Near Texaco Road North	No.8-10 Shing Mun Road
9/4/2014	9/4/2014 18:00	9/4/2014 20:05	Near Lamp Post W2683 Route Twisk	Kwong Pan Tin Tsuen
11/4/2014	11/4/2014 18:30	11/4/2014 21:15	Near No.28B Sham Tseng Kau Tsuen Sham Tseng	Part of Sham Tseng Kau Tsuen
17/4/2014	18/4/2014 02:00	18/4/2014 07:00	Junction of Castle Peak Road- Tsuen Wan and Kwan Mun Hau Street	Wald of Centre
19/4/2014	19/4/2014 15:05	19/4/2014 17:00	Near No.133 Lo Wai Tsuen Tsuen Wan	No.118-135 Lo Wai Tsuen
20/4/2014	20/4/2014 15:46	20/4/2014 19:30	Near Lam Post SPTP/019/C Pak Tin Par Tsuen	Public toilet of Pak Tin Par Tsuen
22/4/2014	23/4/2014 00:30	23/4/2014 04:30	Kwok Shui Road Park Near Public Toilet	Kwok Shui Road Park Public Toilet, Tai Wo Hau MTR Station, Shing Mun Valley Swimming Pool
22/4/2014	22/4/2014 06:30	23/4/2014 01:30	No.603-609, Castle Peak Road	No.603-609, Castle Peak Road
22/4/2014	22/4/2014 09:30	22/4/2014 14:00	Near Lamp Post AC5422 Tsuen Kwai Street	Tsuen Kwai Street , Tsuen Fu Street, Tsuen Wing Street
23/4/2014	23/4/2014 15:00	23/4/2014 16:15	Near Fire Hydrant 239 Kwok Shui Road	No.116-130 Kwok Shui Road
24/4/2014	24/4/2014 12:45	24/4/2014 15:00	Near No.2C Sham Tseng San Tsuen	No.1-35 Sham Tseng San Tsuen
24/4/2014	24/4/2014 18:30	24/4/2014 21:30	No.234 Yau Ma Hon Tsuen	No.234 Yau Ma Hon Tsuen
24/4/2014	24/4/2014 10:05	24/4/2014 12:00	Back Lane of No. 30 Yi Pei Square Tsuen Wan	No.30 Yi Pei Square
26/4/2014	27/4/2014 09:30	27/4/2014 14:00	Back Lane of No. 8 Tso Kung Square	No.6-10 Tso Kung Square

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
29/4/2014	29/4/2014 10:55	29/4/2014 15:36	Near Swan Neck 5168, Route Twisk, Chuen Lung	Part of Chuen Lung Village
1/5/2014	1/5/2014 11:30	1/5/2014 13:10	No.90 Hoi Pa San Tsuen, Kwok Shui Road	No.88-92 Hoi Pa San Tsuen, Kwok Shui Road
2/5/2014	2/5/2014 14:05	2/5/2014 15:30	Back Lane of No. 39 Ho Pui Tsuen	No.39 Ho Pui Tsuen
2/5/2014	2/5/2014 17:20	2/5/2014 19:15	Back Lane of No. 38 Ho Pui Tsuen	No. 30-45 Ho Pui Tsuen
2/5/2014	2/5/2014 09:36	2/5/2014 15:00	Back Lane of No.37 Tsuen Wa Market Street	No.27-37 Tsuen Wa Market Street
2/5/2014	3/5/2014 09:32	3/5/2014 10:09	Back Lane of No. 75 Yeung Uk Road	No. 75 Yeung Uk Road
3/5/2014	3/5/2014 13:25	3/5/2014 15:05	Near No.46 Tai Pak Tin Village	Part of Tai Pak Tin Village
14/5/2014	14/5/2014 10:50	14/5/2014 12:00	Near Lamp Post VC1039 Sheung Kok Shan Road, Lo Wai	Part of Lo Wai Village
14/5/2014	14/5/2014 16:15	14/5/2014 17:10	Near Lamp Post VC0449 Sheung Kok Shan Road, Lo Wai	Part of Lo Wai Village
15/5/2014	15/5/2014 10:22	15/5/2014 14:38	Near Lamp Post AC 2013, Tsuen Wing Street	Tsuen Wing Street Playground
18/5/2014	18/5/2014 16:22	18/5/2014 20:20	Near Lamp Post A9138 Ha Fa Shan	Ha Fa Shan Tsuen
20/5/2014	20/5/2014 10:15	20/5/2014 13:30	Near Lamp Post VC 1521 Lo Wai Tsuen Lo Wai	No.2-8 Lo Wai Tsuen
21/5/2014	21/5/2014 18:45	22/5/2014 00:05	Near No. 45 Shui Wo Street	No.45 Shui Wo Street
22/5/2014	22/5/2014 14:45	22/5/2014 16:00	Back Lane of No. 24 Fu Yung Street	Part of Fu Yung Street
23/5/2014	23/5/2014 22:00	24/5/2014 00:30	Near Lamp Post U7497, Sham Tseng Tsuen Road Sham Tseng	Sham Tseng Tsuen Road
24/5/2014	24/5/2014 15:15	24/5/2014 18:00	Back Lane of No.7 Yeung Uk Tsuen	No.67 Yeung Uk Tsuen
25/5/2014	25/5/2014 14:40	25/5/2014 15:20	Tso Kung Tam Tsuen, Route Twisk	Tso Kung Tam Tsuen,
25/5/2014	25/5/2014 09:30	25/5/2014 11:00	Back Lane of No. 108 Kwan Hau Tsuen	108 Kwan Mun Hau Tsuen

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
26/5/2014	26/5/2014 20:10	26/5/2014 22:50	Back Lane of No.7 Lei Shu Road	1-17, Lei Shu Road
26/5/2014	26/5/2014 17:27	26/5/2014 20:00	Near Lamp Post VC0248 Lung Yue Road Tsing Lung Tau	Lung Yue Road No.92
28/5/2014	28/5/2014 23:00	29/5/2014 00:00	Near Lamp Post U7506 , Sham Tseng Tsuen Road, Sham Tseng	Sham Tseng Tsuen ,
28/5/2014	28/5/2014 18:20	28/5/2014 22:00	No. 23 Castle Peak Road, Tai Lam	No.23-33 Castle Peak Road
28/5/2014	28/5/2014 14:00	28/5/2014 16:15	Near Lamp Post U7497 ,Sham Tseng Tsuen Road, Sham Tseng	Sham Tseng Tsuen, Sham Tseng
30/5/2014	31/5/2014 01:30	31/5/2014 04:15	Near Lamp Post SHMC/D/0076 Fat Yip Lane	No.8 Fat Yip Lane
31/5/2014	31/5/2014 10:30	31/5/2014 13:45	Near Lamp Post SUKPT/D/0022 Kwong Pan Tin San Tsuen	Part of Kwong Pan Tin San Tsuen
1/6/2014	1/6/2014 11:00	1/6/2014 22:00	Near No.2-6 Ma Kok Street	No.120, Texaco Road
2/6/2014	2/6/2014 10:10	2/6/2014 11:10	Back Lane of No.28 Hoi Pa Street	No.22-28 Hoi Pa Street
4/6/2014	4/6/2014 18:35	4/6/2014 19:45	Near Lamp Post SFYS/D/039 Fu Yung Shan Road	Part of Fu Yung Shan Road
5/6/2014	5/6/2014 10:15	5/6/2014 11:00	Near Tso Kung Tam Tsuen, Route Twisk	Tsuen Wan West Ultra High Level Fresh Water Pumping Station
11/6/2014	11/6/2014 22:00	12/6/2014 00:30	Back Lane of No. 27 Wo Tik Street	No.23-33 Wo Tik Street
16/6/2014	16/6/2014 14:00	16/6/2014 15:05	Near No.148, Yi Pei Chun	Part of Yi Pei Chun
16/6/2014	16/6/2014 16:30	16/6/2014 17:00	Back Lane of No. 281 Sha Tsui Road	No. 281 Sha Tsui Road
16/6/2014	16/6/2014 10:30	16/6/2014 11:30	Near No. 364 Sha Tsui Road	No.364-366 Sha Tsui Road
18/6/2014	18/6/2014 19:00	18/6/2014 21:30	Near Swan Neck 416Pak Tin Par Tsuen, Tsuen Wan	Public toilet, Pak Tin Par Tsuen ,Tsuen Wan
20/6/2014	20/6/2014 16:00	20/6/2014 17:58	No.202 Texco Road	No.150-182, Texco Road

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
21/6/2014	21/6/2014 16:36	21/6/2014 17:10	Section I, Kwong Pan Tin Tsuen , Route Twisk	Section I, Kwong Pan Tin Tsuen, Route Twisk
21/6/2014	21/6/2014 17:15	21/6/2014 17:30	No.51 ,Kwong Pan Tin Tsuen, Route Twisk	No.51,Kwong Pan Tin Tsuen, Route Twisk,
23/6/2014	23/6/2014 10:00	23/6/2014 10:48	Near Fire Hydrant 5901, Wing Shun Street	Tsuen Wan Park
24/6/2014	24/6/2014 14:00	24/6/2014 17:00	No. 8 Ma Kok Street	No. 8-12 Ma Kok Street
27/6/2014	27/6/2014 22:00	28/6/2014 00:30	Back Lane of No. 331 Sha Tsui Road	No.331 Sha Tsui Road
27/6/2014	27/6/2014 18:45	27/6/2014 23:05	No. 95 Chai Wan Kok Street	No. 95 Chai Wan Kok St.
29/6/2014	29/6/2014 11:00	29/6/2014 12:15	Near Lamp Post VA0905 Sam Tip Tam Lo Wai Road	Part of Sam Tip Tam Lo Wai Road
1/7/2014	1/7/2014 10:00	1/7/2014 11:30	Wo Yi Hop Road near Lam Post FA9981, Kwai Chung	Wo Yi Hop Road Substation.
2/7/2014	2/7/2014 14:30	2/7/2014 15:30	Near No. 141 Lo Wai Tsuen	Lo Wai Tsuen
3/7/2014	3/7/2014 10:30	3/7/2014 11:30	No.134 Tsing Lung Tau San Tsuen Tsing Lung Tau	No.133-134 Tsing Lung Tau San Tsuen
3/7/2014	3/7/2014 09:42	3/7/2014 11:02	No.11, Ho Pui Tsuen, Kwok Shui Road	Hoi Pui Tsuen No.8-15
4/7/2014	4/7/2014 14:00	4/7/2014 15:00	Near Lamp Post DC0560, Hoi Pa Street	Cheong Tai Building
5/7/2014	6/7/2014 00:30	6/7/2014 07:30	Back Lane of No. 188 Texaco Road	Ma Kok Street
8/7/2014	8/7/2014 10:25	8/7/2014 15:35	Near Lamp Post FC3733, Tsuen Yip Street	Block 2 , Leader Industrial Centre
8/7/2014	8/7/2014 13:30	8/7/2014 14:45	Back Lane of No. 11 Yeung Uk Tsuen	No.11 Yeung Uk Tsuen
9/7/2014	9/7/2014 09:30	9/7/2014 10:15	No.21 Sham Tseng Village Sham Tseng	No.17-23, Sham Tseng Village , Sham Tseng ,
9/7/2014	9/7/2014 02:30	9/7/2014 09:30	Near Lamp Post FC 0593 Chai Wan Kok Street	Part of Chai Wan Kok Street
11/7/2014	11/7/2014 09:30	11/7/2014 15:30	Near Lamp Post W4443,Chuen Lung Village, Route Twisk	Sun Hoi Tin Village , Chun Ha Village, Chuen Lung, Route Twisk

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
14/7/2014	14/7/2014 10:00	14/7/2014 16:10	Near No. 118, Lo Wai Tsuen	Part of Lo Wai Tsuen
14/7/2014	14/7/2014 14:26	14/7/2014 17:15	Near Lamp Post SPTP/018/C Pak Tin Pa San Tsuen	Pak Tin Pa San Tsuen
15/7/2014	15/7/2014 15:10	15/7/2014 20:10	Near No.95 Chai Wan Kok Street Tsuen	No. 83-95, Chai Wan Kok Street, Tsuen Wan
16/7/2014	16/7/2014 15:30	16/7/2014 17:00	Near No. 62 ,Sheung Kwai Chung Village	No.61-62, Sheung Kwai Chung Village
16/7/2014	16/7/2014 11:30	16/7/2014 12:15	Back Lane of No. 108 Chung On Street	No.108 Chung On Street
17/7/2014	17/7/2014 14:35	17/7/2014 15:00	No.2-6, Sha Tsui Road	No. 2-6, Sha Tsui Road
18/7/2014	18/7/2014 18:45	18/7/2014 20:10	No.459 Castle Peak Road Wah Lik Industrial Centre	No.455-457, Chinachem Tsuen Wan Plaza
20/7/2014	21/7/2014 22:00	22/7/2014 05:40	Near Lamp Post FA5863 Shek Wai Kok Road	Shing Mun Valley Swimming Pool and Wai Tsuen Sports Centre
23/7/2014	23/7/2014 10:00	23/7/2014 11:00	No.218 Section II Kwong Pan Tin Village	No.218 Kwong Pan Tin Village, Section II, Tsuen Wan
24/7/2014	24/7/2014 02:00	24/7/2014 04:30	Near No.88 Texaco Road	No.88-96 Texaco Road.
28/7/2014	28/7/2014 17:25	28/7/2014 18:30	Near Fire Hydrant 10915,Gemini Beaches, Sham Tseng	Gemini Beaches
29/7/2014	29/7/2014 10:30	29/7/2014 11:15	DD355A, Aztec Lodge, Ting Kau	DD355A, No.1-7, Aztec Lodge, Ting Kau
29/7/2014	29/7/2014 14:45	29/7/2014 22:00	Near Lamp Post FC0592 Chai Wan Kok Street	No.60-90 Chai Wan Kok Street
30/7/2014	30/7/2014 15:25	30/7/2014 16:30	Near No. 25 Sam Tung Uk Resite Village	No.25 Sam Tung Uk Village
1/8/2014	1/8/2014 10:35	1/8/2014 11:15	Near Swan Neck 5168 Chuen Lung Tsuen	Part of Chuen Lung Tsuen
1/8/2014	1/8/2014 15:00	1/8/2014 17:15	Near No.65 Fu Yung Shan New Village	Part of Fu Yung Shan New Village
8/8/2014	8/8/2014 10:10	8/8/2014 11:00	Near Lamp Post DC1828 Chung On Street	No.86 Chung On Street
12/8/2014	12/8/2014 15:00	12/8/2014 16:40	Near Fire Hydrant 114 Texcao Road	No.186-188 Texaco Road
12/8/2014	12/8/2014	12/8/2014	No.46, Ting Kau	No.42-48,Ting Kau

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
	09:40	10:45	Village, Ting Kau	Village, Ting Kau
13/8/2014	13/8/2014 09:20	13/8/2014 11:28	No.12 Chuen Lung Street	No. 2-30, Chuen Lung Street
16/8/2014	16/8/2014 20:45	16/8/2014 22:45	Junction of Chuen Lung Street and Hau Tei Square	Lady Trench Polyclinic
17/8/2014	17/8/2014 11:50	17/8/2014 12:50	Back Lane of No.88 Chung On Street	No.88 Chung On Street
18/8/2014	18/8/2014 13:58	18/8/2014 14:41	No.21 Tai Pei Square	No.9-31 Tai Pei Square
18/8/2014	18/8/2014 14:52	18/8/2014 15:55	Near Lamp Post TK0108, Ting Yat Rd, Ting Kau	One House
19/8/2014	19/8/2014 11:15	19/8/2014 11:49	Back Lane of No.327, Wo Yi Hop Road	No.327-335 Wo Yi Hop Road
21/8/2014	21/8/2014 16:30	21/8/2014 19:20	Lamp Post W1981, Shing Mun Road	No.9 Shing Mun Road
22/8/2014	22/8/2014 16:08	22/8/2014 17:09	No.2 Chung Kwai Chung Tsuen	No.2 Chung Kwai Chung Tsuen
22/8/2014	22/8/2014 16:05	22/8/2014 17:35	Near No.27, Yi Pei Square	No.27 Yi Pei Square
23/8/2014	23/8/2014 09:20	23/8/2014 10:00	No.14 Sam Pei Square	No.14-20 Sam Pei Square
25/8/2014	25/8/2014 09:45	25/8/2014 11:00	Back Lane of No.18 Sam Pei Square	No.18 Sam Pei Square
25/8/2014	25/8/2014 16:30	25/8/2014 17:45	Near Lamp Post AC1449 Tsuen King Circuit	Ha Fa Shan Tsuen
26/8/2014	26/8/2014 16:45	26/8/2014 19:00	Near No.115 Tsuen Wan Market Street	No.133 Castle Peak Road
26/8/2014	26/8/2014 14:15	26/8/2014 19:50	Near Public Toilet, Pak Tin Pa Tsuen	Part of Pak Tin Pa Tsuen
27/8/2014	27/8/2014 15:49	27/8/2014 17:30	No.103 Lo Wai Village	No.103-120 Lo Wai Village
29/8/2014	29/8/2014 22:46	29/8/2014 23:40	No.15 Castle Peak Road Tsing Lung Tau	No.15 Castle Peak Road Tsing Lung Tau
1/9/2014	1/9/2014 14:09	1/9/2014 14:42	Near Lamp Post 1672, Lo Wai Road	No.9 Lo Wai Road
2/9/2014	4/9/2014 13:45	4/9/2014 15:20	Near Tsuen Wan Salt Water Pumping Station	Part of Tai Chung Road
4/9/2014	4/9/2014 13:47	4/9/2014 14:48	No.28 Sham Tseng San Tsuen Sham Tseng	No.26-28 Sham Tseng San Tsuen
5/9/2014	5/9/2014	5/9/2014	Near Fire Hydrant 9679,	Ma Wan No.2, Fresh

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
	16:06	17:00	Ma Wan, No.2 , Fresh Water Service Reservoir	Water Service Reservoir
6/9/2014	6/9/2014 17:27	6/9/2014 23:43	Near Swan Neck 416, Pak Tin Pa San Tsuen	Part of Pak Tin Pa San Tsuen
6/9/2014	6/9/2014 10:25	6/9/2014 13:30	Near No.36, Hoi Pa Tsuen	No.30 -36 Hoi Pa Tsuen
10/9/2014	10/9/2014 10:45	10/9/2014 11:30	Back Lane No.26B Ting Kau Village Ting Kau	No.26-27 Ting Kau Village
13/9/2014	13/9/2014 14:45	13/9/2014 18:00	Near Lamp Post VC0836 Sham Tseng Village Sham Tseng	No.1-39 Sham Tseng Village
16/9/2014	16/9/2014 11:05	16/9/2014 18:20	Near Lamp Post FB5688, Tak Hoi Street	City Landmark 1
17/9/2014	17/9/2014 14:15	17/9/2014 15:43	Near Swan Neck 416, Pak Tin Pa San Tsuen	Par of Pak Tin Pa San Tsuen
18/9/2014	18/9/2014 22:00	19/9/2014 03:30	Inside Kwok Shui Road Park	Part of Kwok Shui Road Park Hydrant
19/9/2014	19/9/2014 10:00	19/9/2014 11:15	Back Lane of No.196 Yau Ma Hom Resite Village	No.196 Yau Ma Hom Resite Village
24/9/2014	24/9/2014 22:30	24/9/2014 23:45	Near Jing Ho Industrial Building, Tsuen Yip Street	No.178-182 Texaco Road
24/9/2014	24/9/2014 10:00	24/9/2014 11:30	Near No.140, Lo Wai Tsuen Tsuen Wan	Part of Lo Wai Tsuen
24/9/2014	24/9/2014 15:00	24/9/2014 19:50	Near Lamp Post SPTP/019/C, Pak Tin Pa San Tsuen	Part of Pak Tin Pa San Tsuen
25/9/2014	25/9/2014 16:00	25/9/2014 19:00	Near No.40-50, Sha Tsui Road Tsuen Wan	No.40-50, Sha Tsui Road, Tsuen Wan
29/9/2014	29/9/2014 10:15	29/9/2014 11:30	Near No.1 Heung Wo Street	No.1-3 Heung Wo Street
29/9/2014	30/9/2014 23:45	1/10/2014 04:25	Near Lamp Post DC0573 Castle Peak Road, Sham Tseng	Part of Sham Tseng
1/10/2014	2/10/2014 11:30	2/10/2014 14:20	Near No.92 Hoi Pa San Tsuen	No.88-92 Hoi Pa San Tsuen
3/10/2014	3/10/2014 13:57	3/10/2014 15:05	Near No. 135-143 Tsuen Wan Market Street	No.117-143 Tsuen Wan Market Street
4/10/2014	4/10/2014 09:45	4/10/2014 11:30	Near No.86 Kwong Pan Tin Tsuen	No.70-90 Kwong Pan Tin Tsuen
4/10/2014	4/10/2014	4/10/2014	No. 81 Sham Tseng	No.81 Sham Tseng Tsuen

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
	18:30	20:00	Tsuen	
6/10/2014	6/10/2014 16:23	6/10/2014 16:38	Near No.34A Lo Wai Village	Part of Lo Wai Village
6/10/2014	6/10/2014 12:30	6/10/2014 14:05	Near No.2A Ngong Tong Tsuen, Chuen Lung	No.2A Ngong Tong Tsuen
8/10/2014	8/10/2014 05:50	9/10/2014 02:10	Near Fire Hydrant 2009 Texaco Road North	Shing Mun Vallage Swimming Pool
8/10/2014	8/10/2014 21:05	9/10/2014 04:00	Near Lamp Post W2695 Route Twisk	Part of Pak Tin Pa San Tsuen
9/10/2014	9/10/2014 14:00	9/10/2014 16:50	Near No.42 Pak Tin Pa San Tsuen	Part of Pak Tin Pa San Tsuen.
10/10/2014	10/10/2014 09:50	10/10/2014 11:00	Near No.25 Sham Tseng San Tsuen, Sham Tseng	No.25 Sham Tseng San Tsuen
11/10/2014	11/10/2014 13:50	11/10/2014 14:50	No.28. Tai Chung Road	No.22-28 Tai Chung Road
12/10/2014	12/10/2014 21:10	13/10/2014 00:15	Near Lamp Post FA4700 Texaco Road	Tsuen Wan Driving Test Centre
13/10/2014	13/10/2014 13:45	13/10/2014 14:55	Near No.31. Ho Pui Tsuen. Kwok Shui Road	No.31 Ho Pui Tsuen
13/10/2014	13/10/2014 11:05	13/10/2014 12:00	Near Lamp Post VC1070 Ting Kau Village	Part of Ting Kau Village
15/10/2014	15/10/2014 10:30	15/10/2014 11:30	No.932 Kwan Mun Hau Tsuen.	Part of Kwan Mun Hau Tsuen and Yeung Uk Tsuen
20/10/2014	20/10/2014 10:15	20/10/2014 11:35	Near No.1 Ho Pui Tsuen.	No.1-3 Ho Pui Tsuen
22/10/2014	22/10/2014 10:40	22/10/2014 12:00	Near Refuse Collection Point, Wo Yi Hop Tsuen Shing Mun Road	Part of Wo Yi Hop Tsuen
22/10/2014	22/10/2014 18:30	22/10/2014 20:00	Back Lane of No.92 Hoi Pa San Tsuen	92 Hoi Pa San Tsuen
23/10/2014	23/10/2014 14:40	23/10/2014 15:40	Near Lamp Post VA8585 Lo Wai Village	Tung Kok Monastery, Lo Wai Village
23/10/2014	23/10/2014 10:00	23/10/2014 11:00	No.226 Yau Ma Hom Resite Village	No.226-314 Yau Ma Hom Resite Village
24/10/2014	24/10/2014 10:30	24/10/2014 11:30	Near No.71 Wo Yi Hop Tsuen	Part of Wo Yi Hop Tsuen
24/10/2014	24/10/2014 16:15	24/10/2014 17:30	Near Lamp Post CC0547 Lo Wai Tsuen	Part of Lo Wai Tsuen

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
25/10/2014	25/10/2014 14:30	25/10/2014 15:30	Back Lane of No.162 Tsuen Wan Market Street	No.162 Tsuen Wan Market Street
26/10/2014	26/10/2014 13:45	26/10/2014 16:15	Back Lane of No.51 Heung Wo Street	No.43-59 Heung Wo Street
4/11/2014	4/11/2014 14:30	4/11/2014 16:50	Near Lamp Post FA 5494 Route Twisk	Ho Koon Nature Education Cum Astronomical Center
5/11/2014	5/11/2014 16:00	5/11/2014 17:25	Near No.8 Kwong Pan Tin Tsuen	Part of Kwong Pan Tin Tsuen
6/11/2014	6/11/2014 14:15	6/11/2014 15:45	Near No.28 Fu Yung Shan Road.	No.28 Fu Yung Shan Road
7/11/2014	8/11/2014 00:20	8/11/2014 02:15	Near Lamp Post AC 1986 Tsuen Wan Market Street	Maurine Grantham Health Centre
9/11/2014	9/11/2014 09:30	9/11/2014 11:00	Near No.42 Pak Tin Pa Tsuen	Part of Pak Tin Pa Tsuen
10/11/2014	10/11/2014 15:40	10/11/2014 16:20	Near Lamp Post BC 2460 Castle Peak Road	No,99-113 Castle Peak Road
11/11/2014	11/11/2014 10:30	11/11/2014 11:20	Near No.40 Sha Tsui Road	No.40-66 Sha Tsui Road
13/11/2014	13/11/2014 14:00	13/11/2014 16:30	Near Lamp Post FB2852 Ting Fung Street	Part of Yeung Uk Tsuen & Hoi Pa San Tsuen
15/11/2014	15/11/2014 19:00	15/11/2014 20:20	Near No.8 Hoi Pui Tsuen	No.1-8 Ho Pui Tsuen
18/11/2014	18/11/2014 16:45	18/11/2014 17:50	Near Lamp Post VC2131 Ting Kau Village	No.115 Ting Kau Village.
18/11/2014	18/11/2014 10:15	18/11/2014 11:05	No.62B Sham Tseng Kau Tsuen	Part of Sham Tseng Kau Tsuen
19/11/2014	19/11/2014 10:50	19/11/2014 19:30	Near Lamp Post FC2675 Sha Tsui Road	Watering Flowers Meter
19/11/2014	19/11/2014 16:30	19/11/2014 17:30	Near Lamp Post VA9143 Ha Fa Shan	Part of Ha Fa Shan
21/11/2014	21/11/2014 12:15	21/11/2014 16:00	Near Fire Hydrant 3097 Hoi Hing Road.	Hoi Hing Road Park
22/11/2014	23/11/2014 09:00	23/11/2014 14:20	Near No.22B1 Sham Tseng San Tsuen	Part of Sham Tseng San Tsuen
24/11/2014	24/11/2014 15:20	24/11/2014 17:00	Near Lamp Post DC0277 Castle Peak Road	Watering Flowers Meter
24/11/2014	24/11/2014 10:20	24/11/2014 11:25	Near No.96B Lo Wai Tsuen	Part of Lo Wai Tsuen

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
25/11/2014	25/11/2014 21:00	26/11/2014 01:30	Back Lane of No.115 Sha Tsui Road	No.101-119 Sha Tsui Road
25/11/2014	25/11/2014 13:15	25/11/2014 14:20	Near No.10A1 Sham Tseng San Tsuen	Part of Sham Tseng San Tsuen.
26/11/2014	26/11/2014 15:58	26/11/2014 16:50	Back Lane of No.53 Hoi Pa San Tsuen	No.51-53 Hoi Pa San Tsuen
27/11/2014	27/11/2014 12:00	27/11/2014 13:05	Near Lamp Post FC3243 Pun Shan Street	Hing Fung Printing & Dyering Factory Ltd
27/11/2014	27/11/2014 14:05	27/11/2014 15:00	Near No.57 Sham Tseng Village	No.57 Sham Tseng Village
29/11/2014	29/11/2014 14:20	29/11/2014 16:00	Texaco Road near Lamp Post FA1812	Po Yip Building
3/12/2014	3/12/2014 13:30	3/12/2014 19:10	Near Lamp Post FA1726 Lai Chi Road	Belvedere Garden Phase 3 Fire System
3/12/2014	3/12/2014 10:15	3/12/2014 11:30	Back Lane of No.36 Yeung Uk Tsuen	No.36 Yeung Uk Tsuen
4/12/2014	4/12/2014 16:20	5/12/2014 11:00	Near Lamp Post FC0342 Tai Ho Road	Part of Tai Ho Road
5/12/2014	5/12/2014 15:25	5/12/2014 17:10	Back Lane of No. 73 Sam Tung Uk Resite Village	No.73-74 Sam Tung Uk Resite Village.
7/12/2014	7/12/2014 21:00	7/12/2014 21:45	Backlane of No.61 Sham Tseng Kau Tsuen	No.10B. 61 & 60A Sham Tseng Kau Tsuen
7/12/2014	7/12/2014 18:45	7/12/2014 19:10	Near No.29A Sham Tseng San Tsuen	No.18. 10 & 29A Sham Tseng San Tsuen
11/12/2014	11/12/2014 15:45	11/12/2014 16:55	Near No. 11 Hoi Pa Village, Northeast Terrace	Part of Hoi Pa Villagem Northeast Terrace
11/12/2014	11/12/2014 10:30	11/12/2014 12:30	Back Lane of Sandoz Centre, Tsuen Yip Street	Sandoz Centre
11/12/2014	11/12/2014 17:45	11/12/2014 19:35	Back of No. 3 Ho Pui Tsuen	No.1-4 Ho Pui Tsuen
12/12/2014	12/12/2014 17:00	12/12/2014 20:00	Np. 101 Route Twisk	No. 101 Route Twisk
12/12/2014	12/12/2014 17:30	12/12/2014 20:30	Near Swan Neck 5632, Hong Man Sheung Tsuen	Part of Hong Man Sheung Tsuen
15/12/2014	15/12/2014 15:15	15/12/2014 17:05	Near No. 24 Yau Kom Tau Village	Part of Yau Kom Tau Village
16/12/2014	16/12/2014 09:50	16/12/2014 10:30	Near No. 12 Sham Tseng West Village	Part of Sham Tseng West Village
17/12/2014	17/12/2014 13:00	17/12/2014 14:00	Near Lamp Post V5919, Yi Pei Chun Lo Wai	Yi Pei Chun Lo Wai

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
17/12/2014	17/12/2014 15:40	17/12/2014 16:30	No. 17A Tsing Lung Tau	Tsing Lung Tau Tsuen
20/12/2014	21/12/2014 01:30	21/12/2014 03:00	Near No. 48 Castle Peak Road	Chan Kee Commercial Centre
24/12/2014	24/12/2014 11:35	25/12/2014 05:30	Junction of Castle Peak and Tai Ho Road	Tai Ho Road Flower Meter
30/12/2014	30/12/2014 15:50	30/12/2014 17:30	Near Lamp Post DC0279, Tsuen Fung Centre	Flower Meter
30/12/2014	30/12/2014 09:20	30/12/2014 11:30	Near No. 204 Ma Kok Lane	Wo Foo Building
30/12/2014	30/12/2014 12:30	30/12/2014 13:30	Near Lamp Post V9700, Tsing Fai Tong New Village, Sham Tseng	No.60-68 Tsing Fai Tong New Village
31/12/2014	31/12/2014 14:15	31/12/2014 15:45	Near Lamp Post FB5812, Fang Yuen Road, Ma Wan	Fung Shing Village, Ma Wan
1/1/2015	1/1/2015 13:50	1/1/2015 15:00	No. 16 Sheung Kwai Chung Village	Part of Sheung Kwai Chung Village
1/1/2015	2/1/2015 17:00	2/1/2015 19:45	Near Lamp Post DC1455 Hoi On Road	Tsuen Wan West Sports Centre, HK Baptist Convention Primary School
2/1/2015	2/1/2015 14:10	2/1/2015 15:15	Near Lamp Post VC2209 Sheung Kwai Chung Village	Part of Sheung Kwai Chung Village
3/1/2015	3/1/2015 09:30	3/1/2015 20:00	Near No. 125A Chuen Lung Street	No.88 & 118 Chuen Lung Street
5/1/2015	5/1/2015 13:10	5/1/2015 15:00	Near Lamp Post FA1730 Lai Shun Road	Fat Yip Lane CLP Substation
5/1/2015	5/1/2015 14:00	5/1/2015 17:00	Near No. 18 Tsuen Hing Path	No. 14-18 Tsuen Hing Path
9/1/2015	9/1/2015 17:30	9/1/2015 20:30	Near Lamp Post VA9149 Lo Wai Tsuen, Lo Wai	No.60-70 Lo Wai Tsuen
11/1/2015	11/1/2015 10:00	11/1/2015 11:15	Near Lamp Post VA3695 Yuen Tsuen Ancient Trail	Yau Kom Tau Refuse Collection Point, Yau Kom Tau Village
11/1/2015	11/1/2015 13:30	11/1/2015 16:00	Back of No. 15 Lei Shu Road	No. 1-16 Lei Shu Road
12/1/2015	12/1/2015 00:21	12/1/2015 04:30	Near Lamp Post FA5844 Wai Tsuen Road	No.47-51 Wai Tsuen Road
15/1/2015	15/1/2015	15/1/2015	Yeung Uk Tsuen	No.22 Yeung Uk Tsuen

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
	09:00	09:45		
16/1/2015	16/1/2015 15:32	16/1/2015 19:55	200 Tsuen King Circuit	Sheeny Terrace (Fire Service)
17/1/2015	17/1/2015 14:00	17/1/2015 21:30	Near Lamp Post FC3728 Lung Tak Street	No.11 Lung Tak Street, No. 188-202 Texaco Road
19/1/2015	19/1/2015 10:30	19/1/2015 14:15	Near Lamp Post W1983 Kwok Shui Road	Petrol Station
19/1/2015	19/1/2015 14:40	19/1/2015 16:30	Near No. 23-27 Chai Wan Kok Street	No. 23-51 Chai Wan Kok Street
20/1/2015	20/1/2015 14:00	20/1/2015 21:45	Near No. 7 Kin Ming Street	No. 303-313 Castle Peak Road
21/1/2015	21/1/2015 16:10	22/1/2015 02:10	Near No. 301-309 Sha Tsui Road	No.301-309 Sha Tsui Road
21/1/2015	21/1/2015 13:00	21/1/2015 15:30	No. 64 Sham Tseng Village	No.64-69 Sham Tseng Village
22/1/2015	22/1/2015 15:25	22/1/2015 21:30	Near Lamp Post 3296,Chai Wan Kok Street	No. 5-9 Chai Wan Kok Street
22/1/2015	22/1/2015 12:20	22/1/2015 14:50	Near No. 355A Castle Peak Road	No. 355A Castle Peak Road
24/1/2015	24/1/2015 12:20	24/1/2015 14:15	Back Lane of No. 41 Ting Kau Tsuen	No. 40-41 Ting Kau Tsuen
25/1/2015	25/1/2015 17:20	25/1/2015 19:15	Back of No. 12 Hoi Pa Village Northeast Terrace	No.1-12 Hoi Pa Village Northeast Terrace
27/1/2015	28/1/2015 10:10	28/1/2015 11:00	Near Lamp Post 5010 Wun Tung Street, Tsuen Wan	No. 5-7 & 4-12 Wun Tung Street, Tsuen Wan
28/1/2015	28/1/2015 09:20	28/1/2015 11:10	Near No. 77 Chung On Street	No. 77 Chung On Street
2/2/2015	2/2/2015 14:00	2/2/2015 15:10	Near Lamp Post AC2797 Hoi Pa Village Northesat Terrace	Part of Hoi Pa Village Northeast Terrace
3/2/2015	3/2/2015 15:30	3/2/2015 16:30	Near Yuen Tsuen Ancient Trail	Part of Ha Fa Shan Tsuen
5/2/2015	5/2/2015 10:15	5/2/2015 11:00	Near Lamp Post W3734 Sheung Kok Shan Road	Western Monastery
7/2/2015	7/2/2015 18:20	7/2/2015 20:50	Near No. 96 Chung On Street	No. 96 Chung On Street
7/2/2015	7/2/2015 21:15	8/2/2015 01:45	Near Lamp Post VA8102 Lo Wai Sheng Kok Shan	Part of Lo Wai Tsuen

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
9/2/2015	9/2/2015 12:55	9/2/2015 15:45	Near Lamp Post V9334 Sham Tseng Kau Tsuen,	Part of Sham Tseng Kau Tsuen
11/2/2015	11/2/2015 14:35	11/2/2015 17:00	Near Lamp Post VA8585 Lo Wai Road	Part of Lo Wai Tsuen
13/2/2015	13/2/2015 14:20	13/2/2015 16:20	Near Lamp Post FC 4597 Sham Tseng Tsuen	Part of Sham Tseng Tsuen
13/2/2015	13/2/2015 10:30	13/2/2015 11:30	Near No. 42 Ma Wan Main Street Village	Part of Ma Wan Main Street Village
13/2/2015	13/2/2015 18:15	13/2/2015 23:00	Lai Shun Road, Near Lamp Post FA1730B	Fat Yip Lane Substation
15/2/2015	15/2/2015 12:30	15/2/2015 16:15	No. 95 Chai Wan Kok Station	No. 83-95 Chai Wan Kok Street
16/2/2015	16/2/2015 14:40	16/2/2015 16:00	Near 15A Sham Tseng San Tsuen	Part of Sham Tseng San Tsuen
16/2/2015	16/2/2015 11:20	16/2/2015 13:35	Near No. 1 Hilltop, Ham Tin Tsuen	No. 1 Hilltop, Ham Tin Tsuen
17/2/2015	17/2/2015 20:05	17/2/2015 21:30	No. 45 Hoi Pa Resite Village, Yi Pei Chun Road	No. 42-47 Hoi Pa Resite Village
21/2/2015	21/2/2015 17:30	21/2/2015 20:30	No.45 Yau Kom Tau Tsuen Back Lane	45 Yau Kom Tau Tsuen
23/2/2015	23/2/2015 12:55	23/2/2015 15:45	Near Lamp Post AC 4934 Tai Pak Tin Village	Part of Tai Pak Tin Village
24/2/2015	24/2/2015 09:35	24/2/2015 10:20	Near Lamp Post VC0560 Route Twisk	Part of Chuen Lung
26/2/2015	26/2/2015 21:30	27/2/2015 01:00	Near Lamp Post FC3729 Lung Tak Street	No. Lung Tak Street
1/3/2015	1/3/2015 10:00	1/3/2015 11:20	No.45 Yau Kom Tau Tsuen Back Lane	No.45 Yau Kom Tau Tsuen
1/3/2015	1/3/2015 17:25	1/3/2015 21:35	Near Lamp Post FA6906 Fu Yung Shan Road	Chung Kuk Terrace
2/3/2015	2/3/2015 15:38	2/3/2015 16:15	Near No. 45B Fu Yung Shan San Tsuen	Part of Fu Yung Shan San Tsuen
2/3/2015	2/3/2015 09:45	2/3/2015 11:00	No. 36 Chung Kwai Chung Tsuen	No. 36 Chung Kwai Chung Tsuen
3/3/2015	3/3/2015 14:45	3/3/2015 15:50	Near No. 62 Hoi Pa Resite Village	No. 62 Hoi Pa Resite Village
8/3/2015	8/3/2015 16:15	8/3/2015 17:45	Back of No. 124 Sam Tung Uk Resite Village	No. 124 G/F -2/F Sam Tung Uk Resite Village
9/3/2015	9/3/2015	9/3/2015	Kwong Pan Ton San	Kwong Pan Ton San

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
	21:30	23:30	Tsuen Near Lamp Post SUKPT/D/007	Tsuen
12/3/2015	12/3/2015 14:45	12/3/2015 16:45	Near No. 115 Tso Kung Square	No. 105-125 Tso Kung Square
13/3/2015	13/3/2015 15:35	13/3/2015 17:00	Near No. 192 Yau Ma Hom Road	Yau Ma Hom Road & Ya Ma Hom Tsuen
14/3/2015	14/3/2015 15:15	14/3/2015 17:50	No. 86 Lo Wai Tsuen, Lo Wai	No. 81-90 Lo Wai Tsuen
17/3/2015	17/3/2015 14:30	17/3/2015 17:20	Near No. 50 Yuen Tun Village, Tsuen Wan	Yuen Tun Village
18/3/2015	18/3/2015 10:05	18/3/2015 11:10	Near No. 48 Yuen Tung Village	Part of Yuen Tung Village
18/3/2015	18/3/2015 21:15	19/3/2015 01:50	Near No. 59 Chai Wan Kok Street	No. 47-63 Chai Wan Kok Street
19/3/2015	19/3/2015 16:10	19/3/2015 21:00	Near Back Lane of No. 16 Chuen Lung Street	No.15-19 Tsuen Wan Market Street, No. 4-18 Chuen Lung Street, No. 2-4A Shiu Wo Street, No. 19-21 Tai Ho Road
19/3/2015	19/3/2015 09:45	19/3/2015 14:00	Near No. 14 Hoi Pa Village South Terrace	No.13-16 Hoi Pa Village South Terrace
21/3/2015	22/3/2015 11:30	22/3/2015 15:00	No. 101 Fu Yung Shan San Tsuen	Part of Fu Yung Shan
23/3/2015	23/3/2015 15:00	23/3/2015 16:30	No. 35 Fu Yung Shan San Tsuen	No. 37 Fu Yung Shan San Tsuen
26/3/2015	26/3/2015 14:55	26/3/2015 15:35	Near No. 33 Ho Pui Tsuen	No. 33 Hoi Pui Tsuen
26/3/2015	26/3/2015 13:30	26/3/2015 15:00	Near Lamp Post AC1323 Hoi Pa Resite Village	No. 1 Hoi Pa Resite Village
27/3/2015	27/3/2015 10:50	27/3/2015 12:30	Back Lane of No. 75 Tai Pa Street	No. 77-83 Tai Pa Street,
28/3/2015	28/3/2015 09:30	28/3/2015 10:30	No. 13 Hoi Pa Village South Terrace	No. 13 Hoi Pa Village South Terrace
30/3/2015	30/3/2015 13:40	30/3/2015 15:40	Near No. 11 Chai Wan Kok Street	No. 11-15 Chai Wan Kok Street
30/3/2015	30/3/2015 17:45	30/3/2015 18:40	Near Lamp Post FA06906 Fu Yung Shan Road	Part of Fu Yung Shan
30/3/2015	30/3/2015 14:20	30/3/2015 15:40	Near Lamp Post VA5830 Fu Yung Shan Road	Part of Fu Yung Shan
31/3/2015	31/3/2015 22:00	1/4/2015 02:30	Near Lamp Post V9396 Chuen Lung Street	Part of Chuen Lung Street

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
1/4/2015	1/4/2015 09:55	1/4/2015 11:30	Near No. 68 Ho Pui Tsuen	No. 68-73 Ho Pui Tsuen
3/4/2015	3/4/2015 16:31	3/4/2015 21:00	No. 9 Yeung Uk Tsuen	No.8-9 Yeung Uk Tsuen
6/4/2015	6/4/2015 15:12	6/4/2015 21:30	Near No. 23-25 Heung Che Street	Heung Che Street Refuse Collection Point.
8/4/2015	8/4/2015 14:10	8/4/2015 15:15	Near No. 47-53 Shiu Wo Street	No. 47-51 Shiu Wo Street
8/4/2015	8/4/2015 14:21	8/4/2015 17:15	Near No. 932 Kwan Mun Hau Tsuen	No. 29-37 , 111-116, 105-110, 927-932 Kwan Mun Hau Tsuen
9/4/2015	9/4/2015 10:30	9/4/2015 12:25	Near No. 81 Lo Wai	Part of Lo Wai
9/4/2015	9/4/2015 14:00	9/4/2015 15:00	Near Lamp Post FB8522 Lo Wai	Part of Lo Wai
14/4/2015	14/4/2015 14:20	14/4/2015 15:10	Near Lamp Post VC2157 Lo Wai	Part of Lo Wai
14/4/2015	14/4/2015 09:55	14/4/2015 12:00	Near No. 51B Lo Wai	No.50 Lo Wai, Tsuen Wan
16/4/2015	16/4/2015 12:00	16/4/2015 15:10	Near No. 31C Chuen Lung	No.31C Chuen Lung
16/4/2015	16/4/2015 10:20	16/4/2015 11:35	Near No. 53 Hoi Pa San Tsuen	No. 50-53 Hoi Pa San Tsuen
20/4/2015	20/4/2015 18:00	20/4/2015 19:20	Near No. 63 Hoi Pa Resite Village	No. 63 Hoi Pa Resite Village
21/4/2015	21/4/2015 06:00	21/4/2015 12:55	Near Lamp Post AC1254 Tsuen Kwai Street, Tsuen Wan	No.36-48 Tsuen Wah Street, No. 1-27 Tsuen Kwai Street, No. 1-21 Tsuen Fu Street
22/4/2015	22/4/2015 04:55	22/4/2015 09:30	No. 73 Sam Tung Uk Resite Village	No. 73-74 Sam Tung Uk Resite Village
23/4/2015	23/4/2015 14:40	23/4/2015 15:55	Near No. 7 Hoi Pa Restie Village	No. 2-9 Hoi Pa Restie Village
27/4/2015	27/4/2015 09:50	27/4/2015 11:40	Near Lamp Post FB6176 Sheung Kwai Chung Tsuen	No. 78-79 Sheung Kwai Chung Tsuen
28/4/2015	28/4/2015 09:55	28/4/2015 11:30	Back of No. 251 Wo Yi Hop Road	No. 249-335 Wo Yi Hop Road, No.1-17 Lei Shui Road
8/5/2015	8/5/2015 14:05	8/5/2015 15:45	Near Lamp Post VC 1659 Chuen Lung Street	No. 72-78 Chuen Lung
10/5/2015	10/5/2015 14:45	10/5/2015 16:30	Back of No. 36 Han Tin Tsuen Kwok Shui Road	No. 34-37 Han Tin Tsuen
11/5/2015	11/5/2015	12/5/2015	Near No. 83 Chai Wan	No. 83-95 Chai Wan Kok

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
	16:45	00:20	Kok Street	Street
12/5/2015	12/5/2015 20:00	12/5/2015 22:45	Near No. 408B Sham Tseng San Tsuen	Part of Sham Tseng San Tsuen
18/5/2015	18/5/2015 11:00	18/5/2015 23:30	Near No. 11 Lung Tak Street	No. 11 Lung Tak Street, No. 188-202 Texaco Road
21/5/2015	21/5/2015 23:00	22/5/2015 06:00	Near Lamp Post FC2623, Castle Peak Road	Fire Service of Kong Nam Industrial Building
26/5/2015	26/5/2015 18:40	26/5/2015 19:40	Near DD454 Lot 267, Shing Mun Lane	Part of Wo Yi Hop Tsuen
1/6/2015	1/6/2015 20:30	1/6/2015 23:00	Near No. 9 Hoi Pa Village South Terrace	No. 1-21 Hoi Pa Village South Terrace
2/6/2015	2/6/2015 14:30	2/6/2015 16:30	Back of No. 10 Hoi Pa Village South Terrace	No. 1-21 Hoi Pa Village South Terrace
4/6/2015	4/6/2015 11:05	4/6/2015 17:10	Near No. 65A Fu Yung Shan San Tsuen	Part of Fu Yung Shan San Tsuen
6/6/2015	6/6/2015 13:50	6/6/2015 18:00	Near No. 65 San Tsuen, Fu Yung Shan Road	No. 65 San Tsuen
7/6/2015	7/6/2015 18:40	7/6/2015 19:40	Near No. 22 Hoi Pa Village Northeast Terrace	Part of Hoi Pa Village Northeast Terrace
8/6/2015	8/6/2015 15:20	8/6/2015 17:10	Near Lamp Post AC13023 Hoi Pa Resite Village	No. 1-9 Hoi Pa Resite Village
18/6/2015	18/6/2015 18:20	18/6/2015 19:25	Near Lamp Post W1976 Shing Mun Road	No. 2-9 Shing Mun Road,
19/6/2015	19/6/2015 15:30	19/6/2015 17:05	No. 3 Ho Pui Tsuen	No. 3 Ho Pui Tsuen
19/6/2015	19/6/2015 14:30	19/6/2015 16:15	No. 12 Tak Wah Street	No. 12 Tak Wah Street
19/6/2015	19/6/2015 09:40	19/6/2015 11:45	Near No. 3 Yeung Uk Tsuen	No. 2-3 Yeung Uk Tsuen
19/6/2015	19/6/2015 19:15	19/6/2015 20:45	No. 21 Muk Min Ha Tsuen	No. 21 Muk Min Ha Tsuen
21/6/2015	22/6/2015 00:00	22/6/2015 11:00	Near No. 8 Hoi Pa Street	No. 1-9 Hoi Pa Street
21/6/2015	21/6/2015 10:30	21/6/2015 12:00	Near No. 139 Kui Tau Tsuen,	No. 139 Kui Tau Tsuen
22/6/2015	22/6/2015 15:50	22/6/2015 17:00	Near No. 225 Wo Yi Hop Road	Wo Yi Hop Road Substation
23/6/2015	23/6/2015 15:10	23/6/2015 22:00	Near No. 103 Hoi Pa Street	No. 103-117 Hoi Pa Street, No. 45-55 Tai Ho Road, No. 4-12 Tsuen

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
				Wan Market Street,
26/6/2015	26/6/2015 14:45	26/6/2015 16:40	Back Lane of No. 8 Muk Nin Ha Tsuen	No. 1-16 Muk Min Ha Tsuen
30/6/2015	30/6/2015 11:00	30/6/2015 11:30	Back Lane of No. 11 Northeast Terrace	No. 11 of Northeast Terrace
2/7/2015	2/7/2015 17:30	2/7/2015 18:50	Near No. 12 Hoi Pa San Tsuen	No. 12 Hoi Pa San Tsuen
6/7/2015	6/7/2015 17:35	6/7/2015 19:20	Near Lamp Post V9313 Ham Tin Tsuen	Part of Ham Tin Tsuen
7/7/2015	7/7/2015 13:30	7/7/2015 14:40	Near No. 25 Ho Pui Tsuen	No. 25-28 Ho Pui Tsuen
7/7/2015	7/7/2015 16:25	7/7/2015 17:20	No. 24 Ho Pui Tsuen	No. 21-24 Ho Pui Tsuen
7/7/2015	7/7/2015 17:45	7/7/2015 21:00	Near No. 6 Ho Pui Tsuen	No. 5-7 Ho Pui Tsuen
7/7/2015	7/7/2015 16:00	7/7/2015 17:00	Back of No. 80 Sam Tung Uk Resite Village	No. 80 Sam Tung Uk Resite Village
8/7/2015	8/7/2015 16:30	8/7/2015 17:30	Near Fire Hydrant 240 Kwok Shui Road	Part of Kwok Shui Road
10/7/2015	10/7/2015 17:45	10/7/2015 18:50	Back of No. 96 Kwan Mun Hau Tsuen	Kwan Mun Hau Tsuen Garden
12/7/2015	12/7/2015 09:10	12/7/2015 12:30	Back Lane of No. 48 Ho Pui Street	No. 48 Ho Pui Street
13/7/2015	13/7/2015 15:30	13/7/2015 17:00	Near Lamp Post V9687 Sham Tseng San Tsuen	No. 9-30 Sham Tseng San Tsuen
14/7/2015	14/7/2015 15:50	14/7/2015 17:15	Back Lane of No. 25 Sham Tseng Village	No. 25 Sham Tseng Village
15/7/2015	15/7/2015 18:40	15/7/2015 22:20	Back Lane of No.35 Tai Pak Tin Village	No.35 Tai Pak Tin Village
16/7/2015	16/7/2015 13:55	16/7/2015 16:50	Near Lamp Post W0476 Kwok Shui Road	No. 143 Kwok Shui Road
17/7/2015	17/7/2015 10:45	17/7/2015 11:55	Near No. 21 Chung On Street	No.38-44 Siu Wo Street No. 13-19 Chung On Street
17/7/2015	18/7/2015 20:30	18/7/2015 22:00	Near Lamp Post FA4885 Yan Chai Street	No. 18 Yan Chai Street
18/7/2015	18/7/2015 16:00	18/7/2015 19:30	Back of No. 109 Lo Wai Tsuen	No.100-110 Lo Wai Tsuen
19/7/2015	19/7/2015 10:30	19/7/2015 13:30	Back of No. 34 Yeung Uk Tsuen	No. 34 Yeung Uk Tsuen
20/7/2015	20/7/2015 13:50	20/7/2015 16:17	Near 272 Yau Ma Hom Resite Village	No. 272 Yau Ma Hom Resite Village

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
23/7/2015	23/7/2015 17:15	23/7/2015 18:30	Beside of No. 11 Hoi Pa Village Northeast Terrace	No. 1-12 Hoi Pa Village Northeast Terrace
24/7/2015	24/7/2015 11:35	24/7/2015 12:15	Near 43 Ham Tin Tsuen	No. 42-44 Ham Tin Tsuen
24/7/2015	25/7/2015 09:45	25/7/2015 12:00	Near No. 12 Sham Tseng San Tsuen	Part of Sham Tseung San Tsuen
25/7/2015	25/7/2015 13:15	25/7/2015 17:25	Near Lamp Post W2696 Route Twisk	Part of Kwong Pan Tin Tsuen
29/7/2015	29/7/2015 16:30	29/7/2015 17:45	Opposite Lamp Post W0476 Kwok Shui Road	PCCW Kwok Shui Road
30/7/2015	30/7/2015 12:16	30/7/2015 13:25	Near No.37 Ho Pui Tsuen	No.37-40 Ho Pui Tsuen
31/7/2015	31/7/2015 20:00	31/7/2015 21:50	Back Lane of No. 60B Sham Tseng Kau Tsuen	No. 18B Sham Tseng Kau Tsuen
3/8/2015	3/8/2015 11:07	3/8/2015 11:27	Near No. 17 Lei Shu Road	No. 17 Lei Shu Road
6/8/2015	6/8/2015 14:18	6/8/2015 16:35	Near No. 145-149 Kwok Shui Road	No. 145-149 Kwok Shui Road
10/8/2015	10/8/2015 15:15	10/8/2015 15:58	Near Lamp Post W0535 Kwok Shui Road	No. 145-149 Kwok Shui Road
12/8/2015	12/8/2015 10:20	12/8/2015 11:40	Near No. 55 Sham Tseng Village	Part of Sham Tseng Village
12/8/2015	12/8/2015 16:00	12/8/2015 17:00	No.50 Yau Kam Tau Village	No. 50 Yau Kam Tau Village
12/8/2015	12/8/2015 13:35	12/8/2015 17:00	Near DP360 Chuen Lung Village	Chuen Lung Village Aqua Privy
13/8/2015	13/8/2015 15:50	13/8/2015 18:30	Back of No. 1 Yeung Uk Tsuen Kwok Shui Road	No. 1-2 Yeung Uk Tsuen
14/8/2015	14/8/2015 19:30	15/8/2015 02:10	Near No. 21 Pak Tin Par Street	No. 5-39 Pak Tin Par Street
14/8/2015	14/8/2015 13:19	14/8/2015 14:25	Near No.167-185 Tsuen King Circuit	No.167-185 Tsuen King Circuit
18/8/2015	18/8/2015 10:30	18/8/2015 14:00	Near No. 25 Ting Kau Village	No. 12 Ting Kau Village
19/8/2015	19/8/2015 17:00	19/8/2015 19:50	Near No. 268 Yau Ma Hom Resite Village	No. 268 Yau Ma Hom Resite Village
19/8/2015	19/8/2015 13:43	19/8/2015 16:20	Back Lane of No. 146 Sha Tsui Road,	No.146 Sha Tsui Road, Tsuen Wan
20/8/2015	20/8/2015 08:45	20/8/2015 16:30	Near Lamp Post W2707 Tai Ho Road	Tsuen Wan District Junior Police Call Club House
27/8/2015	27/8/2015	27/8/2015	Near Lamp Post V3854,	Chai Wan Kok Village,

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
	10:20	12:58	Hon man Tsuen	Ha Fa Shan Village and part of Hon Man Tsuen
27/8/2015	27/8/2015 08:00	27/8/2015 11:45	Back Lane of No. 11 Tak Hoi Street	No. 11 Tak Hoi Street,
29/8/2015	29/8/2015 09:20	29/8/2015 11:20	No. 85 of Back Lane of Lo Wai Tsuen	No.55, 83,84,85,86 Lo Wai Tsuen
31/8/2015	31/8/2015 14:04	31/8/2015 14:36	Near No.21 Hoi Pa Resite Village	No.16-21 Hoi Pa Resite Village
3/9/2015	3/9/2015 13:50	3/9/2015 14:45	Near Lamp Post VC0603 Kwong Pan Tin Tsuen	Part of Kwong Pan Tin Tsuen
3/9/2015	3/9/2015 11:38	3/9/2015 13:00	Near No. 126 Lo Wai Village	No. 126 Lo Wai
4/9/2015	4/9/2015 13:10	4/9/2015 14:00	Near No. 88E Sham Tseng San Tsuen	No. 88E Sham Tseng San Tsuen
7/9/2015	7/9/2015 10:30	7/9/2015 11:05	Near No. 20 Hoi Pa Rsite Village	No. 16-21 Hoi Pa Resite Village
9/9/2015	9/9/2015 20:03	9/9/2015 22:05	Near 20 Hoi Pa Resite Village	No. 16-21 Hoi Pa Resite Village
10/9/2015	10/9/2015 13:50	10/9/2015 14:10	Near Lamp Post FB5808 Ma Wan Fishermen's Village, Ma Wan	Ma Wan Fishermen's Village Aqua Privy
14/9/2015	14/9/2015 18:18	14/9/2015 21:00	Near No. 101 Route Twisk	Part of Kwong Pan Tin Tsuen
15/9/2015	15/9/2015 14:50	15/9/2015 15:30	Near Lamp Post FA5494, Route Twisk	Part of Kwong Pan Tin Tsuen
19/9/2015	19/9/2015 15:00	19/9/2015 17:30	Near No. 22 Ting Kau Village	No. 20 Ting Kau Village
19/9/2015	19/9/2015 16:00	19/9/2015 17:00	No. 97 Back Lane of Sam Tung Uk Tsuen	No. 97 of Sam Tung Uk Tsuen
20/9/2015	20/9/2015 11:06	20/9/2015 11:15	Near Fire Hydrant 11336 at Lung Yue Road, Tsing Lung Tau	Yuen Tun Village
21/9/2015	21/9/2015 15:05	21/9/2015 15:35	Near No. 4 Ka Loon Tsuen	No. 4 Ka Loon Tsuen
24/9/2015	24/9/2015 10:41	24/9/2015 11:50	Near 220 Yau Ma Hom Resite Village,	220 Yau Ma Hom Resite Village
25/9/2015	25/9/2015 18:45	25/9/2015 22:30	Near Lamp Post FA4650 Ma Kok Lane	Wang Lung Street, Ma Kok Lane, Part of Texaco Road
30/9/2015	30/9/2015 16:10	30/9/2015 19:50	No.7A of Wang Lung Tsuen	No.7A Wang Lung Tsuen
2/10/2015	2/10/2015	2/10/2015	Near No.11-15 Tso	No.11-15 Tso Kung

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
	14:10	17:31	Kung Square	Square
2/10/2015	2/10/2015 20:05	2/10/2015 22:15	Near No. 35 Chuen Lung Tsuen	Part of Chuen Lung Tsuen
8/10/2015	8/10/2015 14:29	8/10/2015 19:16	Near No.18 Sam Tung Uk Resite Village	No.11-18 Sam Tung Uk Resite Village
11/10/2015	11/10/2015 14:10	11/10/2015 16:50	No. 41 Back Lane of Wo Yi Hop Village	Part of Wo Yi Hop Village
13/10/2015	13/10/2015 10:40	13/10/2015 17:15	Near Lamp Post W3296 Chai Wan Kok Street	No. 11-15 Chai Wan Kok Street
15/10/2015	15/10/2015 14:43	15/10/2015 15:13	Near No. 11 Lo Wai	Part of Lo Wai
16/10/2015	16/10/2015 11:10	16/10/2015 12:20	Near No. 57A Sham Tseng San Tsuen	No. 57, 57A Sham Tseng San Tsuen
16/10/2015	16/10/2015 15:50	16/10/2015 17:00	Near No. 25 Ting Kau Village	Part of Ting Kau Village
16/10/2015	16/10/2015 11:20	16/10/2015 12:30	Near No. 112 Kwan Mun Hau Tsuen	No. 112 Kwan Mun Hau Tsuen
19/10/2015	19/10/2015 14:45	19/10/2015 16:30	Near Lamp Post V1807 Yuen Tun Village	Yuen Tun Village
20/10/2015	20/10/2015 12:05	21/10/2015 00:30	Near No.10-16 Pun Shan Street	No.10-16,Pun Shan Street
21/10/2015	21/10/2015 10:30	21/10/2015 14:50	Back Lane of No.20 Hoi Pa Village North-East Terrace	No.19-22 Hoi Pa Village Northeast Terrace
23/10/2015	24/10/2015 10:25	24/10/2015 11:25	Near Lamp Post FB9306, Hoi Pa Village Northeast Terrace	Refuse Collection Point at Hoi Pa Village Northeast Terrace
24/10/2015	24/10/2015 13:45	24/10/2015 16:35	Near Lamp Post DC1204 Tsuen Wan Market Street	Part of Tsuen Wan Market Street
25/10/2015	25/10/2015 11:15	25/10/2015 17:30	Near Fire Hydrant 79 Chai Wan Kok Street	No.66-82 Chai Wan Kok Street
26/10/2015	26/10/2015 09:20	26/10/2015 12:30	Near No.11 Chai Wan Kok Street	No.11-15 Chai Wan Kok Street
27/10/2015	27/10/2015 14:30	27/10/2015 15:35	Near No.325-331 Sha Tsui Road	No.325-331 Sha Tsui Road
27/10/2015	27/10/2015 10:45	27/10/2015 11:23	Near No.49 Sham Tseng San Tsuen, Sham Tseng	Part of Sham Tseng San Tsuen
28/10/2015	28/10/2015 16:53	28/10/2015 18:23	Near No.19 Hoi Pa Village Northeast Terrace	No.19-22 Hoi Pa Village Northeast Terrace
30/10/2015	30/10/2015 11:15	30/10/2015 13:50	Near No.45 Shui Wo Street	No.45 Shui Wo Street.
1/11/2015	1/11/2015	1/11/2015	Near No.75 Chai Wan	No.71-75 Chai Wan Kok

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
	10:00	15:00	Kok Street	Street
2/11/2015	2/11/2015 10:30	2/11/2015 11:30	Near No.17 Hoi Pa Village South Terrace	Hoi Pa Village South Terrace
3/11/2015	3/11/2015 11:25	3/11/2015 12:45	Near No.55 Pak Lam Road, Ma Wan	No.55 Pak Lam Road, Ma Wan
5/11/2015	5/11/2015 10:50	5/11/2015 11:30	Near No.35 Ho Pui Street	No.33-37 Ho Pui Street, No.34-42 San Tsuen Street
5/11/2015	5/11/2015 15:20	5/11/2015 20:00	Near Lamp Post TWH014 Circle Park	Kwok Shui Road Park, Tai Wo Hau MTR Station.
6/11/2015	6/11/2015 09:00	6/11/2015 12:00	Back Lane No.255 Wo Yi Hop Road	No.249-255 Wo Yi Hop Road
6/11/2015	6/11/2015 13:40	6/11/2015 14:05	Near No.95 Chai Wan Kok Street	No.95 Chai Wan Kok Street
7/11/2015	7/11/2015 22:00	8/11/2015 01:45	Near No.41 Tung Wo Road	No.41 Lo Wai Tsuen
7/11/2015	7/11/2015 16:00	7/11/2015 17:05	Near Fire Hydrant 86 Tai Ho Road	Part of Tsuen Wan Market Street and Chuen Lung Street
9/11/2015	9/11/2015 16:05	9/11/2015 18:15	Near Lamp Post AC4744 Pak Yan Road Ma Wan	Ma Wan Police Post
10/11/2015	10/11/2015 13:05	10/11/2015 15:00	Near No.51 Ho Pui Tsuen	No.51 Ho Pui Tsuen
13/11/2015	13/11/2015 10:45	13/11/2015 11:12	Near 179 Ma Wan Rural Committee Road, Ma Wan	179 Ma Wan Rural Committee Road, Ma Wan
16/11/2015	16/11/2015 10:50	16/11/2015 12:40	Near No.69 Sam Tung Uk Resite Village	No.69 San Tung Uk Resite Village
17/11/2015	17/11/2015 10:05	17/11/2015 15:46	Near No.5 Chung Kwai Chung Tsuen	No.5 Chung Kwai Chung Tsuen
17/11/2015	18/11/2015 00:25	18/11/2015 04:00	No.40 Chai Wan Kok Street	No.20-60 Chai Wan Kok Street, NO.9 Hoi Shing Road
17/11/2015	17/11/2015 16:45	17/11/2015 19:15	Near No.49 Chung On Street	No.47-49 Chung On Street
18/11/2015	18/11/2015 17:06	18/11/2015 19:36	Near No.19B Lo Wai	Part of Lo Wai Tsuen
18/11/2015	18/11/2015 10:28	18/11/2015 11:38	Near No.8 Tai Ho Road	No.8 Tai Ho Road, Tsuen Wan
19/11/2015	19/11/2015 15:35	19/11/2015 16:30	Near Lamp Post SU KPT/0/0009, Kwong Pan Tin Tsuen	Part of Kwong Pan Tin Tsuen

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
21/11/2015	21/11/2015 16:30	21/11/2015 18:45	Near No.35 Lo Wai, Yi Pei Chun Road	Part of Lo Wai
21/11/2015	21/11/2015 09:50	21/11/2015 12:35	Back of No.319 Wo Yi Hop Road	No.39 Wo Yi Hop Road
24/11/2015	24/11/2015 11:00	24/11/2015 13:20	Near No.61 Sam Tung UK Resite Village	No.61 Sam Tung UK Resite Village
25/11/2015	25/11/2015 12:30	25/11/2015 17:00	Near No.30 Tso Kung Square	No.2-32 Hoi Pa Street and 2-36 Tso Kung Square
26/11/2015	26/11/2015 21:00	26/11/2015 22:45	Near No.202-216 Sai Lau Kok Road	No.202-216 Sai Lau Kok Road
27/11/2015	27/11/2015 09:30	27/11/2015 11:30	Near Lamp Post FC0594 Chai Wan Kok Street	No.38-40 Chai Wan Kok Street
28/11/2015	28/11/2015 16:30	28/11/2015 17:30	No.286 B/C of Yau Ma Hom Tsuen, Tsuen Wan	No.284-290 Yau Ma Hom Tsuen
28/11/2015	28/11/2015 10:00	28/11/2015 12:20	No.47 Back Lane of Fu Yung Shan San Tsuen	No.47 Fu Yung Shan San Tsuen
30/11/2015	30/11/2015 22:20	1/12/2015 01:45	Near Lamp Post DC 1203 Tsuen Wan Market Street	Jockey Club Tak Wah Park Toilet
30/11/2015	30/11/2015 12:00	30/11/2015 12:30	Near No.2-6 Lo Tak Court	No.2-6 Lo Tak Court
1/12/2015	1/12/2015 11:20	1/12/2015 12:25	Near No.38 Chai Wan Kok Street	No.30 to 40 Chai Wan Kok Street
1/12/2015	1/12/2015 09:30	1/12/2015 15:59	Near 2 Sam Pei Square, Tsuen Wan.	2-12 Sam Pei Square, 98-100 Chung On Street.
4/12/2015	4/12/2015 14:10	4/12/2015 16:10	Near Lamp Post VC2209 Sheung Kwai Chung Village	Part of Sheung Kwai Chung Village
4/12/2015	4/12/2015 12:45	4/12/2015 13:45	Near No.58 Sham Tseng San Tsuen	Part of Sham Tseng San Tsuen
7/12/2015	7/12/2015 14:20	7/12/2015 15:24	Near No.13 Chung Kwai Chung Tsuen	No.13 Chung Kwai Chung Tsuen
8/12/2015	8/12/2015 14:00	8/12/2015 15:20	Near Lamp Post W3685 Hoi Kwai Road	Skyline Plaza
10/12/2015	10/12/2015 10:45	10/12/2015 11:50	Near No.6 Chung Kwai Chung Tsuen	No.8-9 Chung Kwai Chung Tsuen
10/12/2015	10/12/2015 09:45	10/12/2015 11:00	Back Lane of No.5 Fu Yung Street	No.1-5 Fu Yung Street
11/12/2015	11/12/2015 20:45	11/12/2015 23:00	Back Lane of No.14 Tak Wah Street	No.14 Tak Wah Street

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
13/12/2015	13/12/2015 14:00	13/12/2015 16:40	Back of No.214 Yau Ma Hom Resite Village	No.214 Yau Ma Hom Resite Village
14/12/2015	15/12/2015 10:15	15/12/2015 12:45	Near No.124 Fu Yung Shan San Tsuen	No.101-147,Fu Yung Shan San Tsuen
15/12/2015	15/12/2015 10:35	15/12/2015 14:00	Back Lane of No.60 Muk Min Ha Tsuen	No.55 to 64 Muk Min Ha Tsuen
16/12/2015	16/12/2015 10:00	17/12/2015 00:30	Near Lamp Post FC1367 Lo Wai Road	Part of Lo Wai
16/12/2015	16/12/2015 10:08	16/12/2015 14:42	Near No.22 Sam Pei Square	No.16-26 Sam Pei Square
17/12/2015	17/12/2015 14:15	17/12/2015 15:20	Near Lamp Post FC0595 Chai Wan Kok Street	No.38-40 Chai Wan Kok Street
18/12/2015	18/12/2015 12:10	18/12/2015 12:45	Near No.71 Muk Min Ha Tsuen	No.71 Muk Min Ha Tsuen
18/12/2015	18/12/2015 15:30	18/12/2015 17:15	Beside of No.7 Hoi Pa Village Northeast Terrace	No.1-12 Hoi Pa Village Northeast Terrace
19/12/2015	19/12/2015 20:00	19/12/2015 21:00	Near No.25 Sham Tseng San Tsuen, Sham Tseng	Part of Sham Tseng San Tsuen
20/12/2015	20/12/2015 16:30	20/12/2015 18:45	Near No.131-133 Tsuen Wan Market Street	No.131-133 Tsuen Wan Market Street, Kwan Mun Hau Garden
21/12/2015	21/12/2015 06:30	21/12/2015 11:35	Near No.68 Sha Tsui Road	No.68 Sha Tsui Road
21/12/2015	21/12/2015 09:30	21/12/2015 11:20	Back of No.112 Chung On Street	No.112 Chung On Street
29/12/2015	29/12/2015 10:20	29/12/2015 12:00	Near No.40B Sham Tseng San Tsuen, Sham Tseng	No.40A-B,Sham Tseng San Tsuen, Sham Tseng
29/12/2015	29/12/2015 16:40	29/12/2015 17:30	Near 45 Sham Tseng San Tsuen, Sham Tseng	Part of Sham Tseng San Tsuen
30/12/2015	30/12/2015 11:24	30/12/2015 14:18	Near No.123 Fu Yung Shan San Tsuen	No.123 Fu Yung Shan San Tsuen
31/12/2015	31/12/2015 11:03	31/12/2015 12:46	Near No.29 Fu Yung Shan San Tsuen	No.29-31 Fu Yung Shan San Tsuen
31/12/2015	31/12/2015 16:00	31/12/2015 18:00	Near No.31B Sham Tseng San Tsuen, Sham Tseng	No.31B Sham Tseng San Tsuen
31/12/2015	31/12/2015 10:15	31/12/2015 11:40	Near Lamp Post VA2605 San Tsuen,Fu Yung Shan Road	Part of San Tsuen
1/1/2016	1/1/2016 09:30	1/1/2016 11:30	Near No.292 Sha Tsui Road	No.292 Sha Tsui Road

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
2/1/2016	2/1/2016 07:15	2/1/2016 11:45	Near 1-9 Sha Tsui Road	No.503-515 Castle Peak Road, Tsuen Wan
4/1/2016	4/1/2016 14:30	4/1/2016 15:25	Near No.80A2 Sham Tseng San Tsuen	No.80A2 Sham Tseng San Tsuen
5/1/2016	5/1/2016 19:45	6/1/2016 01:30	Near No.38 Chai Wan Kok Street	No.38-40 Chai Wan Kok Street
5/1/2016	5/1/2016 14:15	5/1/2016 16:15	Near Lamp Post BC 2141 of Ha Fa Shan	Ngor Tei & Ha Fa Shan
8/1/2016	8/1/2016 11:15	8/1/2016 12:05	Near Swan Neck 5245 of Lo Wai Tsuen	Part of Lo Wai Tsuen
8/1/2016	8/1/2016 14:00	8/1/2016 15:00	Near No.10 Yi Pei Square	No.10-32 Yi Pei Square(even no.) No.101-123 Chuen Lung Street(odd no.)
11/1/2016	11/1/2016 17:00	11/1/2016 17:50	No.60 Kwan Mun Hau Tsuen	No.55 Kwan Mun Hau Tsuen
11/1/2016	11/1/2016 15:30	11/1/2016 16:15	No.101 Back Lane of Chuen Lung Street	No.55,59 Ho Pui Street, No.10-32 Yi Pei Square, No.101-123 Chuen Lung Street
12/1/2016	12/1/2016 10:20	12/1/2016 11:20	130 Lo Wai Tsuen	No.90-130 Lo Wai Tsuen
13/1/2016	13/1/2016 11:15	13/1/2016 12:45	2-4 Hoi Pa Street Back Lane	No.2-4 Hoi Pa Street
14/1/2016	15/1/2016 13:25	16/1/2016 01:00	Near Lamp Post W1532 Kwok Shui Road	Kwok Shui Road Park & Tai Wo Hau MTR
15/1/2016	15/1/2016 14:00	15/1/2016 15:40	No.85 Back Lane of Chuen Lung Street	No.87-89 Chuen Lung Street, No.237 Sha Tsui Road
17/1/2016	17/1/2016 14:00	17/1/2016 14:45	Back Lane of No.128 Lo Wai Tsuen	No.122-136 Lo Wai Tsuen
20/1/2016	20/1/2016 11:10	20/1/2016 11:25	No.9 Back Lane of Yuen Tun Village Tsing Lung Tan	Yuen Tun Village
23/1/2016	23/1/2016 21:56	24/1/2016 00:11	Near Lamp Post FB5088 Mei Wan Street	Mei Wan Street Substation
25/1/2016	25/1/2016 14:30	25/1/2016 15:20	Near Wo Yi Hap Road 271, Tsuen Wan.	249-335 Wo Yi Hop Road, 1-17 Lei Shu Road
25/1/2016	25/1/2016 11:30	25/1/2016 16:00	Near No.62 Sha Tsui Road	No.62 Sha Tsui Road
26/1/2016	26/1/2016 16:24	26/1/2016 18:46	Near 207 Sha Tsui Road	207 Sha Tsui Road
31/1/2016	31/1/2016 10:10	31/1/2016 15:20	Back Lane of No.45 Hoi Pa Resite Village, Yi Pei	No.45 Hoi Pa Resite Village

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
			Chun Road	
3/2/2016	3/2/2016 16:00	3/2/2016 23:30	Near No.81 Ho Pui Street	No.71-81 Ho Pui Street, No.60-64 Ham Tin Street
3/2/2016	3/2/2016 10:00	3/2/2016 11:00	Near Lamp Post VA2578 Lo Wai Tsuen	Lo Wai Tsuen - Tung Kwu Shek
4/2/2016	4/2/2016 11:20	4/2/2016 11:50	Near No.80B Sham Tseng Kau Tsuen, Sham Tseng	Part of Sham Tseng Kau Tsuen
5/2/2016	5/2/2016 17:00	5/2/2016 18:00	Near No.2 Tai Kiu Tsuen, Route Twisk	Part of Tai Kiu Tsuen.
5/2/2016	5/2/2016 14:35	5/2/2016 16:10	Near No.48 Ma Wan Main Street	Ma Wan Main Street
7/2/2016	7/2/2016 23:50	8/2/2016 04:50	Near No.23-27 Tsuen King Circuit	No.23-27 Tsuen King Circuit, Waylee Industrial Centre, Tsuen King Garden and Tsuen Wan Centre
7/2/2016	7/2/2016 10:50	7/2/2016 11:30	Near 35 Ho Pui Tsuen	Ho Pui Tsuen
9/2/2016	9/2/2016 15:50	9/2/2016 16:45	Near No.119 Tsuen Wan Market Street	No.111-119 Tsuen Wan Market Street
11/2/2016	11/2/2016 19:55	11/2/2016 23:00	No.47 Back Lane of Ho Pui Street	No.125 Chuen Lung Street
12/2/2016	12/2/2016 13:55	12/2/2016 16:45	Back of No.89 Sham Tseng Village	No.89 Sham Tseng Village
17/2/2016	17/2/2016 15:00	17/2/2016 16:00	Near No.199 Tsuen King Circuit	No.199 Tsuen King Circuit
18/2/2016	18/2/2016 16:05	18/2/2016 18:05	Near Fire Hydrant 11336 of Lung Yue Road	Yuen Tun Village
20/2/2016	20/2/2016 19:30	20/2/2016 20:45	Near 16DXE, Lo Wai	16 D & E Lo Wai
26/2/2016	26/2/2016 10:40	26/2/2016 11:50	Near No.81 Lo Wai Tsuen	No.113-116 Lo Wai Tsuen
1/3/2016	1/3/2016 04:40	1/3/2016 15:00	Back Lane of No.9-31 Tai Pei Square	No. 25-53 Chung On Street, No.120-150 Hoi Pa Street, No.31-89 Chuen Lung Street, No.9-31 Tai Pei Square
2/3/2016	2/3/2016 18:20	2/3/2016 19:00	Near 48 Kwan Mun Hau Tsuen	Kwan Mun Hau Tsuen
3/3/2016	3/3/2016 16:30	4/3/2016 02:30	Near No.10-20 Pun Shan Street	No.10-20 Pun Shan Street
4/3/2016	4/3/2016	4/3/2016	Near No.1A, Route	No. 1A,Route Twisk

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
	11:20	13:30	Twisk	
5/3/2016	5/3/2016 18:03	5/3/2016 19:16	Near 8,Hoi Pa Tsuen	1-9,Hoi Pa Tsuen,Tsuen Wan
7/3/2016	7/3/2016 18:20	7/3/2016 21:00	Near No.DD453 Fu Yung Shan San Tsuen	No.DD433 Fu Yung Shan San Tsuen
7/3/2016	7/3/2016 15:30	7/3/2016 16:20	Near Lamp Post FB6175 Sheung Kwai Chung Tsuen Road	No.78-79 Sheung Kwai Chung Tsuen Road
9/3/2016	9/3/2016 18:05	9/3/2016 20:10	No.218 Back Lane of Yau Ma Hom Resite Village	No.218 of Yau Ma Hom Resite Village.
11/3/2016	11/3/2016 19:35	11/3/2016 23:55	Near FA4655 Ma KoK Lane	No.204-248 Texaco Road
18/3/2016	18/3/2016 21:15	18/3/2016 21:45	Near Lamp Post W1974 Planter of Sai Lau Kok Road	HK Examinations of Assessment Authority, Shing Mun Road Substation, New Territories South Region Police Headquarters
18/3/2016	18/3/2016 10:50	18/3/2016 11:45	Near No.37 Sham Tseng Tsuen	No.36-39 Sham Tseng Tsue.
20/3/2016	20/3/2016 12:55	20/3/2016 15:45	Near Lamp Post BC2141 Ha Fa Shan Ngor Tei Route Twisk	Along Ha Fa Shan Ngor Tei
21/3/2016	21/3/2016 09:30	21/3/2016 17:30	Near Lamp Post FC3207 Sha Tsui Road	No.26-36 Sha Tsui Road
31/3/2016	31/3/2016 14:30	31/3/2016 15:10	Near Lamp Post FC3764 Lung Yue Road	No.140 Tsing Lung Tau San Tsuen
1/4/2016	1/4/2016 17:30	1/4/2016 21:35	Near No.3 Sham Tseng East Tsuen	No.1-7 Sham Tseng East Tsuen
4/4/2016	4/4/2016 13:45	4/4/2016 16:30	Near No.180 Chuen Lung, Route Twisk.	Part of Chuen Lung
6/4/2016	6/4/2016 17:15	6/4/2016 19:20	Near Lamp Post FA5508 Route Twisk	Along Kwong Pan Tin Tsuen
7/4/2016	7/4/2016 17:30	7/4/2016 18:40	Near Lamp Post FA1349,Ting Kau Castle Peak Road	No.305, 307, 309 Ting Kau Castle Peak Road
7/4/2016	7/4/2016 17:08	7/4/2016 17:43	Near 160 Lo Wai	No.160-168, Lo Wai
9/4/2016	9/4/2016 15:55	9/4/2016 16:05	No.22 Cariageway of On Yat Street	Block F-R of Allway Gardens, Tsuen King Circuit Wu Chung Swimming pool
11/4/2016	11/4/2016	11/4/2016	Near No.36 Sham Tseng	No.36 Sham Tseng

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
	13:20	15:45	Village	Village
12/4/2016	12/4/2016 17:20	12/4/2016 18:40	Near No.16 Sham Tseng San Tsuen	Part of Sham Tseng San Tsuen
16/4/2016	16/4/2016 15:25	16/4/2016 18:45	Near No.33 Ting Kau Tsuen	No.17-48 Ting Kau Tsuen
21/4/2016	21/4/2016 11:30	21/4/2016 19:00	Near Lamp Post V9344 Choi Yuen Tsuen, Tsing Lung Tau	Part of Lung Tang Road
22/4/2016	22/4/2016 11:10	22/4/2016 12:10	Near Lamp Post VA2261, Pai Min Kok Village	Part of Pai Min Kok Street
22/4/2016	22/4/2016 20:15	22/4/2016 21:30	Back Lane of No.294 Sha Tsui Road	No.286-296 Sha Tsui Road
22/4/2016	22/4/2016 17:15	22/4/2016 18:25	Near Lamp post FA5502, Route Twisk Road	Tso Kung Tam Outdoor Recreation Centre
23/4/2016	23/4/2016 13:00	23/4/2016 15:30	Near No.4 Pai Min Village	Part of Pai Min Kok Village
26/4/2016	26/4/2016 14:55	26/4/2016 16:13	Near 29,Kwan Mun Hau Tsuen	29 Kwan Mun Hau Tsuen
26/4/2016	26/4/2016 14:25	26/4/2016 16:50	Near Lamp Post FA3712 Po Fung Road	Planter at Po Fung Road.
27/4/2016	27/4/2016 16:05	27/4/2016 18:10	Near No.8-18 Lo Tak Court	No.14-18 Lo Tak Court.
28/4/2016	28/4/2016 16:30	28/4/2016 17:40	Near Lamp Post DC1718 Yuen Tun Circuit	Clague Garden Estate.
30/4/2016	30/4/2016 18:05	30/4/2016 18:45	Near No.65 Chuen Lung Street	No.65 Chuen Lung Street.
3/5/2016	3/5/2016 11:00	3/5/2016 12:10	Near Lamp Post V9690 Shu On Terrace	Shu On Terrace
4/5/2016	4/5/2016 17:10	4/5/2016 21:10	Near No.59 Ho Pui Street Back Lane	No.43-65 Ho Pui Street
11/5/2016	11/5/2016 03:00	11/5/2016 04:35	Near No.14 Chung Kwai Chung Tsuen	No.14 Chung Kwai Chung Tsuen
16/5/2016	16/5/2016 22:37	16/5/2016 23:30	Near 109 Sam Tung Uk Resite Village	109 Sam Tung UK Resite Village
17/5/2016	17/5/2016 11:25	17/5/2016 12:35	Near No.329 Wo Yi Hop Road	No.329-335 Wo Yi Hop Road.
18/5/2016	18/5/2016 11:20	18/5/2016 12:05	Near Lamp Post FA1728, Lai Chi Road	Fire Hydrant 4299, Lai Chi Road
19/5/2016	19/5/2016 14:00	19/5/2016 16:10	Near No.4-6 Hoi Pa Street Back Lane	No.2-22 Hoi Pa Street and No.14-36 Tso Kung

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
				Square
19/5/2016	19/5/2016 11:00	19/5/2016 12:00	Near No.20 Hoi Pa Village South Terrace	No.20 Hoi Pa Village South Terrace
19/5/2016	19/5/2016 15:00	19/5/2016 15:35	Near Lamp Post 0995 Hoi Long Path, Tsing Lung Tau	Part of Hoi Long Path.
22/5/2016	22/5/2016 15:30	22/5/2016 16:30	Back of No.7 Lei Shu Road	No.1-17 Lei Shu Road.
23/5/2016	23/5/2016 13:30	23/5/2016 14:45	Near No.2 Ho Pui Tsuen Back Lane	No.1-2 Ho Pui Tsuen.
24/5/2016	24/5/2016 14:10	24/5/2016 16:40	Back Lane of No.28 Hoi Pa Street	No.2-6 Tso Kung Street, No.22-32 Hoi Pa Street, No.2-18 Tso Kung Square
26/5/2016	26/5/2016 16:13	26/5/2016 17:12	Near 31G Sham Tseng San Tsuen, Sham Tseng	Part of Sham Tseng San Tsuen
27/5/2016	27/5/2016 19:25	27/5/2016 22:30	Near Lamp Post V1850 Chuen Lung Tsuen	Part of Chuen Lung Tsuen
2/6/2016	2/6/2016 15:30	2/6/2016 20:05	Near No.129 Sha Tsui Road Back Lane	No.129 Sha Tsui Road
3/6/2016	3/6/2016 21:15	3/6/2016 22:50	Near No.20 Hoi Pa Village South Terrace	No.20 Hoi Pa Village South Terrace
3/6/2016	3/6/2016 10:35	3/6/2016 12:10	Near No.125 Chuen Lung Street	No.101-123 Chuen Lung Street, No.10-32 Yi Pei Square, No.45-53 Ho Pui Street
3/6/2016	3/6/2016 14:35	3/6/2016 15:35	Near No.35 Fu Yung Shan Tsuen	No.35 Fu Yung Shan Tsuen
3/6/2016	3/6/2016 19:50	3/6/2016 20:15	Near No.176 Yau Ma Hom Road	No.172-198 Yau Ma Hom Road
5/6/2016	5/6/2016 14:15	5/6/2016 16:45	Back of No.73 Kwan Mun Hau Tsuen	No.77-80 Kwan Mun Hau Tsuen
7/6/2016	7/6/2016 16:20	7/6/2016 18:25	Near No.5-9 Chai Wan Kok Street	No.5-9 Chai Wan Kok Street
7/6/2016	7/6/2016 14:15	7/6/2016 15:15	Near Lamp Post FB8540 Lo Wai	Part of Lo Wai
8/6/2016	8/6/2016 10:00	8/6/2016 11:06	No.16 Tsing Lung Tau Village	Part of Tsing Lung Tau Village
8/6/2016	8/6/2016 11:05	8/6/2016 11:20	Back Lane, No.196 Yau Ma Hom Village	196 Yau Ma Hom Resite Village
10/6/2016	10/6/2016 20:10	10/6/2016 21:45	Near Bo.151-152 Yi Pei Chun	Part of Yi Pei Chun
18/6/2016	18/6/2016 15:25	18/6/2016 16:35	Near No.139 Lo Wai Yi Pei Chun	No.139-140 Lo Wai Yi Pei Chun

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
21/6/2016	21/6/2016 13:00	21/6/2016 15:00	Near No.51-52 Hoi Pa San Village Back Lane	No.50-53 Hoi Pa San Village
21/6/2016	21/6/2016 16:50	21/6/2016 21:10	Near Lamp Post FA5533 Route Twisk	Hong Kong Gun Club, part of Tai Kiu Tsuen
22/6/2016	22/6/2016 15:00	22/6/2016 16:00	Near Lamp Post GC0682 Wo Yi Hop Village Footpth	No.38-73 Wo Yi Hop Village
27/6/2016	27/6/2016 11:25	27/6/2016 13:15	Near No.18 Muk Min Ha Tsuen Back Lane	No.18 Muk Min Ha Tsuen
30/6/2016	30/6/2016 09:27	30/6/2016 11:19	Near 18 Yeung Uk Tsuen	No.18 Yeung Uk Tsuen
1/7/2016	1/7/2016 11:15	1/7/2016 14:30	Back of No.9 Sai Lau Kok Tsuen	No.9 Sai Lau Kok Tsuen
7/7/2016	7/7/2016 09:45	7/7/2016 10:20	Near No.39 Ho Pui Tsuen	No.39 Ho Pui Tsuen
7/7/2016	7/7/2016 15:35	7/7/2016 17:05	Near No.1165 Kwan Mun Hau Tsuen	No.77-80 Kwan Mun Hau Tsuen
9/7/2016	9/7/2016 16:49	9/7/2016 18:05	Near No.115 Sam Tung UK Resite Village	No.115 Sam Tung UK Resite Village
12/7/2016	12/7/2016 16:00	12/7/2016 22:15	Near No.11 On Wing Street	No.11 On Wing Street
13/7/2016	13/7/2016 16:50	13/7/2016 18:16	Near Lamp Post V9391 Wang Lung Tsuen, Chuen Lung	Part of Wang Lung Tsuen
14/7/2016	14/7/2016 15:50	14/7/2016 16:35	Near No.142 Lo Wai	No.142 Lo Wai
17/7/2016	17/7/2016 07:30	17/7/2016 11:45	Back of No.34 San Tsuen Street	No.34 San Tsuen Street
18/7/2016	18/7/2016 18:30	18/7/2016 20:00	Near No.47-51 Chai Wan Kok Street	No.23-51 Chai Wan Kok Street
18/7/2016	18/7/2016 11:22	18/7/2016 12:26	Near No.16 Sham Tseng San Tsuen, Sham Tseng	Part of Sham Tseng San Tsuen
19/7/2016	19/7/2016 11:15	19/7/2016 22:10	Near Lamp Post AC3331 Tai Ho Road	Tsuen Wan West Station, Gammon Tai Ho Road Construction Site, Part of Tsuen Wan Park
20/7/2016	20/7/2016 11:00	20/7/2016 12:15	Near Lamp Post VA3464 Sham Tseng East Village, Sham Tseng	Sham Tseng East Village
20/7/2016	20/7/2016 18:30	20/7/2016 19:20	Near No.61 Sam Tung UK Resite Village	No.61-62 Sam Tung UK Resite Village
25/7/2016	25/7/2016 17:40	25/7/2016 18:50	Near No.5 Chuen Lung Chun Ha, Route Twisk	Part of Chuen Lung Chun Ha

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
26/7/2016	26/7/2016 22:10	27/7/2016 10:00	Junction of Chuen Lung Street and Ho Pui Street	No.118 Chuen Lung Street
27/7/2016	27/7/2016 14:25	27/7/2016 16:15	Near Back Lane of No.120-140 Tsuen Wan Market Street	No.110-160 Tsuen Wan Market Street
28/7/2016	28/7/2016 15:05	28/7/2016 17:00	Near No.13 Shu On Terrace, Sham Tseng	Part of Shu On Terrace
29/7/2016	29/7/2016 14:15	29/7/2016 17:50	Near No.100 Kwan Mun Hau Tsuen	Part of Kwan Mun Hau Tsuen
1/8/2016	1/8/2016 10:30	1/8/2016 13:00	Near No.54 Sam Tung UK Resite Village	No.54 Sam Tung UK Resite Village
3/8/2016	3/8/2016 05:35	3/8/2016 16:17	Near No.381 Sha Tsui Road	No.381 Sha Tsui Road
4/8/2016	4/8/2016 14:25	4/8/2016 15:45	Back Lane of No.122 Chung On Street	No.2-26 Sam Pei Square. No.92-122 Chung On Street
5/8/2016	5/8/2016 10:25	5/8/2016 16:25	Near Lamp Post SFYS/D/011, Fu Yung Shan Road	Part of Fu Yung Shan Road
5/8/2016	5/8/2016 06:15	5/8/2016 12:10	Near No.20 Hoi Pa Village Northeast Terrace	No.19-22 Hoi Pa Village Northeast Terrace
5/8/2016	5/8/2016 18:29	5/8/2016 19:24	Near 28 Ham Tin Tsuen	No.28 Ham Tin Tsuen
10/8/2016	10/8/2016 11:00	10/8/2016 12:00	Near No.47 Chung On Street	No.47 Chung On Street
10/8/2016	10/8/2016 15:10	10/8/2016 16:39	Near Back Lane of No.33 Shiu Wo Street	No.187-185 Castle Peak Road-Tsuen Wan
10/8/2016	10/8/2016 16:40	10/8/2016 17:45	No.152B Lo Wai Yi Pei Chun	No.152 Lo Wai Yi Pei Chun
10/8/2016	10/8/2016 10:15	10/8/2016 11:40	Near No.116 Lo Wai Yi Pei Chun	Part of Lo Wai Yi Pei Chun
12/8/2016	12/8/2016 16:30	12/8/2016 17:30	Near No.22 Ham Tin Tsuen	No.22 Ham Tin Tsuen
17/8/2016	17/8/2016 11:40	17/8/2016 12:25	Near Lamp Post FB2218 Yau Lai Road	Part of Yau Kom Tau Village
19/8/2016	19/8/2016 14:35	19/8/2016 15:00	Near Back Lane of No.2 Yi Pei Square	No.2-8 Yi Pei Square, No.93-99 Chuen Lung Street
23/8/2016	23/8/2016 15:55	23/8/2016 17:00	Near Fire Hydrant 1991 Po Fung Road	Part of Yau Kom Tau Village
24/8/2016	24/8/2016 12:45	24/8/2016 16:35	Near Lamp Post CC1112 Wing Tak Street Junction with	City Point

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
			Texaco Road	
26/8/2016	26/8/2016 19:10	26/8/2016 21:00	Near No.35 Fu Yung Shan San Tsuen	No.35 Fu Yung Shan San Tsuen
26/8/2016	26/8/2016 11:25	26/8/2016 12:40	Near No.15A Sham Tseng San Tsuen	Part of Sham Tseng San Tsuen
4/9/2016	4/9/2016 11:20	4/9/2016 12:23	Near No.91 Hoi Pa San Tsuen	No.91 Hoi Pa San Tsuen
7/9/2016	7/9/2016 21:00	7/9/2016 22:30	Near No.117 Chuen Lung Street	No.115-117 Chuen Lung Street and 26-28 Yi Pei Square
8/9/2016	8/9/2016 14:34	8/9/2016 17:07	Near No.2-8 Chung On Street	No.2-8 Chung On Street
10/9/2016	10/9/2016 14:20	10/9/2016 18:20	Back Lance of No.4-10 Chuen Lung Street	No.19-21 Tai Ho Road
10/9/2016	10/9/2016 17:16	10/9/2016 18:09	Near No.48 Chung Kwai Chung Tsuen	No.48 Chung Kwai Chung Tsuen
12/9/2016	12/9/2016 14:00	12/9/2016 15:50	Near Back Lance of No.2-8 Yi Pei Square	Hoi Pui Street, Chuen Lung Street, Yi Pei Square
12/9/2016	12/9/2016 18:00	12/9/2016 19:30	Near No.200 Tsuen King Circuit	No.200 Tsuen King Circuit
14/9/2016	14/9/2016 06:26	14/9/2016 09:51	Near No.136 Yi Pei Chun	Part of Yi Pei Chun
15/9/2016	15/9/2016 16:00	15/9/2016 17:05	Near No.39 Chung Kwai Chung Tsuen	No.39 Chung Kwai Chung Tsuen
16/9/2016	16/9/2016 04:45	16/9/2016 10:45	Near No.68 Sha Tsui Road	No.40-76 Sha Tsui Road.
16/9/2016	16/9/2016 11:00	16/9/2016 12:00	Back of No.21 Kwan Mun Hau Tsuen Kwok Shui Road	No.21 Kwan Mun Hau Tsuen
17/9/2016	17/9/2016 11:17	17/9/2016 14:18	Near No.27B Ting Kau, Tsuen Wan	Partially of Ting Kau
17/9/2016	17/9/2016 14:25	17/9/2016 15:30	Near No.30 Tak Wah Street, Tsuen Wan	No.30 Tak Wah Street
18/9/2016	18/9/2016 10:37	18/9/2016 12:13	Near Slope No.6SE-C/C287, Sham Hong Road	Part of Sham Hong Road
22/9/2016	22/9/2016 09:55	22/9/2016 10:56	Near No.50 Yau Kom Tau Village	No.50 Yau Kom Tau Village.
23/9/2016	23/9/2016 16:55	23/9/2016 23:16	Near No.28 Fu Yung Shan Road	No.28 Fu Yung Shan Road
26/9/2016	26/9/2016 11:35	26/9/2016 15:30	Near No.98 Chung On Street	No.92-100 Chung On Street, No.2-14 Sam Pei Square

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
27/9/2016	27/9/2016 10:15	27/9/2016 11:05	Near Back Lance of No.31 Tso Kung Square	No.1-37 Tso Kung Square, No.105-139 Sha Tsui Road
27/9/2016	27/9/2016 17:45	27/9/2016 20:30	Near Lamp Post FA5153 Tai Chung Road	Part of Hoi Shing Road
28/9/2016	29/9/2016 14:32	29/9/2016 16:42	Near No.9-31 Tai Pei Square, Tsuen Wan.	No.9-31 Tai Pei Square, 37-41 Chung On Street.
29/9/2016	29/9/2016 10:10	29/9/2016 11:20	Near Lamp Post CC0547, Lo Wai Village	Part of Lo Wai Village, Sam Dip Tam
2/10/2016	3/10/2016 11:35	3/10/2016 13:00	Near No.28 Sham Tseng San Tsuen	Part of Sham Tseng San Tsuen
4/10/2016	4/10/2016 11:05	4/10/2016 11:30	Near No.4 Sham Dip Tam, Lo Wai Road	No.4 Sham Dip Tam.
5/10/2016	5/10/2016 14:22	5/10/2016 15:43	Near No.32A Sham Tseng San Tsuen	Part of Sham Tseng San Tsuen
5/10/2016	5/10/2016 10:35	5/10/2016 11:10	Near No.65 Hoi Pa San Village, Kwok Shui Road	No.66-65 Hoi Pa San Village
7/10/2016	7/10/2016 10:20	7/10/2016 11:30	Near No.67A, Lo Wai, Tung Wo Street	No.41 Lo Wai, Tung Wo Street
8/10/2016	8/10/2016 11:45	8/10/2016 13:15	Near No.77 Kwan Mun Hau Tsuen	Part of Kwan Mun Hau Tsuen
8/10/2016	8/10/2016 15:25	8/10/2016 17:30	Near 34 Sham Tseng San Tsuen	Part of Sham Tseng San Tsuen
11/10/2016	11/10/2016 13:10	11/10/2016 16:30	Near No.44 Castle Peak Road-Sham Tseng	No.44 Castle Peak Road and Emmanuel Primary School
14/10/2016	14/10/2016 14:00	14/10/2016 15:30	Near 29A Sham Tseng San Tsuen	Part of Sham Tseng San Tsuen
15/10/2016	15/10/2016 19:30	15/10/2016 23:40	Near Lamp Post W0499 Ting Fung Street Kwok Shui Road	No.1-11 Hoi Pa New Village
17/10/2016	17/10/2016 20:25	17/10/2016 22:10	Back of No.3 Hoi Pa Village South Terrace	No.3 Hoi Pa Village South Terrace
18/10/2016	18/10/2016 14:05	18/10/2016 16:00	Near No.143 Castle Peak Road	No.125-143 Castle Peak Road
22/10/2016	22/10/2016 11:35	22/10/2016 12:35	Near No.110 Kwan Mun Hau Tsuen	No.105-110 Kwan Mun Hau Tsuen.
24/10/2016	24/10/2016 16:11	25/10/2016 09:00	No.10 Tso Kung Square	No.2-36 Tso Kung Square, No.2-32 Hoi Pa

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
				Street
26/10/2016	26/10/2016 10:30	26/10/2016 11:30	Near No. 22n Muk Min Ha Tsuen	Part of Muk Min Ha Tsuen
31/10/2016	31/10/2016 19:10	31/10/2016 20:20	Near Lamp Post FC0394, Tai Ho Road	Gammon Constructin Site
31/10/2016	31/10/2016 14:40	31/10/2016 16:30	Near Back Lane of No.95 , Chuen Lung Street	No.93-123 Chuen Lung Street
31/10/2016	31/10/2016 18:45	31/10/2016 19:20	Near No.88 Sam Tung UK Tsuen	No.88 Sam Tung UK Tsuen
31/10/2016	31/10/2016 15:00	31/10/2016 16:30	Near No.34 Chung Kwai Chung Tsuen	No.34 Chung Kwai Chung Tsuen
3/11/2016	3/11/2016 09:50	3/11/2016 13:00	Near No.31 Yuen Tun Village	No.28--35 Yuen Tun Village
3/11/2016	3/11/2016 15:10	3/11/2016 17:00	Near No.8 Tsing Lung Tau Tsuen	Part of Tsing Lung Tau Tsuen
4/11/2016	6/11/2016 02:00	6/11/2016 15:00	Near Lamp Post AC0222 Castle Peak Road	MTR Tsuen Wan Depot and Sai Lau Kok Garden
5/11/2016	5/11/2016 19:35	5/11/2016 20:45	Near No.30A Chuen Lung Tsuen	No.30A Chuen Lung Tsuen
7/11/2016	7/11/2016 15:20	7/11/2016 16:15	Near Swan Neck 839,Lo Wai Tsuen, Lo Wai Road	Part of Lo Wai Tsuen
7/11/2016	7/11/2016 02:55	7/11/2016 12:00	Near Lamp Post DC1204 Tsuen Wan Market Street	No.135-143 Castle Peak Road, Tsuen Wan
8/11/2016	8/11/2016 14:55	8/11/2016 17:00	Back Lane of No.51 Chung Kwai Chung Tsuen	Part of Chung Kwai Chung Tsuen
8/11/2016	8/11/2016 14:00	8/11/2016 15:50	Near No.2-8 Yi Pei Square	No.2-8 Yi Pei Square
11/11/2016	11/11/2016 16:10	11/11/2016 16:55	Near No.95 Kwong Pan Tin Tsuen	No.95 Kwong Pan Tin Tsuen
15/11/2016	15/11/2016 20:00	16/11/2016 06:30	Near Lamp Post FA6371 Kwok Shui Road	No.552-566 Castle Peak Road
15/11/2016	15/11/2016 14:20	15/11/2016 15:20	Near No.18 Tai Pak Tin Village	Part of Tai Pak Tin Village
15/11/2016	15/11/2016 07:30	15/11/2016 09:25	Near No.42 San Tsuen Street	No.38-42 San Tsuen Street
16/11/2016	16/11/2016 16:32	16/11/2016 17:22	Near 167A Lo Wai	Part of Lo Wai
16/11/2016	16/11/2016	16/11/2016	Near Back Lane of	No.120-140 Tsuen Wan

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
	10:45	12:10	No.120-140 Tsuen Wan Market Street	Market Street
17/11/2016	17/11/2016 15:36	17/11/2016 16:28	Near No.167 Lo Wai	No.167 and 167A Lo Wai
17/11/2016	17/11/2016 14:30	18/11/2016 02:30	Near Lamp Post FA5866 Shek Wai Kok Road	Shek Wai Kok Estate
22/11/2016	22/11/2016 10:45	22/11/2016 11:45	Near No.3 Fu Yung Shan San Tsuen	Part of Fu Yung Shan San Tsuen
22/11/2016	22/11/2016 15:20	22/11/2016 17:00	Near Lamp Post FB7592 Wang Lung Street	No.77-78 Wang Lung Street
22/11/2016	22/11/2016 23:55	23/11/2016 01:30	Near No.66 Sha Tsui Road	No.52-76 Sha Tsui Road
27/11/2016	27/11/2016 15:30	27/11/2016 16:30	Near Lamp Post FB5088 Mei Wan Street	Mei Wan Street Substation
27/11/2016	29/11/2016 16:15	29/11/2016 17:00	Yeung Uk Road Market Wo Tik Street	Yeung UK market Tsuen Wan
27/11/2016	27/11/2016 12:00	27/11/2016 13:15	Near No.107 Sam Tung Uk Resite Village	No.107 Sam Tung UK Tsuen
28/11/2016	28/11/2016 10:30	28/11/2016 12:00	Near No.22 Hoi Pa Village South Terrace	No.22 Hoi Pa Village South Terrace
29/11/2016	29/11/2016 22:00	29/11/2016 23:00	Back Lane of No.102 Chung On Street	No.102 Chung On Street
30/11/2016	30/11/2016 10:25	30/11/2016 11:50	Near No.15 Tsing Lung Tau Tsuen	Part of Tsing Lung Tau Tsuen
1/12/2016	1/12/2016 15:23	1/12/2016 15:45	Near lot 453 DD399 Castle Peak Road	Ting Yat Road
1/12/2016	1/12/2016 17:35	1/12/2016 19:10	No.7-11 Chuen Lung Street	No.27-39 Tsuen Wan Market Street
2/12/2016	2/12/2016 14:50	2/12/2016 15:30	Near No.1 Pai Min Kok Village	No.1 Pai Min Kok Village
2/12/2016	2/12/2016 15:45	2/12/2016 16:50	Near No.90 Sham Tseng San Village	Part of Sham Tseng San Village
3/12/2016	3/12/2016 11:30	3/12/2016 15:15	Near Lamp Post VC1558 Sham Hong Road	No.100 Sham Hong Road
5/12/2016	5/12/2016 11:20	5/12/2016 11:50	Near No.8 Tsing Lung Tau Tsuen	No.8 Tsing Lung Tau Tsuen
9/12/2016	9/12/2016 07:00	9/12/2016 14:30	Near No.10-16 Pun Shan Street	No.10-16 Oun Shan Street
12/12/2016	12/12/2016 11:50	12/12/2016 13:10	Near No.65-69 Chai Wan Kok Street	No.65-69 Chai Wan Kok Street

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
14/12/2016	14/12/2016 17:15	14/12/2016 18:00	Near No.118 Sam Tung UK Resite Village	No.118 Sam Tung Uk Resite Village
15/12/2016	15/12/2016 15:50	16/12/2016 02:30	Near Lamp Post FC0475 Texaco Road	No.4-218 Texaco Road
15/12/2016	15/12/2016 18:30	15/12/2016 18:55	Near No.76 Hoi Pa San Tsuen	Part of Hoi Pa San Tsuen, Han Tin Tsuen
17/12/2016	17/12/2016 14:40	18/12/2016 02:35	Near No.84 Chai Wan Kok Street	No.77-84 Chai Wan Kok Street
18/12/2016	18/12/2016 10:30	18/12/2016 21:30	Near Lamp Post FC3728 Lung Tak Street	No.202-188 Texaco Road, No.68 Wang Lung Street
19/12/2016	19/12/2016 10:00	19/12/2016 11:05	Near No.62 Sam Tung Uk Village	No.32 Sam Tung Uk Village
19/12/2016	19/12/2016 17:30	19/12/2016 19:45	Near No.109 Lo Wai	Part of Lo Wai
20/12/2016	20/12/2016 09:45	20/12/2016 11:00	Near No.100 Kwan Mun Hau Tsuen, Tsuen Wan.	No.99-100 Kwan Mun Hau Tsuen
22/12/2016	22/12/2016 14:30	22/12/2016 17:00	Back Lane of No.9-31 Tai Pei Square	No.9-31 Tai Pei Square
28/12/2016	28/12/2016 10:55	28/12/2016 15:10	Near No.80 Sam Tung UK Resite Village	No.80 Sam Tung Uk Resite Village
28/12/2016	28/12/2016 14:15	28/12/2016 17:00	Near Lamp Post GC0798 Hoi Hing Road	Part of Hoi Hing Road
29/12/2016	29/12/2016 21:30	30/12/2016 00:10	Near Lamp Post W1976 Shing Mun Road	No.1-10 Shing Mun Road
29/12/2016	30/12/2016 00:40	30/12/2016 02:10	Near No.40 Chai Wan Kok Street	Part of Chai Wan Kok Street
31/12/2016	31/12/2016 10:05	31/12/2016 11:00	Near Lamp Post V9686 Sham Hong Road	Sham Tseng Commercial New Village, Sham Tseng Light Housing
2/1/2017	2/1/2017 11:00	2/1/2017 13:45	Near No.57 Sham Tseng Commercial New Village	Part of Sham Tseng Commercial New Village
4/1/2017	4/1/2017 10:35	4/1/2017 11:08	Near Lo 2BB/56 Kin Yip San Tsuen	Kin Yip San Tsuen
9/1/2017	10/1/2017 00:20	10/1/2017 05:30	Near Lamp Post DC1359 Yuen Tun Circuit	Tsuen Wan Plaza
10/1/2017	10/1/2017 14:35	10/1/2017 15:10	Near No.16 Sham Tseng Kau Village	No.16 Sham Tseng Kau Village
10/1/2017	10/1/2017 09:55	10/1/2017 10:30	Near No.97 Kwan Mun Hau Tsuen	No.97 Kwan Mun Hau Tsuen
10/1/2017	10/1/2017	10/1/2017	Near Lamp Post	Mita Centre

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
	14:15	15:20	FA6363 Kwok Shui Road	
10/1/2017	10/1/2017 14:50	10/1/2017 16:20	Near Lamp Post FB8507 Lo Wai	Part of Lo Wai
10/1/2017	10/1/2017 10:20	10/1/2017 11:00	Near No.40 Yuen Tun Village	Part of Yuen Tun Village
11/1/2017	11/1/2017 09:30	11/1/2017 10:10	Near No.67 Lo Wai Tsuen	No.66-76 Lo Wai Tsuen
12/1/2017	12/1/2017 14:00	12/1/2017 17:30	Near 132 Chung On Street	125-136 Chung On Street
13/1/2017	13/1/2017 14:55	13/1/2017 15:25	Near No.55 Lo Wai Tsuen	No.55-75 Lo Wai Tsuen
16/1/2017	18/1/2017 00:00	18/1/2017 07:55	Near No.188-202 Texaco Road	No.62-164 Texaco Road, and No.391-407 Sha Tsui Road, No.188 Yeung Uk Road
16/1/2017	16/1/2017 10:30	16/1/2017 11:25	Near No.119 Sam Tung Uk Resite Village	No.119 Sam Tung Uk Resite Village
18/1/2017	18/1/2017 20:07	19/1/2017 14:10	Near 7 Shing Mun Road	Shing Mun Road
18/1/2017	18/1/2017 14:25	19/1/2017 11:00	Near Lamp Post AC3336 Tai Chung Road	Hoi Hing Road Refuse Collection Point
19/1/2017	19/1/2017 11:15	19/1/2017 12:00	Near No.76 Hoi Pa San Tsuen	No.76 Hoi Pa San Tsuen
21/1/2017	21/1/2017 11:05	21/1/2017 12:10	Near No.3 Sham Tseng Village	No.3 Sham Tseng Village
30/1/2017	30/1/2017 14:20	30/1/2017 23:30	Near 4A Chai Wan Kok Street	Chai Wan Kok Street Food Market and Chai Wan Kok Street Public Toilet
3/2/2017	3/2/2017 10:20	3/2/2017 11:05	Near Lamp Post W3712 Lo Wai	Part of Lo Wai Tung Kwu Shek
4/2/2017	4/2/2017 14:30	4/2/2017 15:45	Near No.123 Sam Tung Uk Resite Village	No.123 Sam Tung Uk Resite Village.
7/2/2017	7/2/2017 22:45	8/2/2017 03:15	Near No.239 Sha Tsui Road	No.237-255 Sha Tsui Road & No.83-89 Chuen Lung Street
9/2/2017	9/2/2017 10:45	9/2/2017 11:40	Near Lamp Post W3710 Lo Wai Tsuen	Lo Wai Tsuen
10/2/2017	10/2/2017 16:10	10/2/2017 17:20	Near No.146 Lo Wai Tsuen	No.140-151 Lo Wai Tsuen
10/2/2017	10/2/2017 10:10	10/2/2017 19:10	Near Lamp Post W0476 Kwok Shui Road	No.132-140 Kwok Shui Road (Safety Godown)

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
13/2/2017	13/2/2017 19:25	13/2/2017 22:30	Near No.53 Chung Kwai Chung Tsuen	No.53 Chung Kwai Chung Tsuen
13/2/2017	13/2/2017 23:00	14/2/2017 01:00	Back Lance of No.49 Chung On Street	No.49 Chung On Street
15/2/2017	15/2/2017 11:05	15/2/2017 11:55	Near Lamp Post VA3772, Ha Fa Shan	Part of Ha Fa Shan
17/2/2017	17/2/2017 16:30	17/2/2017 17:10	Near No.4 Kin Yin Sun Tsuen	No.4-10 Kin Yin Sun Tsuen
17/2/2017	17/2/2017 10:30	17/2/2017 11:50	Near No.61 Ho Pui Street	No.45-46 Ho Pui Street
17/2/2017	17/2/2017 13:30	17/2/2017 14:40	Near No.34 Fai Yiu Kok Street	No.12-34 Fai Yiu Kok Street No.35-47 Wang Lung Street.
20/2/2017	20/2/2017 15:30	21/2/2017 10:45	Near Refuse Collection Point.Yau Kom Tau Village	Refuse Collection PointYau Kom Tau Village
21/2/2017	21/2/2017 07:55	21/2/2017 12:35	No. 4 Ho Pui Tsuen, Kwok Shui Road	No. 4 Ho Pui Tsuen
22/2/2017	23/2/2017 20:30	24/2/2017 04:45	Near No.93 Chai Wan Kok Street	No.77-95 Chai Wan Kok Street
26/2/2017	27/2/2017 16:35	27/2/2017 17:35	Near No.18 Tsuen Kwai Street	Jade Court, Tsuen Wan Garden Commercial Center
27/2/2017	27/2/2017 09:40	27/2/2017 10:20	Near No.42C Sham Tseng San Tsuen	No.42C Sham Tseng San Tsuen
2/3/2017	2/3/2017 17:45	3/3/2017 04:00	Near No.53-61 Pak Tin Pai Street	No.41-51 Pak Tin Par Street, No.8 Tai Chung Road
8/3/2017	8/3/2017 13:45	8/3/2017 15:00	Near No.61 Sam Tung Uk Resite Village	No.61-62 Sam Tung Uk Resite Village
9/3/2017	9/3/2017 15:40	9/3/2017 16:40	Near Lamp Post W4130 Hoi Shing Road	No. 20 Hoi Shing Road
10/3/2017	10/3/2017 09:55	10/3/2017 10:40	Near No. 130 Lo Wai Tsuen	No.110-130 Lo Wai Tsuen
10/3/2017	11/3/2017 09:30	11/3/2017 11:30	Near No.6-9 Ho Pui Tsuen,	No.56-73 Ho Pui Tsuen
11/3/2017	11/3/2017 14:00	11/3/2017 15:30	No. 7-9 Hill Top Road, Tsuen Wan.	No.1-9 Hill Top Road
12/3/2017	12/3/2017 09:55	12/3/2017 21:30	Near No.107 Hoi Pa Street, Tsuen Wan.	No.107 Hoi Pa Street
13/3/2017	14/3/2017 14:30	14/3/2017 16:00	Near Lamp Post AC4856 Sham Hong Road	No. 7-12 Sham Hong Road

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
13/3/2017	13/3/2017 17:30	13/3/2017 20:30	Near No. 133 Castle Peak Road	No.117-135 Castle Peak Road
17/3/2017	17/3/2017 16:10	17/3/2017 18:00	Near No. 21 Wo Tik Street	No. 21 Wo Tik Street
17/3/2017	18/3/2017 08:30	18/3/2017 10:35	Near Fu Yung Shan Yiu Tai Public Toilet	Fu Yung Shan Yiu Tai Public Toilet
22/3/2017	22/3/2017 19:15	22/3/2017 20:30	Back of No.8 Hoi Pa Resite Village	No. 8 Hoi Pa Resite Village
23/3/2017	23/3/2017 18:00	23/3/2017 18:45	Near No.89 Chung On Street	No.89-99 Chung On Street, No.27-33 Yi Pei Square
27/3/2017	27/3/2017 15:40	27/3/2017 16:10	Near Lamp Post W2682, Route Twisk	Kwong Pan Tin Village Public Toilet
30/3/2017	7/4/2017 10:25	7/4/2017 15:00	Near No. 184 Sha Tsui Road	No. 146-188 Sha Tsui Road, No. 61-73 Yuen Tun Win, No. 45-59 Heung Wo Street
30/3/2017	30/3/2017 10:00	30/3/2017 12:05	Near No.25 Tso Kung Square	No. 25-27 Tso Kung Square
1/4/2017	1/4/2017 10:30	1/4/2017 14:15	Near Lamp Post VA3775 Fung Shing Tsuen, Ma Wan	Fung Shing Tsuen
3/4/2017	3/4/2017 15:40	3/4/2017 16:35	Near No. 67 Tsing Fai Tong New Village	No. 66-68 Tsing Fai Tong New Village
4/4/2017	4/4/2017 11:30	4/4/2017 18:15	Near Lamp Post FA5556 Route Twisk	Part of Route Twisk
4/4/2017	4/4/2017 17:55	4/4/2017 20:00	Near No. 63A Tsing Fai Tong New Village, Sham Tseng	Tsing Fai Tong New Village
6/4/2017	13/4/2017 10:05	13/4/2017 12:00	Back Lane of No. 106 Chung On Street	No. 92-122 Chung On Street (even no.)
8/4/2017	8/4/2017 15:10	8/4/2017 17:40	Near No. 132-140 Kwok Shui Road	No. 116-149 Kwok Shui Road
8/4/2017	8/4/2017 18:45	8/4/2017 21:00	Near No. 132 Lo Wai Tsuen	No. 132 Lo Wai Tsuen
9/4/2017	9/4/2017 10:50	9/4/2017 11:55	Near No. 10-16 Pun Shan Street	No. 10-22 Pun Shan Street
10/4/2017	10/4/2017 10:25	10/4/2017 11:05	Near No. 1C Sham Tseng San Tsuen	Part of Sham Tseng San Tsuen
11/4/2017	13/4/2017 09:55	13/4/2017 10:50	Back Lane of No. 91 Chung On Street	No. 89-99 Chung On Street (odd no.), No. 27-31 Yi Pei Square (odd

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
				no.)
12/4/2017	12/4/2017 16:40	12/4/2017 17:30	Near No. 127 Tai Pak Tin Village	No. 127 Tai Pak Tin Village
13/4/2017	13/4/2017 14:40	13/4/2017 17:40	Near Lamp Post DC2114 Tai Ho Road	Tsuen Wan Park
14/4/2017	14/4/2017 16:05	14/4/2017 16:50	Near Lamp Post FC0493 Wing Tak Street	Part of Wing Tak Street
15/4/2017	15/4/2017 10:10	15/4/2017 16:00	Near Lamp Post FA4700 Texaco Road	No. 231 Texaco Road
16/4/2017	16/4/2017 14:55	16/4/2017 17:00	Near Lamp Post SLKPT/D/0014 Kwok Pan Tin Village	Partially of Kwok Pan Tin Village
16/4/2017	16/4/2017 15:00	16/4/2017 16:30	No. 10A1 Sham Tseng New Tsuen	Part of Sham Tseng New Village
18/4/2017	18/4/2017 10:00	18/4/2017 11:25	No. 10A Sham Tseng San Village	Part of Sham Tseng New Village
19/4/2017	19/4/2017 17:45	19/4/2017 21:45	Near No. 340 Castle Peak Road,	No. 328-350 Castle Peak Road.
27/4/2017	27/4/2017 15:20	27/4/2017 17:15	Near No. 7-11 Tsuen Hing Path	No. 7-11 Tsuen Hing Path
2/5/2017	2/5/2017 22:00	3/5/2017 01:00	Near Lamp Post DC1452 Hoi On Road	Hoi On Road
5/5/2017	5/5/2017 12:10	5/5/2017 13:00	Near No. 19 Sham Tseng Village	No. 32C Sham Tseng Village
9/5/2017	9/5/2017 10:34	9/5/2017 14:36	Near No.109 Sam Tung Uk Resite Village	No.109 Sam Tung Uk Resite Village
10/5/2017	11/5/2017 09:00	11/5/2017 10:30	Near No. 188 Yau Ma Hom Road	No.188 Yau Ma Hom Resite Village
17/5/2017	17/5/2017 21:20	17/5/2017 22:50	Near No. 42 Fui Yiu Kok Street	No. 42 Fui Yiu Kok Street
18/5/2017	18/5/2017 10:05	18/5/2017 10:36	Near No. 16 Tsing Lung Tau Tsuen	Part of Tsing Lung Tau Tsuen
19/5/2017	19/5/2017 16:40	21/5/2017 09:00	Near No. 71-75 Chai Wan Kok Street	No. 35-81 Chai Wan Kok Street
19/5/2017	19/5/2017 21:30	20/5/2017 01:45	Back of No. 72 Kwan Mun Hau Tsuen	No. 72 Kwan Mun Hau Tsuen
22/5/2017	22/5/2017 09:40	22/5/2017 10:40	Near No. 61 Sham Tseng Kau Tsuen	No. 61 Sham Tseng Kau Tsuen
25/5/2017	25/5/2017 17:40	25/5/2017 18:35	Near No.36 Muk Min Ha Village	No. 36 Muk Min Ha Village
26/5/2017	26/5/2017 11:35	26/5/2017 12:30	Near No. 51 Ho Pui Tsuen	No. 51 Ho Pui Tsuen

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
29/5/2017	30/5/2017 09:30	30/5/2017 11:30	Near No. 27 Yi Pei Square	No.27-29 Yi Pei Square
31/5/2017	31/5/2017 15:00	31/5/2017 17:25	Near No.20 Hoi Pa Village Northeast Terrace	No. 19-22 Hoi Pa Village Northeast Terrace
31/5/2017	31/5/2017 14:57	31/5/2017 15:38	Near No. 99 Sam Tung Uk Resite Village	No.99 Sam Tung Uk Resite Village
31/5/2017	6/6/2017 11:05	6/6/2017 14:00	Near Lamp Post FB4674 Tso Kung Square	Heung Che Street Refuse Collection Point
31/5/2017	6/6/2017 10:40	6/6/2017 12:00	Near Lamp Post VC2140, Chuen Lung	Part of Chuen Lung
1/6/2017	1/6/2017 14:10	1/6/2017 15:25	Near No. 39K Sham Hong Road	Part of Sham Hong Road
2/6/2017	2/6/2017 17:00	2/6/2017 18:00	Near No. 94 Sam Tung Uk Resite Village	No. 94 Sam Tung Uk Resite Village
3/6/2017	3/6/2017 14:08	3/6/2017 15:45	Near No. 17 Hoi Pa Resite Village	No. 16-21 Hoi Pa Resite Village
3/6/2017	3/6/2017 13:10	3/6/2017 14:00	Near No. 86C Sham Tseng San Tsuen	No. 36-90 Sham Tseng San Tsuen.
5/6/2017	5/6/2017 11:25	5/6/2017 15:00	Near Lamp Post FB5794 Po Fung Road	1 No. of Building Service Meter
6/6/2017	6/6/2017 16:40	6/6/2017 17:45	Near No. 32A Sham Tseng San Tsuen	Part of Sham Tseng San Tsuen
9/6/2017	9/6/2017 14:00	9/6/2017 18:55	Near No. 185-187 Castle Peak Road	No. 185-187 Castle Peak Road
9/6/2017	9/6/2017 20:15	9/6/2017 21:30	Near Lamp Post AC0206 Castle Peak Road	No. 364-372, 382-392 Castle Peak Road
10/6/2017	10/6/2017 16:15	10/6/2017 17:30	Opposite Lamp Post AC4856 Sham Hong Road	No. 7-10 Sham Tseng San Tsuen
13/6/2017	13/6/2017 10:20	13/6/2017 11:20	Near Back Lance of No. 17-33 Wang Lung Street	No. 17-33 Wang Lung Street
15/6/2017	15/6/2017 11:05	15/6/2017 12:35	No. 36 San Tsuen Street	No. 36 San Tsuen Street
16/6/2017	16/6/2017 20:15	17/6/2017 00:00	Back Lane of No. 9-31 Tai Pei Square	No. 9-31 Tai Pei Square
16/6/2017	16/6/2017 09:40	16/6/2017 13:00	Near Lamp Post W1948 Sai Lau Kok Road	Firs services supply of Tsuen Wan Station
23/6/2017	23/6/2017 10:50	23/6/2017 12:10	Near No. 113 Sam Tung Uk Resite Village	No. 113 Sam Tung Uk Resite Village
23/6/2017	27/6/2017	27/6/2017	Near No. 53-61, Pak Tin	No. 53-61 Pak Tin Par

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
	18:15	21:30	Par Street	Street
24/6/2017	25/6/2017 14:00	25/6/2017 16:30	No. 4 Yeung Uk Tsuen	No. 1-13 Yeung Uk Tsuen
27/6/2017	27/6/2017 10:40	27/6/2017 12:10	Near No. 127 Yi Pei Chun	Part of Yi Pei Chun
28/6/2017	28/6/2017 14:05	28/6/2017 15:00	Near No. 52 Sham Tseng Village	No. 50-53 Sham Tseng Village
29/6/2017	29/6/2017 09:00	29/6/2017 12:00	Near Lamp Post V9701 Tsing Fai Tong New Village	No. 60-67 Tsing Fai Tong New Village
30/6/2017	30/6/2017 14:00	30/6/2017 15:20	Near No. 26 Ho Pui Tsuen	No. 25-26 Ho Pui Tsuen
8/7/2017	8/7/2017 22:46	9/7/2017 03:45	Near No. 40-50 Sha Tsui Road	No. 40-66A Sha Tsui Road
10/7/2017	10/7/2017 11:15	10/7/2017 12:45	Back Lane of No. 109 Chuen Lung Street	No. 109 Chuen Lung Street
13/7/2017	13/7/2017 13:20	13/7/2017 15:45	Near No. 39K Sham Tseng San Tsuen	No. 36 Sham Tseng San Tsuen
15/7/2017	15/7/2017 14:00	15/7/2017 16:30	Back of No. 33 Hoi Pa Village South Terrace	No. 33 Hoi Pa Village South Terrace
19/7/2017	19/7/2017 16:30	19/7/2017 19:30	No. 2 Ho Pui Tsuen	No. 1-2 Ho Pui Tsuen
20/7/2017	20/7/2017 14:45	20/7/2017 16:25	Near No. 16 Hoi Pa Village	No. 16-21 Hoi Pa Village
22/7/2017	22/7/2017 16:00	22/7/2017 17:30	Back Lane of No. 125A Chuen Lung Street	No. 125 Chuen Lung Street
24/7/2017	24/7/2017 18:50	25/7/2017 02:33	Near No. 20 Hoi Shing Road	No. 20 Hoi Shing Road
27/7/2017	27/7/2017 09:55	27/7/2017 10:27	Near No. 16 Kwan Mun Hau Tsuen	No. 16 Kwan Mun Hau Tsuen
28/7/2017	28/7/2017 15:35	28/7/2017 16:05	Near Lamp Post FC 3764 Lung Yue Road	Part of Lung Yue Road
29/7/2017	29/7/2017 14:10	29/7/2017 19:00	Near No. 220 Sai Lau Kok Road	Ho Fai Garden
3/8/2017	3/8/2017 15:30	3/8/2017 17:00	Near No. 95 Sam Tung Uk Village	No. 95 Sam Tung Uk Village
3/8/2017	3/8/2017 10:35	3/8/2017 11:45	Near Kwong Pan Tin Tsuen Toilet, Route Twisk	Part of Kwong Pan Tin Tsuen
4/8/2017	5/8/2017 15:50	5/8/2017 22:30	Near No. 417 Castle Peak Road	No. 364-380 Castle Peak Road Wing Lok House(Fuk Loi Estate)

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
5/8/2017	5/8/2017 10:30	5/8/2017 12:40	Near Lamp Post SFYS/D/006 Fu Yung Shan Tsuen	Part of Fu Yung Shan Tsuen
6/8/2017	6/8/2017 01:00	6/8/2017 07:20	Near No. 95 Chai Wan Kok Street	No. 77-95 Chai Wan Kok Street
6/8/2017	6/8/2017 01:30	6/8/2017 08:30	Near No. 77 Chai Wan Kok Street	No.77-95 Chai Wan Kok Street
6/8/2017	6/8/2017 10:00	6/8/2017 12:20	Near Lamp Post FB5087 Mei Wan Street	Mei Wan Street CLP Substation
9/8/2017	9/8/2017 10:10	9/8/2017 13:05	Near No. 2-8, Tsuen Hing Path	No. 2-8 Tsuen Hing Path
10/8/2017	10/8/2017 09:55	10/8/2017 15:00	Near No. 7 Hoi Pa Resite Village	No. 1-9 Hoi Pa Resite Village
11/8/2017	11/8/2017 14:20	11/8/2017 15:30	Near Lamp Post VC0570 Lo Wai Sheung Kok Shan Tsuen	No. 11 B Sheung Kok Shan Tsuen
11/8/2017	11/8/2017 09:30	11/8/2017 11:20	Near Lamp Post AC5123 Tai Ho Road	Tsuen Wan Park
14/8/2017	14/8/2017 10:05	14/8/2017 11:05	Near No. 124 Chung On Street	No. 124 Chung On Street.
14/8/2017	14/8/2017 22:00	15/8/2017 06:20	Near Lamp Post FB2837 Ting Kwok Street	Kwan Mun Hau Tsuen
15/8/2017	15/8/2017 13:15	15/8/2017 14:00	Near No. 108 Sam Tung Uk Village	No. 108 Sam Tung Uk Village
15/8/2017	15/8/2017 10:45	15/8/2017 12:15	Near Lamp Post W2690 Kwong Pan Tin Tsuen, Route Twisk	Part of Kwong Pan Tin Tsuen
16/8/2017	16/8/2017 09:35	16/8/2017 12:00	Near No. 18 Cho Kung Square	No. 14-36 Cho Kung Square
16/8/2017	16/8/2017 09:35	16/8/2017 10:30	Near No. 67 Kwan Mun Hau Tsuen	No. 67 Kwan Mun Hau Tsuen
16/8/2017	16/8/2017 21:30	16/8/2017 23:30	Back Lane of No. 52 Kwan Mun Hau Tsuen	No. 52 Kwan Mun Hau Tsuen
17/8/2017	21/8/2017 09:40	21/8/2017 12:55	Near No. 5-9 Chai Wan Kok Street	No. 5-9 Chai Wan Kok Street
18/8/2017	18/8/2017 10:30	18/8/2017 12:00	Near No. 30-32 Chai Wan Kok Street	No. 30-32 Chai Wan Kok Street
18/8/2017	18/8/2017 10:00	18/8/2017 15:00	Near Lamp Post BC2193 Tai Kiu Tsuen, Route Twisk	Part of Tai Kiu Tsuen
19/8/2017	19/8/2017 10:30	19/8/2017 13:10	Near No. 1A Route Twisk, Tsuen Wan.	No. 1A Route Twisk

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
20/8/2017	20/8/2017 09:15	20/8/2017 13:00	Back Lane of No. 337-339 Sha Tsui Road, Tsuen Wan.	No. 337-339 Sha Tsui Road
21/8/2017	22/8/2017 10:05	22/8/2017 10:35	Near No. 301 Wo Yi Hop Road	No. 301 Wo Yi Hop Road
28/8/2017	28/8/2017 22:00	29/8/2017 00:30	Near Lamp Post W0631 Hilltop Road	Po Kwong Yuen
1/9/2017	1/9/2017 13:00	1/9/2017 14:15	Near No. 25 Chung Kwai Chung Tsuen	No. 25 Chung Kwai Chung Tsuen
1/9/2017	1/9/2017 11:00	1/9/2017 13:45	Near Lamp Post SFYS/D/004, Fu Yung Shan Road	Fu Yung Shan Road
1/9/2017	1/9/2017 23:00	2/9/2017 06:00	Near Tsuen Wan West Low Level Fresh Water Service Reservoir	Allway Gardens
5/9/2017	5/9/2017 08:10	5/9/2017 11:50	Near Lamp Post V9687 Sham Tseng Sun Tsuen	Sham Tseng Sun Tsuen
6/9/2017	6/9/2017 14:30	6/9/2017 15:23	Near No. 120 Sam Tung Uk Resite Village	No. 120 Sam Tung Uk Resite Village
7/9/2017	7/9/2017 11:00	7/9/2017 16:00	Back Lane of No. 1165 Kwan Mun Hau Tsuen	Part of Kwan Mun Hau Tsuen
8/9/2017	8/9/2017 13:20	8/9/2017 14:10	Near Lamp Post FB8492 Lo Wai Tsuen	No. 171-172 Lo Wai Tsuen
8/9/2017	8/9/2017 23:05	9/9/2017 02:50	Near No. 12 Chuen Lung Street	No. 4-18 Chuen Lung Street, No.15-19 Tsuen Wan Market Street, No. 2-4 Shiu Wo Street
10/9/2017	10/9/2017 18:45	10/9/2017 22:06	Near No 3-7 Kin Ming Street.	Cheong Wah Building
11/9/2017	11/9/2017 21:30	12/9/2017 01:05	Near No. 28 Tai Chung Road	No. 22-28 Tai Chung Road
11/9/2017	11/9/2017 14:32	11/9/2017 15:15	Near No.23 Tsuen Wan Market Street	No. 27-49 Tsuen Wan Market Street. No. 12-36 Shiu Wo Street
14/9/2017	14/9/2017 11:25	14/9/2017 21:39	Near Lamp Post FA5153 Tai Chung Road	Chai Wan Kok Street Garden. Hoi Shing Road CLP Station
18/9/2017	18/9/2017 20:37	18/9/2017 23:30	Near No. 22-24 Tak Wah Street	No. 22-24 Tak Wah Street
18/9/2017	18/9/2017 09:30	18/9/2017 10:20	Near Lamp Post V9404 Ha Fa Shan Tsuen	Ha Fa Shan Playground
20/9/2017	20/9/2017 09:51	20/9/2017 11:07	Near No. 25A Sham Tseng San Tsuen	Part of Sham Tseng San Tsuen

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
20/9/2017	20/9/2017 14:00	20/9/2017 15:40	Near Lamp Post FB3018 Sha Tsui Road	Wang Wo Tsai Street Garden
25/9/2017	25/9/2017 09:25	25/9/2017 10:10	Near No. 81 Lo Wai Tsuen	No. 115-117 Lo Wai Tsuen
28/9/2017	28/9/2017 14:20	28/9/2017 15:20	Near No. 600 Castle Peak Road	No. 600 Castle Peak Road
29/9/2017	29/9/2017 14:10	29/9/2017 18:20	Near No. 8 Tai Ho Road	No. 8 Tai Ho Road
30/9/2017	30/9/2017 13:10	30/9/2017 14:30	Near No. 185-187 Castle Peak Road	No. 187 Castle Peak Road
2/10/2017	2/10/2017 13:46	2/10/2017 14:21	Near No. 15 Pai Min Kok Village	Part of Pai Min Kok Village
6/10/2017	6/10/2017 10:20	6/10/2017 11:15	Near No. 39 Yuen Tun Village	No.39 Yuen Tun Village
6/10/2017	6/10/2017 14:00	6/10/2017 15:10	Near No. 64 Fu Yung Shan San Tsuen	Part of Fu Yung Shan San Tsuen
13/10/2017	22/10/2017 11:35	22/10/2017 12:35	Near No. 52A Sha Tsui Road	No. 52A Sha Tsui Road
13/10/2017	13/10/2017 13:45	13/10/2017 15:58	Near No. 21 Ho Pui Tsuen	No. 21-24 Ho Pui Tsuen
14/10/2017	14/10/2017 09:35	14/10/2017 12:16	Near No. 22 Ho Pui Tsuen	No.21-24 Ho Pui Tsuen
16/10/2017	16/10/2017 10:40	16/10/2017 11:20	Back of No. 13 Kwan Mun Hau Tsuen	No. 1-19 Kwan Mun Hau Tsuen
16/10/2017	16/10/2017 13:40	16/10/2017 15:10	Near Lamp Post W3710 Lo Wai Road	Lo Wai Road
19/10/2017	24/10/2017 10:10	24/10/2017 12:30	Near No. 11-15 Tso Kung Square	No. 129 Sha Hsui Road
23/10/2017	23/10/2017 11:41	23/10/2017 12:08	Near Lamp Post 1998 Sai Lau Kok Road	Tsuen Wan Station
23/10/2017	23/10/2017 14:19	23/10/2017 15:17	Near Lamp Post U7680 Hoi Pa Street	Tsuen Wan Government Secondary School
25/10/2017	25/10/2017 10:00	25/10/2017 10:45	Near No. 27C Sham Tseng Sun Tsuen	No. 9-30 Sham Tseng Sun Tsuen
25/10/2017	25/10/2017 14:15	25/10/2017 17:00	Near No. 40 Sam Tung Uk Village	No. 39-40 Sam Tung Uk Village
25/10/2017	25/10/2017 16:15	25/10/2017 18:00	Near Lam Post No. VC0388 Ma Wan Main Street	Ma Wan Youth Camp
30/10/2017	30/10/2017 13:20	30/10/2017 14:50	Near Lamp Post FB4670, Tai Kiu Tsuen	Part of Tai Kiu Tsuen
31/10/2017	31/10/2017 14:05	31/10/2017 16:30	Near No. 2 Lai Shun Road	No. 2 Lai Shun Road

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
31/10/2017	5/11/2017 12:35	5/11/2017 14:35	Back of No. 36 Ho Pui Tsuen	No.36 Ho Pui Tsuen
1/11/2017	1/11/2017 19:05	2/11/2017 01:30	Near No. 132-140 Kwok Shui Road	No. 132-149 Kwok Shui Road
2/11/2017	2/11/2017 09:50	2/11/2017 11:25	Near No. 84-92 Chai Wan Kok Street	Chai Wan Kok Street
6/11/2017	6/11/2017 15:35	6/11/2017 16:20	Near Lamp Post FB4674 Tso Kung Square	Heung Che Street Market
9/11/2017	11/11/2017 23:30	12/11/2017 01:30	Near Lamp Post P No. W1542 Texaco Road North	Shing Mun Valley Swimming Pool, Wai Tsuen Sports Center
14/11/2017	18/11/2017 12:15	18/11/2017 14:30	Near Lamp Post FA2163 Heung Che Street	Refuse Collection Point Heung Che Street
20/11/2017	20/11/2017 09:50	20/11/2017 10:55	Near No. 35 Fu Yung Shan San Tsuen	No. 36 Fu Yung Shan San Tsuen
21/11/2017	21/11/2017 14:35	21/11/2017 16:30	Near No. 42, Ho Pui Tsuen, Kwok Shui Road	No. 42, Ho Pui Tsuen
23/11/2017	23/11/2017 09:45	23/11/2017 11:30	Near Lamp Post FA5508, Route Twisk, Tsuen Wan	Part of Kwong Pan Tin Tsuen Section 4
24/11/2017	29/11/2017 09:55	29/11/2017 14:05	Near No. 86, Hoi Pa San Tsuen	No. 84-87, Hoi Pa San Tsuen
24/11/2017	29/11/2017 09:55	29/11/2017 10:50	Near No. 90, Hoi Pa San Tsuen	Part of Hoi Pa San Tsuen, Ho Pui Tsuen and Kwan Mun Hau Tsuen
24/11/2017	24/11/2017 10:05	24/11/2017 10:35	Near No. 47-51, Shiu Wo Street	No. 167-169, Castle Peak Road and No. 47-51, Shiu Wo Street
29/11/2017	29/11/2017 16:50	29/11/2017 20:35	Near Lamp Post SHMC/D/0023 Yau Kom Tau Village	Part of Yun Kom Tau Village
30/11/2017	30/11/2017 10:20	30/11/2017 11:35	Near No. 43, Ting Kau	Part of Ting Kau Tsuen
30/11/2017	30/11/2017 13:20	30/11/2017 16:00	Near No. 86, Hoi Pa San Tsuen	No. 84-87, Hoi Pa San Tsuen
1/12/2017	1/12/2017 11:20	1/12/2017 12:08	Near Lamp Post VC0449 Lo Wai Tsuen	Part of Shueng Kok Shan Road
3/12/2017	3/12/2017 11:50	3/12/2017 13:30	Near Fire Hydrant 10539, Castle Peak Road-Ting Kau	Part of Approach Beach

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
5/12/2017	5/12/2017 16:25	5/12/2017 19:30	Near Lamp Post DC2121, Tai Ho Road	Skyline Plaza
5/12/2017	5/12/2017 20:25	6/12/2017 05:25	Near No. 3-7, Kin Ming Street	No. 3-7, Kin Ming Street.
6/12/2017	6/12/2017 07:50	6/12/2017 19:00	Near Lamp Post AC1986, Tsuen Wan Market Street	No.67-133 Market Street, No.7-11 Yan Chai Street
6/12/2017	6/12/2017 09:55	6/12/2017 11:20	Back of No. 49, Tsuen Wan Market Street	No. 49, Tsuen Wan Market Street
11/12/2017	11/12/2017 14:48	11/12/2017 16:34	Near No. 7, Hoi Pa Village Northeast Terrace	No. 7-8, Hoi Pa Village Northeast Terrace
11/12/2017	11/12/2017 10:40	11/12/2017 11:30	Near No. 47-51, Shiu Wo Street	No. 47-51, Shiu Wo Street
13/12/2017	13/12/2017 12:45	13/12/2017 13:40	Near Lamp Post V9425, Sham Tseng West Tsuen	Part of Sham Tseng West Tsuen
14/12/2017	14/12/2017 10:30	14/12/2017 11:35	Near No. 8, Hoi Pa Village Northeast Terrace	No. 8, Hoi Pa Village Northeast Terrace
15/12/2017	15/12/2017 09:40	15/12/2017 10:40	No. 112, Fu Yung Shan San Tsuen	No. 112, Fu Yung Shan San Tsuen
20/12/2017	20/12/2017 23:00	21/12/2017 00:45	Near No. 123, Castle Peak Road	No. 117-133, Castle Peak Road
30/12/2017	30/12/2017 08:10	30/12/2017 10:45	Beside of No. 37, Tso Kung Square	Tso Kung Square Garden

(B) Flushing Water Suspensions in Tsuen Wan District due to Emergency Repair of Water Mains from 2013 to 2017

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
10/1/2013	10/1/2013 09:50	10/1/2013 13:30	No.22 Hoi Pa Village South Terrace Back Lane	No.21-33 Hoi Pa Village South Terrace
12/1/2013	12/1/2013 21:20	13/1/2013 14:00	No.21 Tai Ho Road	Chau's Building, No.12-18 Chuen Lung Street, Junior Police Call Club Building
15/1/2013	15/1/2013 05:00	15/1/2013 11:45	No.633 Castle Peak Road	Tsuen Wan Government Primary School, Belvedere Garden Phase

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
				II, T.W. West Sport Centre, HK Baptist Convention Primary School, Bay View Garden, The Westminster Terrace
17/1/2013	17/1/2013 10:15	18/1/2013 09:00	No.78 Texaco Road Back Lane	No.72-86 Texaco Road
18/1/2013	18/1/2013 10:30	18/1/2013 15:00	No.86 Texaco Road Back Lane	No.72-96 Texaco Road Premises
19/1/2013	19/1/2013 11:40	19/1/2013 14:30	No.88 Texaco Road Back Lane	No.72-88 Texaco Road
25/1/2013	25/1/2013 17:00	25/1/2013 19:30	No.38 Chai Wan Kok Street	No.30-40 Chai Wan Kok Street
28/1/2013	28/1/2013 19:00	28/1/2013 19:45	Near Fire Hydrant 2332 On Yin Street	Tsuen Wan Adventist Hospital, Construction site
30/1/2013	30/1/2013 11:30	1/2/2013 02:20	Hoi Kwai Road near Lamp Post AC 5902	Kwai Ching North, Kwai Ching South, Tsuen Wan Town Centre, Container Port Road
2/2/2013	2/2/2013 09:30	2/2/2013 16:00	No.313 Wo Yi Hop Road Back Lane	No.273-335 Wo Yi Hop Road, 1-7 Lei Shu Road
2/2/2013	2/2/2013 10:40	2/2/2013 16:30	No.95 Kwan Mun Hau Tsuen	No.81-90 Kwan Mun Hau Tsuen
2/2/2013	2/2/2013 14:01	2/2/2013 15:30	No.40 Hau Tei Square Back Lane	No.28-82 Hau Tei Square, No.207-211 Sha Tsui Road, No.91-99 Tai Ho Rd
5/2/2013	6/2/2013 01:30	7/2/2013 01:35	Yeung Uk Road Near Lamp Post DC1784	Tsuen Wan Town Centre, North & South Kwai Chung, Container Pier Road
7/2/2013	7/2/2013 13:30	7/2/2013 14:50	No.40-50 Sha Tsui Rd	No.8-76 Sha Tsui Rd
7/2/2013	8/2/2013 01:40	8/2/2013 14:00	Yeung Uk Road near Lamp Post DC1785	Tsuen Wan Town Centre, Container Part Rd, North and East Kwai Chung
14/2/2013	14/2/2013 14:05	14/2/2013 18:45	Sha Tsui Road near Lamp Post AC 3408	Sha Tsui Road Playground
18/2/2013	18/2/2013 13:15	18/2/2013 22:00	No.6 Tai Pei Square	No.27-55 Chung On Street, No.120-150 Hoi Pa Street, No.31-89 Chuen Lung Street,

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
				No.2-24 Tai Pei Square, No.237-255 Sha Tsui Road
21/2/2013	21/2/2013 11:55	21/2/2013 15:00	No.18 Pun Shan Street	No.10-20 Pun Shan Street
27/2/2013	27/2/2013 13:35	27/2/2013 15:30	Tsuen Yip Street near Fire Hydrant 5425	No.120-164 Texaco Rd No.18 Ma Kok Street
28/2/2013	28/2/2013 14:30	1/3/2013 09:00	Near No.80 Hau Tei Square Back Lane	Hai Tei Square
8/3/2013	8/3/2013 13:55	8/3/2013 17:05	No.30 Hoi Pa Street	No.2-32 Hoi Pa Street, No.2-36 Tso Kung Square, No.25-32 Heung Che Street, No.2-6 Tso Kung Street
10/3/2013	10/3/2013 07:30	10/3/2013 15:00	Tsuen Wan Market Street	Tsuen Wan Market Street Public Toilet Playground
12/3/2013	12/3/2013 20:00	13/3/2013 01:00	No.102 Tsuen King Circuit	Tsuen King Circuit & On Yin Street
13/3/2013	13/3/2013 10:00	13/3/2013 14:00	1B Sam Tung Uk Resite Village Back Lane	No.11-18 Sam Tung Uk Resite Village
14/3/2013	14/3/2013 14:00	15/3/2013 09:00	Near Mita Centre Kwok Shui Road	Mita Centre
19/3/2013	19/3/2013 14:00	20/3/2013 09:00	Near No.311 Wo Yi Hop Road Back Lane	No.309-311 Wo Yi Hop Road
22/3/2013	22/3/2013 10:10	22/3/2013 10:40	Near No.41 Chung Kwai Chung Tsuen	No. 1 to 58 Chung Kwai Chung Tsuen
22/3/2013	22/3/2013 18:32	23/3/2013 00:30	No.275 Wo Yi Hop Road Back Lane	No.273-355 Wo Yi Hop Road & No.1-17 Lei Shu Road
23/3/2013	23/3/2013 10:30	23/3/2013 15:30	Near No.37 Tso Kung Square Back Lane	No.105 Sha Tsui Road
24/3/2013	24/3/2013 12:30	25/3/2013 09:00	No.362 Sha Tsui Road	Fortune Commerical Building
25/3/2013	25/3/2013 10:30	25/3/2013 15:30	No.28 Hoi Pa Resite Village Back Lane	No.22-31 Hoi Pa Resite Village
26/3/2013	26/3/2013 10:00	26/3/2013 11:30	Near No.177 Tsuen Wan Market Street	No.117-133 Castle Peak Road
27/3/2013	27/3/2013 06:50	27/3/2013 12:00	No.270 Sha Tsui Road Back Lane	No.254-280 Sha Tsui Road
27/3/2013	27/3/2013 13:50	27/3/2013 20:30	No.633 Castle Peak Road	Bayview Garden, Greenview Court, Belvedere Garden Ph 2, Tseun Wan West Sports Centre HK Baptist

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
				Convention Primary School
28/3/2013	28/3/2013 10:30	28/3/2013 12:00	Near Long Beach Gardens, Castle Peak Road	Long Beach Garden
3/4/2013	3/4/2013 17:30	3/4/2013 19:25	No.47-51 Shiu Wo street	No.2-8 Chung On Street & 47-51 Shiu Wo Street
4/4/2013	4/4/2013 06:25	4/4/2013 14:00	Kwu Uk Lane	Luk Yeung San Chuen, MTR Depot
6/4/2013	6/4/2013 15:02	6/4/2013 20:00	No.40-50 Sha Tsui Road	No.8-76 Sha Tsui Road Premises
15/4/2013	15/4/2013 13:50	15/4/2013 15:20	No.19-21 Tai Ho Road	No.19-21 Tai Ho Road & No.4-10 Chuen Lung Street
16/4/2013	16/4/2013 13:45	16/4/2013 14:45	No.46 Fu Yiu Kok Street Back Lane	No.40-58 Fu Yiu Kok Street & No.55-71 Wang Lung Street
18/4/2013	18/4/2013 09:23	18/4/2013 17:11	Near No.54-68 Hau Tei square Back Lane	No.207,209,211 Sha Tsui Road, No.91,93,95,97 99 Tai Ho Road, No.24-30 32-36 38 40-46 48-52 54-68 69-77 70-72 80-84 Hau Tei Square
23/4/2013	23/4/2013 19:30	24/4/2013 04:30	Yeung Uk Road near Lamp Post DC 1786	Tsuen Wan Centre South, North Kwai Chung
22/4/2013	23/4/2013 22:00	24/4/2013 06:30	99 Yeung Uk Road near	Tsuen Wan & Kwai Chung
24/4/2013	24/4/2013 15:00	24/4/2013 20:00	Near No. 204-210 Texaco Road	No.188-202 Texaco Road and No.11 Lung Tak Street
26/4/2013	26/4/2013 18:40	27/4/2013 03:00	No.22 Kwan Mun Hau Street	No.22-24 Kwan Mun Hau Street Yau Chai Hospital The Hong Kong Jockey Club PolyClinic
2/5/2013	2/5/2013 15:50	2/5/2013 20:30	No.23 Sam Tung Uk Tsuen Back Lane	No.19-72 Sam Tung Uk
8/5/2013	8/5/2013 17:30	9/5/2013 00:00	Near No. 5-9 Chai Wan Kok Street	No. 10-18 & 22-32 Pun Shan Street, Chai Wan Kok Street
13/5/2013	13/5/2013 20:00	13/5/2013 23:00	Near No. 45 Shiu Wo Street	No. 2-8 Chung On Street
21/5/2013	21/5/2013 12:15	21/5/2013 17:40	Near No.204-210 Texaco Road	Tsuen Wan Driving Test Centre
23/5/2013	23/5/2013	23/5/2013	No.5 Tai Pa Street	Yen Wai Garden, Fu

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
	09:00	14:00		Yung House, Win Shing House
28/5/2013	28/5/2013 09:57	28/5/2013 14:00	No.207 Sha Tsui Road	No.207-211 Sha Tsui Road, No.24-84 Hall Tei Square, No.77-99 Tai Ho Road.
28/5/2013	28/5/2013 14:30	28/5/2013 19:00	Near No.14 Wang Lung Street	No.14-30, Wang Lung Street
8/6/2013	8/6/2013 11:00	9/6/2013 01:15	Near No.150-164 Texaco Road Back Lane	Ma Kok Street and Tsuen Yip Street
10/6/2013	10/6/2013 17:30	11/6/2013 09:00	No.14 Hoi Pa Village North-East Terrace Footpath	No.9 Hoi Pa Village North-East Terrace
11/6/2013	11/6/2013 09:50	11/6/2013 20:30	Near Lamp Post W1979 Sai Lau Kok Road	HKEAA, Tsuen Wan Assessment Centre
17/6/2013	17/6/2013 20:00	18/6/2013 05:00	Near No. 381-389 Sha Tsui Road	No.271-407 Sha Tsui Road, Ham Tin Street, Kwan Mun Hau Street, Tak Hoi Street and No.110-202 Texaco Road
20/6/2013	20/6/2013 11:05	20/6/2013 14:10	Near No.72 Ho Pui Street Back Lane	No.70-84 Ho Pui Street and No.85-99 Yeung Uk Road
20/6/2013	20/6/2013 11:45	20/6/2013 18:45	Junction of Tsuen Wan Market Street and Chung On Street	2-66 Chung On Street, 47-51 Shu Wo Street 87-95 Market Street
21/6/2013	21/6/2013 15:00	21/6/2013 16:20	Near No.58 Tak Wah Street Back Lane	No.297-355 Sha Tsui Road, No.2-70 Tak Wah Street & No.72-78 Kwan Mun Hau Street
24/6/2013	24/6/2013 15:45	24/6/2013 16:55	Near No.2 Hoi Pa Resite Village Back Lane	No.2-31 Hoi Pa Resite Village
30/6/2013	30/6/2013 10:30	30/6/2013 21:00	Tsuen Kam Interchange Carriageway near Lamp Post BC0147	Fairview Garden, Luk Yeung San Chuen, Ma Sim Pai Road, Fu Yung Shan Road
4/7/2013	4/7/2013 10:10	4/7/2013 14:00	No.93 Kwan Mun Hau Tsuen Back Lane	No.91-100 Kwan Mun Hau Tsuen
5/7/2013	5/7/2013 18:25	5/7/2013 21:00	No.50 Ham Tin Street Carriageway	Ham Tin Street, Tak Wah Street, Kwan Mun Hau Street, Sha Tsui Road & City Landmark I
17/7/2013	17/7/2013	17/7/2013	No.19 Chung Kwai	No.7-58 Chung Kwai

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
	15:30	16:45	Chung Tsuen	Chung Tsuen
20/7/2013	20/7/2013 13:00	20/7/2013 17:00	No.22-32 Pun Shan Street Tsuen Wan	Tom Lee Godown, No.22-32 Pun Shan Street
6/8/2013	6/8/2013 03:40	6/8/2013 16:30	Near Lamp Post FA5869 Shek Wai Kok Road	Shek Wai Kok Estate
10/8/2013	10/8/2013 14:00	10/8/2013 19:00	No.200 Tsuen King Circuit	No.200 Tsuen King Circuit
10/8/2013	10/8/2013 19:15	11/8/2013 01:45	Near Lamp Post FA 6026, Sam Tung Village, Tsuen Wan	Chuen Yiu Terrace, Yi Pei Chun Hoi Pa Village, Sam Tung Uk Village, Wing Wah Terrace
25/8/2013	25/8/2013 18:01	25/8/2013 19:00	Back Lane of No.34 Chung Kwan Chung Tsuen	No.7-58 Chung Kwai Chung Tsuen
29/8/2013	29/8/2013 09:07	29/8/2013 19:00	Near Wing Lung House, Hoi Pa Street	Lo Tak Court, Hoi Pa Street, Sha Tsui Road
29/8/2013	29/8/2013 11:00	29/8/2013 17:10	Near No.1 Pak Tin Pa Tsuen	No.1-4,10-13 Pak Tin Pa Tsuen, Tsuen Wan
3/9/2013	3/9/2013 15:30	4/9/2013 01:40	Near No.38-46, Tsuen Wah Street	Tsuen Fu Steet, Tsuen Wing Street, Tsuen Kwai Street , Tsuen Wah Street
6/9/2013	6/9/2013 09:45	6/9/2013 16:40	Kun Ming Street, Lo Tak Court	No.303-313, Castle Peak Road
9/9/2013	9/9/2013 17:00	9/9/2013 22:00	No.289 Sha Tsui Road , Back Lane	No.271-289 Sha Tsui Road, No.45-50 Han Tin Street, No.9-17 Sze Pei Square
11/9/2013	11/9/2013 20:10	11/9/2013 22:00	Back Lane No.142, Tsuen Wan Market Street	No.120-166, Tsuen Wan Market Street
12/9/2013	12/9/2013 14:15	12/9/2013 20:45	Back Lane of No.28-30, Tak Wah Street	No.325-331, Sha Tsui Road
18/9/2013	18/9/2013 19:15	18/9/2013 21:00	Near Tsuen Wan Plaza, Hoi Shing Road	Tsuen Wan Plaza, Hoi Shing Road
24/9/2013	24/9/2013 09:40	24/9/2013 11:40	Back Lane of No.286. Sha Tsui Road	No.286-296. Sha Tsui Road
25/9/2013	25/9/2013 16:00	26/9/2013 10:00	Near No.3 Tsuen Wah Street	No.3 Tsuen Wah Street
26/9/2013	26/9/2013 23:00	27/9/2013 07:50	Near No.87, Tsuen King Circuit	Tsuen King Graden & Tsuen Wan Centre
28/9/2013	28/9/2013 13:30	28/9/2013 14:30	Back Lane of No.11, Tsuen Lok Street	No.120-166 Tsuen Wan Market Street, 1-17 Tsuen Lok Street

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
28/9/2013	28/9/2013 16:05	28/9/2013 22:00	No.44-50, Wang Wo Tsai Street	No.43-69 Wang Wo Tsai Street ,368-370 Sha Tsui Road
4/10/2013	4/10/2013 10:30	4/10/2013 16:00	No.19 Tai Ho Road	Chau's Building, Tsuen Wan District Junior Police Call Club House,
4/10/2013	4/10/2013 12:30	4/10/2013 20:35	No.40-50, Sha Tsui Road	No.40-50 , Sha Tsui Road
7/10/2013	8/10/2013 10:10	8/10/2013 11:55	No.225 Wo Yi Hop Road, Kwai Chung	Wo Yi Hop Road Substation
10/10/2013	10/10/2013 15:00	10/10/2013 16:35	No.83-93. Chai Wan Kok Street	No.83-93, Chai Wan Kok Street
16/10/2013	16/10/2013 19:00	17/10/2013 20:00	Near Lamp Post FB2843, Kwok Shui Road	No.684-708, Castle Peak Road, Chung Kwai Village, Partk of Kwok Shui Road, Yeung Uk Village , Ho Pui Village, Ham Tin Villge, Hoi Pa Sam Tsuen, Fa Chuen Ping Village,Tai Pak Tsiu Village, Sheung Kwai Chung Village
19/10/2013	19/10/2013 14:20	19/10/2013 17:30	Back Lane of No.136 Ho Pa Street	No.134-136 Ho Pa Street
23/10/2013	23/10/2013 10:30	23/10/2013 18:00	No. 57 Sha Tsui Road Tsuen Wan	No.1-57,2-79 Sha Tsui Rd No.1-53,2-44 Pak Tin Par Street
23/10/2013	23/10/2013 18:05	24/10/2013 04:30	Near No.503 Castle Peak Road	Pak Tin Par Street, 503-515 Castle Peak Road, Tai Chung Road
23/10/2013	23/10/2013 20:30	24/10/2013 15:00	No.38 Tai Chung Road	No.1-57,2-76 Sha Tsui Road No.1-53,2-44 Pak Tin Par Street
24/10/2013	24/10/2013 15:30	25/10/2013 09:30	Tai Ho Rd, Near Nina Towerr,	Tai Ho Road Bus Terminus
24/10/2013	24/10/2013 17:00	24/10/2013 19:30	Back Lane of No. 127-135 Yeung Uk Road	No.127-143 Yeung Uk Road No.2-14 Kwu Hang Road
27/10/2013	27/10/2013 15:35	28/10/2013 09:00	Back Lane of No.127-135 Yeung Uk Road	No.127-135 Yeung Uk Road
29/10/2013	29/10/2013	29/10/2013	Lamp Post FB5106	Tsuen King Circuit Sports

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
	21:30	22:30	Chiu Tam Path	Centre
31/10/2013	31/10/2013 10:10	31/10/2013 16:30	Near Lamp Post FB2843, Kwok Shui Road	No.698-704, Castle Peak Road
1/11/2013	1/11/2013 11:30	2/11/2013 09:00	Near Chai Wai Kok Cooked Food Centre	Chai Wan Kok Public Toilet
8/11/2013	8/11/2013 09:30	8/11/2013 15:40	No.60-64, Ham Tin Street	No.298 Sha Tsui Road, No.60-64 Ham Tin Street
10/11/2013	10/11/2013 11:00	10/11/2013 14:00	No.40-47, Pak Par Street	No.36-61 Tin Par Street No.2-28 Tai Chung Road No.459-469 Castle Road
12/11/2013	12/11/2013 11:00	12/11/2013 16:15	No.9-23 Heung Wo Street	No.112-189, Sha Tsui Road, No.9-69 Heung Wo Street
14/11/2013	14/11/2013 12:40	14/11/2013 17:00	Near No.72 Hoi Pa Resite Village	Sam Tung Uk Village, Hoi Pa Resite Village
14/11/2013	14/11/2013 15:30	14/11/2013 19:10	Back Lane of No. 133-135 Chuen Lung Street	No.133-135 Chuen Lung Street, No.56-60 Ho Pui Street, No.112-114 Chung On Street, No.77-79 Yeung Uk Road
15/11/2013	15/11/2013 13:52	15/11/2013 19:15	Back Lane of No.115 Hoi Pa Street	No.103-117 Hoi Pa Street, No.22-30 Chung On Street, No.4-22 Market Street, No.45-55 Tai Ho Road
18/11/2013	19/11/2013 04:00	19/11/2013 20:00	Wai Tsuen Rd. Near Block B, Luk Yeung Sun Chuen	Fu Yung Shan Road, Ma Siu Par Road, Wai Tsuen Road, Luk Yeung Sun Chuen
21/11/2013	21/11/2013 13:50	21/11/2013 14:45	Back Lane of No.19 Tso Kung Square	No.1-37 Tso Kung Square No.105-139 Sha Tsui Road
22/11/2013	22/11/2013 03:00	22/11/2013 10:30	No.74 Hau Tei Square	No.74 Hau Tei Square
26/11/2013	26/11/2013 09:30	26/11/2013 22:35	No.106-114, Kwok Shui Road	No.88-130, Kwok Shui Road
28/11/2013	29/11/2013 09:40	29/11/2013 12:30	No.221 Wo Yi Hop Road, Kwai Chung	No.221 Wo Yi Hop Road
6/12/2013	6/12/2013 13:30	7/12/2013 09:00	No.145-149, Kwok Shui Road	No.55-149, Kwok Shui Road
8/12/2013	8/12/2013 11:30	8/12/2013 18:30	No.75 Chai Wan Kok Street	2-95. Chai Wan Kok Street
11/12/2013	11/12/2013	12/12/2013	Near Lamp Post	Yan Chai Hospital Hong

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
	17:00	00:30	AC1246 Kwan Mun Hau Street	Kong Jockey Club Polyclinic, Yan Chai Multi-Services Complex, Tsuen Wan Catholic Primary School
18/12/2013	18/12/2013 14:00	19/12/2013 09:00	Back Lane of No.68 Ho Pui Street	Mary of Providence Primary School
19/12/2013	19/12/2013 07:30	19/12/2013 15:00	Near No.18 Ma Kok Street	Pbe Building, 18 Ma Kok Street
21/12/2013	21/12/2013 21:00	22/12/2013 04:15	Back Lane of No. 37-41 Tak Wah Street	No.37-41 Tak Wah Street
22/12/2013	22/12/2013 09:10	22/12/2013 16:30	Near No.9-10 Pak Tin Pa Tsuen	No.1-4,10-13 Pak Tin Pa Tsuen
24/12/2013	24/12/2013 09:20	24/12/2013 19:00	Lamp Post FB5076, Mei Wan Street	Tsuen King Circuit Sports Centre
2/1/2014	2/1/2014 12:05	2/1/2014 18:00	Back Lane of No.188, Texaco Road	No.188-202 Texaco Road
4/1/2014	4/1/2014 16:52	4/1/2014 21:30	Back Lane of No.932 Kwan Mun Hau Tsuen	No.927-932,111-116,105-110,14-37 Kwan Mun Hau Tsuen
5/1/2014	5/1/2014 08:37	5/1/2014 15:00	Near No.18-20 Pun Shan Street	No.10-20 Pun Shan Street
6/1/2014	6/1/2014 12:50	7/1/2014 02:30	59-71, Wang Lung Street	Wang Lung Street and Ma Kok Street
11/1/2014	11/1/2014 11:25	11/1/2014 17:30	Back Lane of No. 75 Ham Tin Street	No. 61-75 Ham Tin Street
17/1/2014	17/1/2014 06:50	17/1/2014 16:35	No.3-7 Kin Ming Street	No.303-313, Castle Peak Road
17/1/2014	17/1/2014 15:20	17/1/2014 18:45	Besides of Nina Tower	Nina Tower, Tai Hoi Road
20/1/2014	20/1/2014 09:31	20/1/2014 16:30	Near Fire Hydrant 3104, Hoi Kwai Road	Hoi Kwai Rd, Refuse Collection Point
24/1/2014	24/1/2014 18:02	25/1/2014 01:00	Near No.6-28, Chai Wan Kok Street	Chai Wan Kok Street Public Toilet
26/1/2014	26/1/2014 15:30	27/1/2014 09:00	Back Lane of No.319 Sha Tsui Road	No.315-323 Sha Tsui Road
4/2/2014	4/2/2014 15:15	5/2/2014 09:00	Back Lane of No. 57 Hoi Pa Sau Tsuen	30-58 Hoi Pa Sau Tsuen
4/2/2014	4/2/2014 17:10	5/2/2014 09:00	Back Lane of No.39 Hoi Pa Sau Tsuen	No.39 Hoi Pa Sau Tsuen
7/2/2014	7/2/2014 10:30	7/2/2014 15:00	No.23 Mei Wan Street	No.23-27, Mei Wan Street
7/2/2014	8/2/2014	8/2/2014	Near CLP substation,	1 Mei Wan Street, CLP

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
	00:30	02:00	Mei Wan Street	substation, 1-17 Sai Lau Kok Road, Tsuen Kam Centre, Tsuen Wan Government Office Library
17/2/2014	17/2/2014 12:15	18/2/2014 14:30	Near Lamp Post FC3732 Tsuen Yip Street	No.188-202 Texaco Road
20/2/2014	20/2/2014 18:00	21/2/2014 02:00	Back Lane of No. 168 Sha Tsui Road	No.112-188 Sha Tsui Road, No. 9-63 Heung Wo Street
20/2/2014	20/2/2014 18:50	21/2/2014 09:00	No. 71 Yuen Tun Circuit	No.112-188 Sha Tsui Road and No.9-63 Heung Wo Street and Magistrates Courts
21/2/2014	21/2/2014 13:00	21/2/2014 15:35	Back Lane of No. 44 Chung Kwai Chung Tsuen	No.7-58, Chung Kwai Chung Tsuen
23/2/2014	23/2/2014 15:05	24/2/2014 02:00	Near Lamp Post DC 1208 Tsuen Wan Market Street	Part of Tsuen Wan Market Street
25/2/2014	25/2/2014 11:12	25/2/2014 17:12	Back Lane of No.45 Shiu Wo Street	No.2-24 Chung On Street, No.46-51 Shiu Wo Street, No.167-173 Castle Peak Road
25/2/2014	25/2/2014 13:40	25/2/2014 15:00	Near Lamp Post FC3734, Tsuen Yip Street	No.2-18 Ma Kok St, No.68-84 Wang Lung Street
27/2/2014	27/2/2014 09:52	27/2/2014 15:00	Back Lane of No. 2-8 Yi Pei Square	NO.93-123 Chuen Lung Street, No.2-32 Yi Pei Square, No.254-260 Sha Tsui Road
4/3/2014	4/3/2014 15:30	4/3/2014 16:30	Back Lane of No.18 Chung On Street	167-173, Castle Peak Rd, 2-24, Chung On St. 47-51, Shui Wo St.
6/3/2014	6/3/2014 18:05	6/3/2014 20:45	Near Lamp Post FA4700 Texaco Road	No. 229-231 Texaco Road
14/3/2014	14/3/2014 20:30	14/3/2014 22:50	Back Lane of No. 8 Tso Kung Street	No.2-32 Hoi Pa St, No.2-36 Tso Kung Street
17/3/2014	17/3/2014 21:45	18/3/2014 09:00	No.5-9 Chai Wan Kok Street	No. 5-15 Chai Wan Kok Street
18/3/2014	18/3/2014 14:00	19/3/2014 03:30	Near Lamp Post W1851, Chiu Tam Path	No.374-380 Castle Peak Road

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
19/3/2014	19/3/2014 20:00	20/3/2014 02:30	Near Tso Kung Tam Nursery, Chiu Tam Path	No.374-380 Castle Peak Road
24/3/2014	24/3/2014 23:00	25/3/2014 00:30	No.5-15, Chai Wan Kok Street	No.11-15, Chai Wan Kok Street
25/3/2014	25/3/2014 10:30	26/3/2014 09:30	No.5-9 Chai Wan Kok Street	No.5-15 Chai Wan Kok Street
2/4/2014	2/4/2014 16:45	3/4/2014 09:00	Near No. 38 Sai Lau Kok Road	Tsuen Kam Centre
3/4/2014	3/4/2014 17:30	3/4/2014 23:00	Near Lamp Post FB3147 Texaco Road	Part of Texaco Road
8/4/2014	8/4/2014 15:40	9/4/2014 10:30	Near Lamp Post W4441 Kwan Mun Hau Tsuen	Part of Kwan Mun Hau Tsuen
9/4/2014	9/4/2014 20:30	9/4/2014 23:45	Back Lane of No. 24 Shiu Wo Street	12-40, Shui Wo Street, 27-59 Tsuen Wan Market Street, 1-23 Chung On Street, 3-25 Chun Lung Street, 181-227, Castle Park Road
20/4/2014	20/4/2014 04:45	20/4/2014 12:30	Near Lamp Post DC 0565 Kin Ming Street	No. 313-303 Castle Peak Road -Tsuen Wan
22/4/2014	22/4/2014 13:50	23/4/2014 09:00	Near No.70 Hoi Pa Street	One School
27/4/2014	27/4/2014 09:50	27/4/2014 15:30	Near Lamp Post W0463 Yau Ma Hom Road	No.19-25 Fu Uk Road
5/5/2014	5/5/2014 13:10	5/5/2014 16:20	Near No.55 Kwan Mun Hau Tsuen	No.39-60 Kwan Mun Hau Tsuen
16/5/2014	16/5/2014 15:30	16/5/2014 20:00	Near Lamp Post W0475 Kwok Shui Road	Part of Kwok Shui Road
17/5/2014	17/5/2014 19:20	18/5/2014 03:00	Near Kwok Shui Road Park Kwok Shui Road	Part of Kwok Shui Road
19/5/2014	19/5/2014 14:40	20/5/2014 06:45	Near Lamp Post W0535, Kwok Shui Road	PCCW Building
22/5/2014	22/5/2014 15:15	22/5/2014 17:30	B/L of No. 125 Castle Peak Road	No. 115-143 Castle Peak Road
23/5/2014	23/5/2014 10:30	23/5/2014 17:00	Near Ka Pok Mansion, No.115-119 Building Market Street	No.115-119Market Street
29/5/2014	29/5/2014 10:20	29/5/2014 17:00	Near No.115 Tsuen Wan Market Street	No.115-143Tsuen Wan Market Street
10/6/2014	10/6/2014 12:00	10/6/2014 16:17	No.15, Sze Pei Square	No.4-17 Sze Pei Square, No.221-289 Sha Tsui Road and No.44-50 Ham Tin Street

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
10/6/2014	10/6/2014 20:00	11/6/2014 04:00	No.184-186 Texaco Road	Tsuen Wan Garden , Jade Court, No.168-186 Texco Road , Cheong Kwai Court
10/6/2014	10/6/2014 20:30	11/6/2014 04:30	No.126-140 Texaco Road	No.67-147 Texaco Road.
13/6/2014	13/6/2014 06:30	13/6/2014 21:30	Tai Ho Rd, Near Yeung Uk Road	Vision City, No. 1 Yeung Uk Road
16/6/2014	16/6/2014 22:40	17/6/2014 02:15	Near Tsuen Wan Plaza Yuen Tun Circuit	Yuen Tun Circuit Heung Wo Street, Hoi Shing Road
17/6/2014	17/6/2014 06:35	17/6/2014 13:30	Near Lamp Post CC0999 Tsuen King Circuit	Tsuen King Garden Block 8 &10
21/6/2014	21/6/2014 21:00	22/6/2014 02:30	No. 34-45 Chai Wan Kok Street	No.2-90 Chai Wan Kok Street,
24/6/2014	24/6/2014 20:52	25/6/2014 00:15	Beside No.71 Yuen Tun Circuit	112-180Sha Tsui Road, 5-69Heung Wo Street
26/6/2014	26/6/2014 19:00	26/6/2014 22:00	Near Fui Yiu Kok Street,Wang Lung Street	Fui Yiu Kok Street and Wang Lung Street
2/7/2014	2/7/2014 23:00	3/7/2014 03:30	Near Lamp Post FC0408 Hoi Kok Street	Belvedere Garden Phase I.II.III. Greenview Court , Greenview Terrace, The Westminster Terrace, Long Beach Garden
9/7/2014	9/7/2014 14:45	9/7/2014 20:50	Near Lamp Post W0065, Tsuen King Circuit	Tsuen King Garden, Tsuen Wan Police Station, Way Lee Industrial Center
10/7/2014	10/7/2014 04:00	10/7/2014 15:00	Near Lamp Post DC 1207 Tsuen Wan Market Street	Part of Tsuen Wan Market Street
10/7/2014	10/7/2014 14:00	10/7/2014 16:30	Near No.2 Ho Pa Resite Village	No. 2-9, Hoi Pa Resite Village
11/7/2014	11/7/2014 09:35	11/7/2014 16:30	Near No. 321, Wo Yi Hop Road	No.273-327, Wo Yi Hop Road
15/7/2014	15/7/2014 14:50	15/7/2014 15:50	Near No.83, Chai Wa Kok Street	No. 85-89 , Chai Wan Kok Street
17/7/2014	18/7/2014 00:30	18/7/2014 04:00	Near Lamp Post W0064 Tsuen King Circuit	Tsuen King Circuit
23/7/2014	23/7/2014 13:00	24/7/2014 01:30	Near Fire Hydrant 3760, Phase I, Belvedere Garden Tsuen Wan	1.Phase I,II,III, Belvedere Garden 2.Serenade Cove

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
				3.Greenview Court 4.Bayview Garden 5.Golden View 6.Greenview Terrace
31/7/2014	31/7/2014 18:40	31/7/2014 22:00	Near Lamp Post AC1986 Tsuen Wan Market Street	No.115-129 Market Street
2/8/2014	2/8/2014 18:30	2/8/2014 22:30	Near Lamp Post FC0474, Texaco Road	Tsuen Wan Driving Test Centre
6/8/2014	6/8/2014 07:30	6/8/2014 20:00	Near No.118 Chuen Lung Street	Chuen Lung Street, Ho Pui Street, San Tsuen Street, Sha Tsui Road and Wo Tik Street
8/8/2014	8/8/2014 18:00	8/8/2014 21:45	Near No.271 Sha Tsui Road	No.74-90 Chung On Street
8/8/2014	8/8/2014 23:00	9/8/2014 01:08	Near Lamp Post DC1784 Yeung Uk Road	Vision City
9/8/2014	9/8/2014 22:00	10/8/2014 01:50	No.95 Kwan Mun Hau Tsuen Back Lane	Kwan Mun Hau Tsuen
15/8/2014	15/8/2014 23:15	16/8/2014 01:30	Near No.45 Chuen Lung Street	No.43-135 Chuen Lung Street, No. 33-66 Ho Pui Street No.230-252 Sha Tsui Road, and No.45-79 Yeung Uk Road
19/8/2014	19/8/2014 14:05	19/8/2014 19:00	Near Lamp Post FC2620, Castle Peak Road	The Panorama
26/8/2014	26/8/2014 13:40	27/8/2014 09:00	Near Lamp Post AC1260, Tsuen Kwai Street	Wealthy Garden
27/8/2014	27/8/2014 17:55	28/8/2014 09:00	No.115 Tsuen Wan Market Street	No.115-119 Tsuen Wan Market Street and No.99-121 Castle Peak Road
27/8/2014	27/8/2014 22:00	28/8/2014 02:00	Near Lamp Post W2105 Tsuen King Circuit Tsuen Wan	Tsuen King Circuit
30/8/2014	30/8/2014 05:51	30/8/2014 21:50	No.381-389 Sha Tsui Road	No.381-389 Sha Tsui Road
30/8/2014	30/8/2014 22:00	31/8/2014 00:20	No.24-32, Pak Tin Par Street	Pak Tin Par Street
3/9/2014	3/9/2014	3/9/2014	Near Lamp Post	No.1-27 Tsuen Kwai

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
	11:31	21:45	DC0162, Kwan Mun Hau Street	Street, and No.12-26 Tsuen Fu Street
8/9/2014	8/9/2014 09:55	9/9/2014 09:00	Near No.51 Lo Tak Court	Cheong Wah Building
10/9/2014	11/9/2014 01:00	11/9/2014 10:30	Texaco Road O/S No.142-148	No.1-100 Texaco Road
10/9/2014	11/9/2014 03:00	11/9/2014 11:00	Near Lamp Post AC3291 Sha Tsui Road	Part of Sha Tsui Road and Kwan Mun Hau Street Texaco Road
11/9/2014	11/9/2014 18:40	11/9/2014 19:50	Back Lane of No.32 Hoi Pa Street	No.2-32 , Hoi Pa Street and No.2-36 Tso Kung Square
15/9/2014	15/9/2014 14:30	15/9/2014 17:30	Back Lane of No.48 Tak Wah Street	No.40-60 Tak Wah Street, No.337-355 Sha Tsui Road
18/9/2014	18/9/2014 17:50	19/9/2014 09:00	Near No.297 Wo Yi Hop Road	No.273-336 Wo Yi Hop Road
19/9/2014	19/9/2014 05:30	19/9/2014 15:30	Near No.67-95, Tsuen Wan Market Street	No.117-143 Castle Peak Road, No.2-24 Chung On Street, No.67-95 Tsuen Wan Market Street, Yan Chai Hospital 47-51 Shin Wo Street
19/9/2014	19/9/2014 14:35	19/9/2014 20:30	Near No.50 Wang Wo Tsai Street	No.2-50 Wang Wo Tsai Street, No.127-181 Yeung Uk Road
22/9/2014	22/9/2014 16:30	23/9/2014 06:30	Near Lamp Post W4127 Hoi Shing Road	Hoi Shing Road, Chai Wan Kok Street, Yuen Tun Circuit
22/9/2014	22/9/2014 21:00	23/9/2014 08:30	Near Lamp Post FC0536 Tsuen Wan Road	Part of Tsuen Wan Area
24/9/2014	24/9/2014 22:00	25/9/2014 15:35	Near Chelsea Court, Ma Tau Pa Road	Chelsea Court
26/9/2014	26/9/2014 09:25	26/9/2014 11:39	Near No.115-119 Tsuen Wan Market Street	No.99-133 Tsuen Wan Market Street
26/9/2014	26/9/2014 20:00	27/9/2014 02:49	Near Tsuen Wan Salt Water Pumping Station	Part of Tsuen Wan
4/10/2014	4/10/2014 23:00	5/10/2014 01:30	No.54 Hoi Pa Resite Village	54-57 Hoi Pa Resite Village
10/10/2014	10/10/2014 13:55	10/10/2014 17:00	Near No.73. Chuen Lung Street	Part of Chuen Lung Stret. Sha Tsui Road. and Chung On Street
12/10/2014	12/10/2014	12/10/2014	Back Lane of No.90	87-90 Sam Tung Uk

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
	11:45	20:30	Sam Tung Uk Resite Village	Resite Village
13/10/2014	13/10/2014 15:30	14/10/2014 20:00	Near Lamp Post W0068 Tsuen King Circuit	Tsuen King Garden I & II, Tsuen Wan Centre I & II
14/10/2014	14/10/2014 21:00	15/10/2014 13:30	Near Tsuen Wan Salt Water Pumping Station	Clague Garden Estate
16/10/2014	16/10/2014 12:00	17/10/2014 07:00	Near Lamp Post W4127 Hoi Shing Road	Part of Tsuen Wan Area
16/10/2014	16/10/2014 14:30	16/10/2014 15:45	Near No.36-44 Pak Tin Par Street	Goodwill Industrial Building
23/10/2014	23/10/2014 11:00	23/10/2014 21:30	Near Former Tsuen Wan Lutheran School, Cheung Shan Estate	Former Tsuen Wan Lutheran School
24/10/2014	24/10/2014 13:30	24/10/2014 16:30	No.3-5 Tsuen Hing Path, Lo Tak Circuit	Lo Tak Circuit.
22/10/2014	24/10/2014 17:00	25/10/2014 10:00	Near Lamp Post CC0412 Kwok Shui Road	Part of Kwok Shui Road
30/10/2014	30/10/2014 19:40	31/10/2014 03:45	Near Lamp Post AC1246 Kwan Mun Hau Street	Yan Chai Hospital The Hong Kong Jockey Club Polyclinic New Haven
31/10/2014	31/10/2014 14:00	31/10/2014 15:20	Near No.1 Ho Pui Tsuen	No.1-48 Ho Pui Tsuen
31/10/2014	31/10/2014 19:00	31/10/2014 20:30	Back Lane of No.23 Sha Tsui Road	No.23 Sha Tsui Road
1/11/2014	1/11/2014 12:00	1/11/2014 16:10	No.72 Hoi Pa San Tsuen	No.59-81 Hoi Pa San Tsuen
5/11/2014	5/11/2014 14:00	5/11/2014 15:10	Near No.114 Kwan Mun Hau Tsuen	No.85 Kwan Mun Hau Tsuen
5/11/2014	5/11/2014 22:30	6/11/2014 01:00	Near Lamp Post FC 3727 Lung Tak Street	Part of Lung Tak Street
9/11/2014	9/11/2014 22:40	10/11/2014 10:00	Near No.35 Chai Wan Kok Street	Part of Chai Wan Kok Street
10/11/2014	10/11/2014 17:00	10/11/2014 21:45	Near Lamp Post DC 1769 Tai Ho Road	Part of Tai Ho Road
12/11/2014	12/11/2014 10:00	12/11/2014 17:00	Near Lam Post No. FA5945 Sam Tung Uk Road	Part of Sam Tung Uk Tsuen
15/11/2014	15/11/2014 10:00	15/11/2014 15:30	Near Lamp Post AC3347 Hoi Kok Street.	Refuse Storage, Hoi Hing Road
19/11/2014	19/11/2014 13:15	19/11/2014 14:30	Near Lamp Post FB2852 Ting Fung	Part of Yeung Uk Tsuen & Hoi Pa San Tsuen

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
			Street	
21/11/2014	21/11/2014 13:20	21/11/2014 15:00	Near No.59 Hoi Pa San Tsuen	Hoi Pa San Tsuen. Ham Tin Tsuen
21/11/2014	21/11/2014 20:45	22/11/2014 04:15	Near Lam Post No. FC0258 Hau Tei Square	Part of Hau Tei Square
28/11/2014	28/11/2014 10:00	29/11/2014 10:00	No.2-4 Chai Wan Kok Street	Chai Wan Kok Public Toilet.
1/12/2014	1/12/2014 15:00	2/12/2014 09:00	Back Lane of No.144 Sha Tsui Road	No.112-188 Sha Tsui Road & No.9-73 Heung Wo Street
2/12/2014	2/12/2014 10:35	2/12/2014 16:30	Near No.44 Pak Tin Par Street	Goodwill Industrial Building.
3/12/2014	3/12/2014 15:40	4/12/2014 09:00	Back Lane of No.41 Heung Wo Street	No.112-188 Sha Tsui Road & No.9-73 Heung Wo Street
9/12/2014	9/12/2014 05:00	10/12/2014 04:40	Near Lamp Post W1542, Texaco Road North	Shing Mun Valley Swimming Pool, Shek Wai Kok Estate
10/12/2014	10/12/2014 10:15	10/12/2014 12:00	No.62 Hau Tei Square	Part of Hau Tei Square
15/12/2014	15/12/2014 15:00	15/12/2014 21:40	Near Lamp Post AC5666 Wang Wo Tsai Street	Wang Wo Tsai Street, Wong's Factory Building, Bonsun Industrial Building
18/12/2014	18/12/2014 09:45	18/12/2014 11:00	Near No.57 Chung Kwai Chung Tsuen	No. 7-12, 19-24, 31-36, 53-58 Chung Kwai Chung Tsuen
19/12/2014	19/12/2014 16:10	20/12/2014 09:30	Near No. 68 Hau Tei Square	No. 24-72 Hau Tei Square
22/12/2014	22/12/2014 15:05	22/12/2014 15:50	Near No.61 Ho Pui Tsuen. Ting Fung Street	No.47-73 Ho Pui Tsuen
29/12/2014	29/12/2014 14:10	29/12/2014 17:00	No. 88 Kwok Shui Road	Part of Kwok Shui Road
30/12/2014	30/12/2014 14:30	31/12/2014 09:31	Near Lamp Post FA6369 Kwok Shui Road	No. 88 Kwok Shui Road
2/1/2015	2/1/2015 16:10	3/1/2015 09:45	Near Lamp Post DC0164 Kwan Mun Hau Street	Yan Chai Hospital The Hong Kong Jockey Club Polyclinic, New Haven
6/1/2015	6/1/2015 06:15	6/1/2015 16:20	Near Lamp Post AC0820 On Yin Street	Part of Tsuen King Circuit
9/1/2015	9/1/2015 09:40	9/1/2015 12:05	Near No. 70 Tak Wah Street	No. 40-70 Tak Wah Street, No. 337-355 Sha Tsui Road

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
14/1/2015	14/1/2015 14:20	15/1/2015 09:00	Near Lamp Post FB9305 Sai Lau Kok Road	No. 1 Sai Lau Kok Road
18/1/2015	18/1/2015 15:30	19/1/2015 03:00	Near Lamp Post FC3727 Lung Tak Street	Lung Tak Street
21/1/2015	21/1/2015 09:45	21/1/2015 10:30	Near No. 273 Wo Yi Hop Road	No.273-335 Wo Yi Hop Road, No.1-17 Lei Shu Road
29/1/2015	29/1/2015 11:02	29/1/2015 17:30	Near No. 144 Hoi Pa Street	No. 142-146 Hoi Pa Street
31/1/2015	31/1/2015 15:05	1/2/2015 01:30	Near Lamp Post DC1769 Tai Ho Road	Bus Terminus
1/2/2015	1/2/2015 16:50	1/2/2015 21:15	Near Fire Hydrant 83 Chai Wan Kok Street	Chai Wan Kok Street Public Toilet
3/2/2015	3/2/2015 23:24	4/2/2015 08:30	Near No. 566 Castle Peak Road	Mita Centre
7/2/2015	7/2/2015 11:30	7/2/2015 15:00	Near No. 31 Ma Tau Pa Road	No. 19-31 Ma Tau Pa Road
14/2/2015	14/2/2015 06:00	14/2/2015 16:30	Cheung Shan Estate East Road	Lo Wai, Sham Tung Uk Tsuen, Hoi Pa Resite Village, Cheung Shan Estate, Ho Fung College, and Li Ping Secondary School
16/2/2015	16/2/2015 13:10	17/2/2015 01:30	Near Lamp Post W0047 Cheung Shan Estate Road East	Part of Cheung Shan Estate, Sam Tung Uk Resite Village, Yi Pei Chun Road, Lo Wai
17/2/2015	17/2/2015 09:15	17/2/2015 18:45	No. 26-38 Sha Tsui Road	Part of Sha Tsui Road
18/2/2015	24/2/2015 10:30	24/2/2015 17:35	Near Lamp Post 3281 Wing Shun Street	Waterside Plaza, Shek Chung Shan Memorial College Primary School
26/2/2015	26/2/2015 14:35	26/2/2015 15:45	Near No. 16 Hoi Pa Village South Terrace	No. 16 Hoi Pa Village South Terrace
5/3/2015	5/3/2015 14:00	5/3/2015 22:30	Near Lamp Post AC0659 Tsuen King Circuit	Tsuen King Circuit
6/3/2015	6/3/2015 09:55	6/3/2015 15:45	Near No. 66-82 Chai Wan Kok Street	No. 66-82 Chai Wan Kok Street, Tsuen Wan
9/3/2015	9/3/2015	10/3/2015	No. 13 Lei Shu Road	No. 7-17 Lei Shu Road

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
	18:20	00:10		
10/3/2015	10/3/2015 07:20	10/3/2015 14:30	No. 26-38 Sha Tsui Road	No. 2-76 Sha Tsui Road, 8-38 Tai Chung Road, 1-32 Pun Shan Road, 6-61 Pak Tin Par Street
13/3/2015	13/3/2015 12:30	13/3/2015 21:00	Near Lamp Post W0068 Tsuen King Circuit	No. 374-380 Castle Peak Road
13/3/2015	13/3/2015 14:15	13/3/2015 23:05	Near No. 32 Pun Shan Street	No. 1-32 Pun Shan Street
16/3/2015	16/3/2015 17:30	17/3/2015 00:30	Near Lamp Post W1860 Tsuen King Circuit	No. 374-380 Castle Peak Road
20/3/2015	20/3/2015 21:20	21/3/2015 03:00	Near No. 115 Hoi Pa Street	No. 103-117 Hoi Pa Street, No. 22-30 Chuen Lung Street, No. 4-12 Tsuen Wan Market Street
25/3/2015	25/3/2015 14:10	25/3/2015 15:40	Near Lamp Post FB6410 Hoi Pa Village South Terrace	Hoi Pa Village South Terrace
26/3/2015	26/3/2015 10:55	26/3/2015 12:00	Near No. 33 Ho Pui Tsuen	Part of Ho Pui Tsuen
31/3/2015	31/3/2015 11:50	31/3/2015 13:00	Near No. 80 Hoi Pa San Tsuen	Part of Hoi Pa San Tsuen
5/4/2015	5/4/2015 23:35	6/4/2015 03:45	Near No. 37 Chuen Lung Street	No. 120-150 Hoi Pa Street and No. 31-89 Chuen Lung Street
8/4/2015	8/4/2015 16:20	8/4/2015 18:10	Near No. 932 Kwan Mun Hau Tsuen	No. 29-37, 111-16, 105-110, 927-932 Kwan Mun Hau Tsuen
22/4/2015	22/4/2015 16:50	23/4/2015 09:00	Near No. 144 Sha Tsui Road	No. 25-41 Heung Wo Street, No. 132-144 Sha Tsui Road
29/4/2015	29/4/2015 11:30	29/4/2015 16:00	Back of No. 107 Chuen Lung Street	Part of Chuen Lung Street, Hoi Pui Street, Sha Tsui Road & Chung On Street
30/4/2015	30/4/2015 09:00	30/4/2015 15:30	Near Fire Hydrant 3742 Hoi Pui Street	Part of Hoi Pui Street
1/5/2015	1/5/2015 09:30	2/5/2015 09:30	Near No. 18 Pun Shan Street	No. 10-20 Pun Shan Street
2/5/2015	2/5/2015 10:30	2/5/2015 15:30	Back of No. 28 Ho Pui Tsuen Kwok Shui Road	No. 1-5 Ho Pui Tsuen
2/5/2015	2/5/2015 20:15	3/5/2015 00:20	Near No. 115 Tsuen Wan Market Street	No. 115 Tsuen Wan Market Street,

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
				No. 117-133 Castle Peak Road
6/5/2015	6/5/2015 09:10	6/5/2015 11:50	No. 52A Sha Tsui Road	No. 12-76 Sha Tsui Road
6/5/2015	6/5/2015 09:30	6/5/2015 15:20	Near No. 19 Heung Shing Street	No. 16-22 Heung Wo Street, No. 19-47 Tai Pa Street
18/5/2015	18/5/2015 15:30	18/5/2015 21:00	Near No. 11 Lung Tak Street	No. 204-248 Texaco Road, and No. 32-56 Wang Lung Street
19/5/2015	19/5/2015 13:50	19/5/2015 23:35	Near No. 38-40 Chai Wan Kok Street	Chai Wan Kok Street
21/5/2015	21/5/2015 08:40	21/5/2015 15:30	Near Lamp Post DC1208 Tsuen Wan Market Street	No.67-129 Tsuen Wan Market Street, Tak Hoi Street, Yan Chai Hospital
21/5/2015	21/5/2015 23:30	22/5/2015 05:00	Near No. 44 Ham Tin Street	City LandMark I
22/5/2015	22/5/2015 11:30	22/5/2015 12:45	Back of No.109 Sam Tung Uk Resite Village	No.109 -116 Sam Tung Uk Resite Village
22/5/2015	22/5/2015 16:30	22/5/2015 17:30	Near No.110 Sam Tung Uk Resite Village	No.109-116 Sam Tung Uk Resite Village
22/5/2015	23/5/2015 00:15	23/5/2015 10:25	Near Lamp Post FC0477 Texaco Road	No.204-220 Texaco Road
27/5/2015	27/5/2015 10:30	27/5/2015 17:15	Near No. 36 Pak Tin Par Street, Tsuen Wan	No. 36-48 Pak Tin Pak Street
1/6/2015	1/6/2015 14:50	2/6/2015 09:00	Near Lamp Post AC1260 Tsuen Kwai Street	Tsuen Kwai Street, Tsuen Wah Street, Tsuen Fu Street,
2/6/2015	2/6/2015 13:30	2/6/2015 21:00	Near Lamp Post W0476 Kwok Shui Road	Safety Godown, Chevrier Cold Storage Building, Sun Fung Centre
4/6/2015	4/6/2015 12:00	7/6/2015 02:00	Near No.168 Kwok Shui Road	Safety Godown, Chevalier Cold Storage Building, Sun Fung Centre, Mita Centre
7/6/2015	7/6/2015 08:30	7/6/2015 15:00	No. 89 Ham Tin Street	No. 69-89 Ham Tin Street & No. 12-28 Luen Yan Street
12/6/2015	12/6/2015 17:15	12/6/2015 22:30	Back of No.15 Lei Shu Road	No. 1-17 Lei Shu Road
14/6/2015	14/6/2015 14:10	14/6/2015 18:00	Back of No.5 Chung Kwai Chung Tsuen	No. 1-6 Chung Kwai Chung Tsuen
15/6/2015	15/6/2015	16/6/2015	Near No. 34 Fui Yui	No. 34 Fui Yui Kok

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
	19:30	09:00	Kok Street	Street, Tsuen Wan
19/6/2015	19/6/2015 14:00	19/6/2015 15:00	Near No. 23 Chung On Street	No. 27-39 Tsuen Wan Market Street, No. 12-36 Shiu Wo Street, No. 13-23 Chung On Street
26/6/2015	26/6/2015 12:00	26/6/2015 20:30	Near No. 228 Yau Ma Hom Tsuen	Part of Yau Ma Hom Tsuen
26/6/2015	26/6/2015 14:40	27/6/2015 09:30	Near Lamp Post AC1303 Shiu Wo Street	No. 10-12 Chung On Street, No. 46 Shiu Wo Street
26/6/2015	26/6/2015 15:30	26/6/2015 20:00	Near No. 107 Sha Tsui Road	No. 1-37 Tso Kung Square No. 105-139 Sha Tsui Road
27/6/2015	27/6/2015 13:10	28/6/2015 09:00	Beside of No. 46 Shui Wo Street	No. 46 Shui Wo Street
1/7/2015	1/7/2015 11:10	1/7/2015 15:30	Near No. 32 Hoi Pui Tsuen	No. 32 Hoi Pui Tsuen
8/7/2015	8/7/2015 18:45	8/7/2015 23:45	Near Lamp Post FC3737 Tsuen Yip Street	Ma Kok Street, Texaco Road, Lung Tak Street, Wang Lung Street
14/7/2015	14/7/2015 15:45	14/7/2015 21:30	Near No. 44 Wang Wo Tsai Street	Wang Wo Tsai Street
16/7/2015	16/7/2015 14:50	17/7/2015 04:00	Near Lamp Post FC3727 Lung Tak Street	Lung Tak Street, No. 142-264 & 231 Texaco Road
23/7/2015	23/7/2015 10:05	23/7/2015 11:45	Near No.100 Kwan Mun Hau Tsuen	No.31-60, 81-104 Kwan Mun Hau Tsuen
25/7/2015	26/7/2015 10:35	27/7/2015 09:00	Near No. 36 Hoi Pa Resite Village	No. Hoi Pa Resite Village
3/8/2015	3/8/2015 14:30	3/8/2015 17:00	Back Lane of No. 87 Sam Tung Uk Resite Village	No. 87-124 Sam Tung Uk Resite Village
8/8/2015	8/8/2015 21:54	10/8/2015 09:00	Near Lamp Post AC3619 Lo Wai Road	Chuen Yiu Terrace & Wing Wah Terrace
11/8/2015	11/8/2015 17:30	12/8/2015 14:00	Near Lamp Post W4144 Hoi Shing Road	TML Tower
12/8/2015	12/8/2015 09:10	13/8/2015 09:30	Near No. 188 Yeung Uk Road	No. 188 Yeung Uk Road
13/8/2015	13/8/2015 09:40	13/8/2015 16:44	Near No.70-72 Hau Tei Square	No.89-77 Tai Ho Road No.32-36, No. 72-79 Hau Tei Square, Tsuen Wan

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
16/8/2015	16/8/2015 10:47	16/8/2015 16:45	No. 204-210 Texaco Road	Driving Centre of Texaco Road
20/8/2015	20/8/2015 11:50	21/8/2015 09:00	Near No.251 Wo Yi Hop Road	No.249-255 Wo Yi Hop Road
22/8/2015	23/8/2015 00:05	24/8/2015 16:30	Near Lamp Post W4171 of Hoi Shing Road	No.1-7 Hoi Shing Road, No.5-19 Chai Wan Kok Street
4/9/2015	4/9/2015 21:00	5/9/2015 22:00	Hoi Kok Street Junction of Hoi Hing Road	Public Toilet near Tsuen Wan West Station
11/9/2015	11/9/2015 13:47	11/9/2015 14:14	Near 14-18 Tso Kung Square	Heung Che Street Market, No. 2-30 (even no.) Tso Kung Square, No. 2-32 (even no.) Hoi Pa Street
12/9/2015	12/9/2015 13:24	12/9/2015 20:43	Near Lamp Post W3679 Sai Lau Kok Road	Part of Sai Lau Kok Road, Cheong Lok Mansion, Nam Fung Center
15/9/2015	15/9/2015 22:05	16/9/2015 03:01	Near Lamp Post FA5867 Shek Wai Kok Road	Shek Wai Kok Estate
15/9/2015	15/9/2015 23:45	16/9/2015 09:30	Near Lamp Post W1957, Kwu Uk Lane	Sam Tung Uk Museum, Tsuen Wan MTR Station
16/9/2015	16/9/2015 14:48	16/9/2015 17:15	Near Lam Post No. FB9305 Sai Lau Kok Road	No. 1-17 Sai Lau Kok Road
22/9/2015	22/9/2015 10:35	22/9/2015 15:00	Near No. 220 Yau Ma Hom Resite Village	No. 168, 170, 218-220, 222-225 of Yau Ma Hom Resite Village
23/9/2015	23/9/2015 08:50	24/9/2015 09:30	Near No. 68 Sha Tsui Road	No. 26-76 Sha Tsui Road
23/9/2015	23/9/2015 15:45	24/9/2015 06:00	Near 9 Shing Mun Road	New Territories South Regional Police Headquarters, Si Yuan School, Hk Exam & Assessment Authority & Part of Shing Mun Road
25/9/2015	25/9/2015 13:05	26/9/2015 01:30	Kwok Shui Road Park Near Texaco Road Flyover	2, 6-8 Shing Mun Road, Waldorf Centre, Tai Wo Hau Station, Kwok Shui Road Park, 682-704 Castle Peak Road, Part of Kwok Shui Road
26/9/2015	26/9/2015 14:40	26/9/2015 18:45	Near Lamp Post FC4363 Shiu Wo Street	No. 185-213 Castle Peak Road, No.1-11 Chung On

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
				Street, No. 23-37 Shiu Wo Street
26/9/2015	27/9/2015 03:00	27/9/2015 10:20	Near Tai Chung Road Sha Tsui Road	No. 1-70 Sha Tsui Road
29/9/2015	29/9/2015 18:00	30/9/2015 10:25	Near No. 66A Sha Tsui Road	No. 8-76 Sha Tsui Road
30/9/2015	30/9/2015 11:05	30/9/2015 12:00	Near No. 224 Yau Ma Hom Resite Village	No. 168, 170, 218-224 Yau Ma Hom Resite Village
3/10/2015	3/10/2015 14:00	3/10/2015 15:35	No. 271 Back Lane of Wo Yi Hop Road	No. 225-271 Wo Yi Hop Road
12/10/2015	12/10/2015 16:35	12/10/2015 20:45	Near No.32 Ho Pui Tsuen	Part of Ho Pui Tsuen, Kwan Mun Hau Tsuen & Yeung Uk San Tsuen
16/10/2015	16/10/2015 09:35	17/10/2015 23:05	Near Fire Hydrant 3104 Tai Ho Road	Refuse Collection Point of Hoi Kwai Road
17/10/2015	17/10/2015 16:00	17/10/2015 20:00	No. 125 Chuen Lung Street	Part of Hoi Pui Street
19/10/2015	19/10/2015 16:00	19/10/2015 21:00	Back Lane of No. 18 Tai Pei Square	No. 31-85 Chuen Lung Street, No.2-24 Tai Pei Square, No. 122 Hoi Pa Street
22/10/2015	22/10/2015 09:33	22/10/2015 16:33	Near No.48A Ho Pui Tsuen	Ho Pui Tsuen, Kwan Mui Hau Tsuen, Ho Pa San Tsuen
22/10/2015	22/10/2015 18:55	23/10/2015 09:11	Near No.95 Chai Wan Kok Street	Chai Wan Kok Street
23/10/2015	23/10/2015 09:55	23/10/2015 14:38	Near 84 Hoi Pa Shan Tsuen	59-87 Hoi Pa Shan Tsuen
23/10/2015	23/10/2015 17:00	23/10/2015 18:30	Near Lamp Post GC 0038, Hoi Pa Street	No.2-32 Hoi Pa Street.No.2-36 Tso Kung Square.
26/10/2015	26/10/2015 11:50	26/10/2015 14:20	Near No.58 Ho Pui Tsuen	Part of Ho Pui Tsuen and Hoi Pa San Tsuen
26/10/2015	27/10/2015 11:00	27/10/2015 12:20	Near No.37 Tak Wah Street	Tsuen Wan Catholic Primary School
28/10/2015	28/10/2015 09:50	28/10/2015 16:51	Near No.87 Hoi Pa San Tsuen	Ho Pui Tsuen, Hoi Pa San Tsuen
4/11/2015	4/11/2015 09:00	4/11/2015 23:00	Near Lamp Post PA5167, Wing Shun Street	Shak Chung Shan Memorial Catholic Primary School,& Waterside Plaza
6/11/2015	6/11/2015 15:22	7/11/2015 00:30	Underneath Texaco Rd Flyover, near Kwok	Shing Mun Road, Wai Tsuen Road, No.130-142

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
			Shui Road Park	& No.682-704 Castle Peak Road, Kwok Shui Road, Fu UK Road, Shek Wai Kok Road, Sai Lau Kok Road.
9/11/2015	9/11/2015 10:30	9/11/2015 11:15	Near Lamp Post AC1446 Tsuen King Circuit	Sheeny Terrace
11/11/2015	11/11/2015 16:26	11/11/2015 22:46	Near No.113 Chuen Lung Street	No.118 Chuen Lung Street,34-58 Sun Chin Street,33-37 Ho Pui Street, 23-33 Wo Tik Street
13/11/2015	13/11/2015 18:50	13/11/2015 22:30	Near No.22 Pun Shan Street	No.22 Pun Shan Street
21/11/2015	21/11/2015 15:00	22/11/2015 09:30	Near No.301-305 Wo Yi Hop Road	No.301-305 Wo Yi Hop Road
29/11/2015	29/11/2015 09:50	30/11/2015 00:00	Near Lamp Post FB5103 Tsuen King Circuit,Tsuen Wan	No.23-27 Tsuen King Circuit, Tsuen King Garden.
29/11/2015	29/11/2015 14:40	29/11/2015 19:02	Near No. 52 Chung Kwai Chung Tsuen	No. 37-52 Chung Kwai Chung Tsuen
1/12/2015	1/12/2015 14:30	1/12/2015 16:45	No.289 Sha Tsui Road	No.9-17 Sze Pei Square and No.44-50 Ham Tin Street and No.269-289 Sha Tsui Road
2/12/2015	2/12/2015 16:03	2/12/2015 18:41	Near Lamp Post FA5235 Wing Shun Street	Shek Chung Shan Memorial Catholic Primary School, Waterside Plaza, No.19-31 Ma Tau Pa Road
10/12/2015	10/12/2015 13:45	10/12/2015 15:15	Back Lane of No.32 Heung Shing Street	No.9-17 Fu Yung Street, No.16-32 Heung Shing Street
14/12/2015	14/12/2015 09:00	14/12/2015 19:00	Near Lamp Post FA4652 Ma Kok Lane	No.32-40 Wang Lung Street
16/12/2015	16/12/2015 17:50	16/12/2015 20:50	Back of No.2-24 Tai Pei Square	No.2-24 Tai Pei Square. No.35-85 Chuen Lung Street
18/12/2015	18/12/2015 15:10	19/12/2015 00:30	Near Fire Hydrant 2334, Tsuen King Circuit	Joyful Building, Tsuen Tak Garden, Kam Fung Garden, Woo Hon Fai Secondary School,

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
				Church of the Annunciation
19/12/2015	19/12/2015 05:25	19/12/2015 19:00	Near Lamp Post W4126 Hoi Shing Road	Along Hoi Shing Road and Tai Pa Street
19/12/2015	19/12/2015 10:30	19/12/2015 17:30	Near Lamp Post W0065 of Tsuen King Circuit	Tsuen King Garden Phase 2
19/12/2015	19/12/2015 10:35	20/12/2015 01:46	19-21 Tai Ho Road	No. 7-21 Tai Ho Road, Tsuen Wan District of Junior Police Call Club House
19/12/2015	19/12/2015 12:00	19/12/2015 19:30	Near No.620 Castle Peak Road	Belvedere Square Two, Bayview Garden, Long Beach Gardens, Golden Village, The Bag Bridge
19/12/2015	19/12/2015 14:58	20/12/2015 12:16	Carriageway Opposite MTR Depot Kwu Uk Lane	No.101-137 Sai Lau Kok Road.
19/12/2015	19/12/2015 18:12	20/12/2015 00:35	No.5-21 Pak Tin Par Street	No.5-21 Pak Tin Par Street
20/12/2015	20/12/2015 08:30	20/12/2015 17:15	Near Lamp Post FB4930 Hoi Pa Village South Terrace	Hoi Pa Village South Terrace
22/12/2015	22/12/2015 10:48	23/12/2015 04:32	Near Lamp Post W4935 Sai Lau Kok Road	Sai Lau Kok Road, No. 90-350 Castle Peak Road
22/12/2015	22/12/2015 14:35	22/12/2015 23:00	Near Lamp Post FA5845 Wai Tsuen Road	Ma Sim Pai Road, Wai Tsuen Road, Luk Yeung Sun Chuen, Fairview Garden.
24/12/2015	24/12/2015 14:00	24/12/2015 16:00	Near Lamp Post FB7572 Wang Lung Street	Ma Kok Lane, Texaco Road, Wang Lung Street, Fui Yiu Kok Street
2/1/2016	2/1/2016 12:00	3/1/2016 09:00	Near No.28 Wang Wo Tsai Street	No.28 Wang Wo Tsai Street
3/1/2016	3/1/2016 11:40	3/1/2016 16:30	Near No.18 Ma Kok Street, Tsuen Wan.	No.18 Ma Kok Street
11/1/2016	11/1/2016 13:30	11/1/2016 14:30	Near 95 Chung On Street	Ho Pui Street, Chung On Street, Yi Pei Square, Chuen Lung Street
11/1/2016	11/1/2016 14:25	11/1/2016 15:45	83 Hoi Pa Street Back Lane	No.77-93 Hoi Pa Street & No.2-6 Lo Tak Court
11/1/2016	11/1/2016 22:25	12/1/2016 06:40	Near Lamp Post AC1982 Castle Peak Road	Belvedere Square Two, Bayview Garden, Long Beach Garden Villa, The Bay Bridge

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
13/1/2016	13/1/2016 16:30	14/1/2016 09:00	No.46 Back Lane of Hau Tei Square	No.40-46 Hau Tei Square
23/1/2016	23/1/2016 16:59	23/1/2016 20:20	Near Lamp Post W2666 Hoi Pa Street	Lo Tak Court, Hoi Pa Street Government Primary School
25/1/2016	25/1/2016 13:30	25/1/2016 22:00	Back of No.29 Ham Tin Tsuen	No.1-30 Ham Tin Tsuen.
26/1/2016	26/1/2016 09:45	26/1/2016 15:00	Near No.9-31 Tai Pei Square Back Lane	No.9-31 Tai Pei Square, No.25-51 Chung On Street
27/1/2016	27/1/2016 06:40	28/1/2016 14:10	Near Lamp Post FA5185 Yi Lok Street	Riviera Gardens
28/1/2016	28/1/2016 19:00	28/1/2016 20:15	Back Lane of No.9 Tso Kung Square	No.1-37 Tso Kung Square, No.105-139 Sha Tsui Road, No.28-30 Tso Kung Street
28/1/2016	29/1/2016 00:30	30/1/2016 16:15	Near Lamp Post W0585 Kwok Shui Road	Kwok Shui Road
4/2/2016	4/2/2016 09:55	4/2/2016 21:30	Near No.50 Wang Wo Tsai Street	Wang Wo Tsai Street and No.100 Texaco Road
7/2/2016	7/2/2016 09:50	8/2/2016 04:50	Near No.23-27 Tsuen King Circuit	No. 23-27 Tsuen King Circuit, Waylee Industrial Centre, Tsuen King Garden
11/2/2016	11/2/2016 16:30	11/2/2016 19:00	Near Lamp Post AC1986 Tsuen Wan Market Street, Tsuen Wan	No.115-119 Tsuen Wan Market Street & Yan Chai Hospital
12/2/2016	12/2/2016 14:50	13/2/2016 09:00	Near No.115 Tsuen Wan Market Street	No.115-119 Tsuen Wan Market Street
24/2/2016	24/2/2016 16:05	24/2/2016 17:15	Near No.10-20 Pun Shan Street	No.10-20 Pun Shan Street
24/2/2016	25/2/2016 01:50	25/2/2016 09:45	Near Lamp Post FA5842 Wai Tsuen Road	Fairview Garden, Tsuen Wan Ambulance Depot, Luk Yeung Sun Chuen, Hoi Pa Village South Terrace, Muk Min Ha Tsuen
25/2/2016	25/2/2016 14:25	26/2/2016 00:30	Near Lamp Post FA4651 Ma Kok Lane	Ma Kok Lane
29/2/2016	29/2/2016 11:00	29/2/2016 18:30	No.5-9 Chai Wan Kok Street	No.5-15 Chai Wan Kok Street
1/3/2016	1/3/2016 10:00	1/3/2016 10:35	Near No.60 Ho Pui Tsuen	No.56-71 Hoi Pui Tsuen

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
2/3/2016	2/3/2016 15:45	2/3/2016 16:35	Near No.43-45 Chung On Street Back Lane	No.25-49 Chung On Street, No.134-150 Hoi Pa Street, No.9-31 Tai Pei Square
2/3/2016	2/3/2016 19:40	3/3/2016 15:00	Near 25-31 Tsuen Hing Path	Lo Tak Court
4/3/2016	4/3/2016 16:30	4/3/2016 21:30	Near No. 7 Hoi Pa Tsuen	No. 1-9, Hoi Pa Tsuen
10/3/2016	10/3/2016 16:10	10/3/2016 18:20	Near Lamp Post W2104 Tsuen King Circuit	Tsuen King Circuit Recreation Ground and Rest Garden
10/3/2016	10/3/2016 23:05	11/3/2016 11:00	Near Lamp Post FC0550 , Tai Ho Road	Sha Tsui Road Playground & Princess Alexandra Community Centre
11/3/2016	12/3/2016 00:30	12/3/2016 03:50	Near Lamp Post FA4655 Ma Kok Lane	No.204-248 Texaco Road.
21/3/2016	21/3/2016 06:40	21/3/2016 10:45	Near Lamp Post V7675, Hoi Pa Street	Holy Cross Lutheran School
22/3/2016	22/3/2016 16:30	22/3/2016 18:45	Near No.301 Wo Yi Hop Road Back Lane	No.301 Wo Yi Hop Road
30/3/2016	30/3/2016 05:08	30/3/2016 15:24	Near Lamp Post FC2618 Castle Peak Road	Yau Lai Road, Bayview Garden, Belvedere Garden, Lai Shun Road, Fat Yip Lane and Wang Fat Ching She
31/3/2016	31/3/2016 16:50	1/4/2016 09:00	Near No.261 Wo Yi Hop Road	No.225-271 Wo Yi Hop Road
1/4/2016	2/4/2016 00:25	2/4/2016 06:30	No.52A Sha Tsui Road	No.26-76 Sha Tsui Road
5/4/2016	5/4/2016 13:50	5/4/2016 15:40	Near No.23 Tsuen Hing Path	Lo Tak Court and Tsuen Hing Path
9/4/2016	9/4/2016 12:00	9/4/2016 15:30	No.22 On Yat Street	Block F-R of Allway Gardens, Tsuen King Circuit Wo Chung Swimming Pool
11/4/2016	11/4/2016 10:05	11/4/2016 19:12	Near No.103, Kwan Mun Hau Tsuen	No.103 Kwan Mun Hau Tsuen
16/4/2016	16/4/2016 14:52	16/4/2016 22:40	Near No.220-248 Texaco Road	Waterside Plaza, Part of Wing Tak Street
17/4/2016	17/4/2016 09:58	17/4/2016 15:40	Near No.66-82 Chai Wan Kok Street	Chai Wan Kok Street, Part of Pan Shan Street
18/4/2016	18/4/2016	18/4/2016	Near No.19-21 Tai Ho	Part of Tai Ho Road

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
	15:15	17:24	Road	
18/4/2016	18/4/2016 17:20	18/4/2016 19:20	Near FC3731 Tsuen Yip Street	No.2-18 Ma Kok Street, No.72-84 Wang Lung Street, No.168-202 Texaco Road, Tsuen Yip Street
21/4/2016	21/4/2016 09:40	22/4/2016 04:00	Near No.30 Tsuen King Circuit	Waylee Industrial Centre
28/4/2016	28/4/2016 08:50	28/4/2016 19:00	Near No.40-50 Sha Tsui Road	No.16-76 Sha Tsui Road
30/4/2016	30/4/2016 16:00	30/4/2016 22:30	Near No.36 Chai Wan Kok Street	Chai Wan Kok Street
1/5/2016	1/5/2016 15:00	1/5/2016 18:00	Near No.59 Wang Lung Street	Part of Wang Lung Street
6/5/2016	6/5/2016 15:50	7/5/2016 09:00	Near No.47 Chai Wan Kok Street	No.47 Chai Wan Kok Street
8/5/2016	8/5/2016 16:30	8/5/2016 18:45	No.99 Back Lane of Yeung Uk Road	No.70-84 Ho Pui Street, No.85-99 Yeung Uk Road
14/5/2016	14/5/2016 17:30	15/5/2016 00:40	Near No.47-51 Wai Tsuen Road	Muk Min Ha Tsuen, Hoi Pa Village South Terrace, Tsuen Wan Ambulance Depot, Fairview Garden, Part of Luk Yeung Sun Tsuen.
18/5/2016	18/5/2016 17:15	18/5/2016 22:15	Near No.21 Pak Tin Par Street	No.5-39 and No.2-28 Pak Tin Par Street
19/5/2016	19/5/2016 16:50	19/5/2016 22:50	Near No.27 Mei Wan Street	No.1-37 of Mei Wan Street
20/5/2016	20/5/2016 11:25	20/5/2016 16:40	Near No.19 Hoi Pa Village South Terrace	No.19 Hoi Pa Village South Terrace
24/5/2016	24/5/2016 11:00	24/5/2016 23:15	Near Lamp Post W1531, Kwok Shui Road	Shing Mun Valley Swimming Pool, Shek Wai Kok Estate
25/5/2016	25/5/2016 01:25	26/5/2016 23:15	Near Lamp Post W0620 Texaco Road North	Shek Wai Kok Estate
25/5/2016	25/5/2016 14:30	25/5/2016 17:00	Near No.4 Hoi Pa Village South Terrace	Hoi Pa Village South Terrace
27/5/2016	27/5/2016 11:48	27/5/2016 15:54	Near No.28-30 Tso Kung Street	No.1-37 Tso Kung Square, No.105-139 Sha Tsui Road.
29/5/2016	29/5/2016 14:20	29/5/2016 21:30	Back Lane of No.25 Wo Tik Street	No.23-33 Wo Tik Street, No.33-37 Ho Pui Street, No.34-58 San Tsuen Street

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
31/5/2016	31/5/2016 17:00	1/6/2016 09:00	Near No.15 Fu Yung Street	No.9-17 Fu Yung Street, No.16-32 Heung Shing Street
1/6/2016	1/6/2016 17:05	2/6/2016 09:00	Near Lamp Post W3295 Chai Wan Kok Street	Part of Chai Wan Kok Street
3/6/2016	3/6/2016 11:40	3/6/2016 16:40	Near Lamp Post W3295 Chai Wan Kok Street	Chai Wan Kok Street Public Toilet
3/6/2016	3/6/2016 16:55	3/6/2016 23:50	Near No.40-50 Sha Tsui Road	No.26-76 Sha Tsui Road
4/6/2016	4/6/2016 13:52	4/6/2016 18:00	Near Lamp Post FC0600 Chai Wan Kok Street	Chai Wan Kok Public Toilet
4/6/2016	4/6/2016 16:49	5/6/2016 02:00	Near 84-92 Chai Wan Kok Street	Chai Wan Kok Street
11/6/2016	11/6/2016 18:30	12/6/2016 06:15	Near Lamp Post BC0315 Tsuen King Circuit	No.30-34 Tsuen King Circuit
15/6/2016	15/6/2016 14:30	15/6/2016 16:25	Near No.111 Hoi Pa Street Back Lane	No.105-117 Hoi Pa Street, No.22-30 Chuen Lung Street.
16/6/2016	16/6/2016 16:20	18/6/2016 15:00	Near Lam Post No. DC1786 Yeung UK Road	Tsuen Wan and Kwai Chung
17/6/2016	17/6/2016 10:30	18/6/2016 09:00	Back of No.208 Castle Peak Road, Tsuen Wan	Tsuen Wan Multi-storey Carpark Building
19/6/2016	19/6/2016 07:35	20/6/2016 17:15	Near Lamp Post W3680 Sai Lau Kok Road	No.1-37 Mei Wan Street, Tsuen Kam Center. No.38-100 Sai Lau Kok Road, Tsuen Wan Station
20/6/2016	20/6/2016 16:00	20/6/2016 22:30	Near Lamp Post W2535 Sai Lau Kok Road	Tsuen Wan Multi-storey Carpark Building
24/6/2016	24/6/2016 10:35	24/6/2016 15:15	Near Lamp Post FB3018 Sha Tsui Road	No.381-389 Sha Tsui Road
24/6/2016	24/6/2016 14:30	25/6/2016 09:00	Near No.16 Pun Shan Street	No.10-16 Pun Shan Street
25/6/2016	25/6/2016 20:15	26/6/2016 03:00	Near No.123 Chuen Lung Street	Part of Ho Pui Street
29/6/2016	29/6/2016 08:15	29/6/2016 16:10	Near No.31 Ma Tau Pa Road	No.19-31 Ma Tau Pa Road
30/6/2016	30/6/2016 17:45	1/7/2016 09:00	Near No.44 Hau Tei Square	No.40-46 Hau Tei Square
2/7/2016	2/7/2016 06:14	2/7/2016 13:56	Near Lamp Post FA4655, Ma Kok Lane	No.204-248 Texaco Road, No.32-56 Wang

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
				Lung Street
4/7/2016	4/7/2016 14:50	4/7/2016 15:10	Near Former Kwai Chung Public School, Kwok Shui Road	Former Kwai Chung Public School
5/7/2016	5/7/2016 12:00	5/7/2016 14:30	Near No.3-5 On Wing Street	No.3-11 On Wing Street.
8/7/2016	8/7/2016 13:30	8/7/2016 16:50	Near No.117-121 Tsuen Wan Market Street	No.67-119 Tsuen Wan Market Street, Yan Chai Hospital, No.2-24 Chung On Street, No.46-51 Sin Wo Street
12/7/2016	12/7/2016 13:48	12/7/2016 14:43	Near No.41-47 Pak Tin Par Street	No.41-47 Pak Tin Par Street
12/7/2016	12/7/2016 16:00	13/7/2016 09:00	Near No.13 Ham Tin Tsuen	No.12-29 Ham Tin Tsuen
15/7/2016	15/7/2016 18:00	16/7/2016 09:00	Near No.325 Wo Yi Hop Road	No.273-335 Wo Yi Hop Road
16/7/2016	16/7/2016 10:15	16/7/2016 16:35	Near No.59 Chai Wan Kok Street	No.59-63 Chai Wan Kok Street
16/7/2016	16/7/2016 16:45	16/7/2016 21:40	Near 43 Sha Tsui Road	No.1-76 Sha Tsui Road, Pak Tin Par Street, Pun Shan Street, Part of Chai Wan Kok Street
22/7/2016	22/7/2016 09:15	22/7/2016 16:50	Near Hoi Hing Road, Tsuen Wan Salt Water Pumping Station	Tsuen Wan Salt Water Pumping Station
28/7/2016	28/7/2016 16:48	28/7/2016 18:15	Near Lamp Post BC1475 Wo Yi Hop Road	No. 225-271 Wo Yi Hop Road
29/7/2016	29/7/2016 15:05	30/7/2016 08:50	Near No.273 Wo Yi Hop Road	Part of Wo Yi Hop Road
30/7/2016	30/7/2016 15:35	30/7/2016 18:30	Near 68 Hau Tei Square	Iau Kin Building, Po Shing Mansion, Foo Wah House, Iau Keung Building
5/8/2016	5/8/2016 18:00	5/8/2016 21:15	Back Lane of No.38 Hau Tei Square	No.24-72 Hau Tei Square
6/8/2016	6/8/2016 17:00	6/8/2016 23:25	Back of No.32 Yi Pei Square	Part of Chuen Lung Street and Ho Pui Street
7/8/2016	7/8/2016 16:25	7/8/2016 21:40	Near No.2 Shing Mun Road	Si Yuan School of the Precious Blood, Hong Kong Examinations and Assessment Authority

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
13/8/2016	13/8/2016 14:00	13/8/2016 16:20	No.7 Tsuen Hing Path	Part of Hoi Pa Street, Tsuen Hing Path, On Wing Street, Lo Tak Court
13/8/2016	13/8/2016 16:00	14/8/2016 09:30	Junction of Sai Lau Kok Road and Mei Wan Street	No.1-38 Sai Lau Kok Road, No.1-37 Mei Wan Street, Tsuen Kam Center, Cheong Lok Mansion, Nan Fung Center, Tsuen Wan Station
23/8/2016	23/8/2016 18:59	24/8/2016 04:00	Near Lamp Post CC1112 Wing Tak Street Junction with Texaco Road	City Point
25/8/2016	25/8/2016 16:40	25/8/2016 19:20	Near No.34-36 Chai Wan Kok Street	Chai Wan Kok Street
8/9/2016	8/9/2016 17:15	9/9/2016 00:15	Near No.34 San Tsuen Street	No.34-38 Tsuen Street, No.22-33 Wo Tik Street, No.33-35 Ho Pui Street
10/9/2016	10/9/2016 14:30	11/9/2016 04:30	Near Lamp Post FB5823 Sai Lau Kok Road	Part of Sai Lau Kok Road, Nan Fung Centre
12/9/2016	12/9/2016 14:55	12/9/2016 17:45	Near No.199 Tsuen King Circuit	Tsuen Wan Adventist Hospital, Allway Gardens Block A-E
13/9/2016	13/9/2016 10:20	13/9/2016 16:30	Near 2-8 Tsuen Hing Path	No.30-38 Tai Ho Road
14/9/2016	14/9/2016 09:40	14/9/2016 13:40	Near No.106-114 Kwok Shui Road	No.88-140 Kwok Shui Road, Tsuen Wan
17/9/2016	17/9/2016 14:59	18/9/2016 08:00	Near 166 Sha Tsui Road	112-188 Sha Tsui Road, 9-63 Heung Wo Street
17/9/2016	17/9/2016 22:15	18/9/2016 01:12	Near Lamp Post FB7581 Wang Lung Street	Wang Lung Street, Ma Kok Street and No.168 Yeung UK Road
19/9/2016	19/9/2016 15:15	21/9/2016 09:00	Back Lane of No.105 Sha Tsui Road	No.105-139 Sha Tsui Road, No.1-37 Tso Kung Square
19/9/2016	19/9/2016 15:15	20/9/2016 09:00	Near 31 Muk Min Ha Tsuen	No.31 Muk Min Ha Tsuen
21/9/2016	21/9/2016 10:50	21/9/2016 13:25	Near Back Lane of No.9 Hoi Pai Resite Village, Yi Pei Chun Road.	No.1-9 Hoi Pai Resite Village
23/9/2016	23/9/2016	23/9/2016	Near No.37 Tso Kung	No.100-130 Sha Tsui

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
	10:45	17:10	Square	Road, Tso Kung Square
23/9/2016	23/9/2016 22:00	25/9/2016 03:50	Near No.289 Sha Tsui Road	Sze Pei Square, No.271-289 Sha Tsui Road
27/9/2016	27/9/2016 13:45	28/9/2016 09:00	Back of No.45 Ho Pui Tsuen, Kwok Shui Road	No.1-48 Ho Pui Tsuen
3/10/2016	3/10/2016 16:55	4/10/2016 09:00	Back Lane of No.31 Wo Tik Street	No.22-33 Wo Tik Street, No.34-58 San Tsuen Street, No.118 Chuen Lung Street, No.33-37 Ho Pui Street
5/10/2016	5/10/2016 11:10	5/10/2016 13:00	Near Lamp Post W2108 Tsuen King Circuit	No.86-92 Tsuen King Circuit
7/10/2016	7/10/2016 13:35	7/10/2016 16:15	Near No.83-85 Chuen Lung Street, Tsuen Wan.	No. 31-89 Chuen Lung Street
10/10/2016	10/10/2016 23:00	11/10/2016 14:56	Near I Yeung UK Road	Tsuen Wan and Kwai Chung weak in SW Supply Pressure
12/10/2016	12/10/2016 18:00	12/10/2016 22:30	Back Lane of No.144 Sha Tsui Road	No.112-188 Sha Tsui Road, No.1-9 Heung Shing Street, No.9-63 Heung Wo Street, No.67-73 Yuen Tun Circuit
13/10/2016	13/10/2016 20:40	14/10/2016 00:30	Near No.30-38 Tsuen King Circuit	No.23-81 Tsuen King Circuit
15/10/2016	15/10/2016 08:37	15/10/2016 14:40	Near 95 Chuen Lung Street	93-127 Chuen Lung Street, 2-32 Yi Pei Square
16/10/2016	16/10/2016 10:10	16/10/2016 12:15	Back of No.120 Sha Tsui Road	No.112-188 Sha Ysui Road and No.9-73 Heung Wo Street
17/10/2016	17/10/2016 15:10	18/10/2016 14:00	Near No.30-38 Tsuen King Circuit	No.30-38 Tsuen King Circuit
20/10/2016	20/10/2016 09:10	20/10/2016 16:00	Near No.202-216 Sai Lau Kok Road	No.170-216 Sai Lau Kok Road
20/10/2016	20/10/2016 15:10	20/10/2016 18:50	Near No.50 Wang Wo Tsai Street	No.100 Texaco Road
23/10/2016	23/10/2016 12:10	23/10/2016 16:45	Near No.72 Hoi Pa Resite Village	Hoi Pa Resite Village
24/10/2016	24/10/2016 10:15	24/10/2016 14:15	Near No.1 Ho Pui Tsuen, Kok Shui Road	Part of Kwan Mun Hau Tsuen, Yeung UK Tsuen, Ho Pui Tsuen
24/10/2016	24/10/2016 16:50	24/10/2016 19:30	Back Lane of No.1 Yeung UK Tsuen	No.1-13 Yeung UK Tsuen

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
26/10/2016	26/10/2016 21:00	27/10/2016 06:00	Near Lamp Post FC3737 Tsuen Yip Street	No.14-18 Ma Kok Street
26/10/2016	26/10/2016 21:30	27/10/2016 06:30	Near No.37 Ho Pui Street	Ho Pui Street, Wo Tik Street, San Tsuen Street
8/11/2016	10/11/2016 11:33	10/11/2016 19:54	Near Lamp Post AC5902 Hoi Kwai Road	Tsuen Wan & Kwai Chung Weak in Pressure Road
10/11/2016	10/11/2016 18:30	11/11/2016 09:00	Near Lamp Post FC0482 Texaco Road	Tsuen Wan Driving Test Centre
11/11/2016	11/11/2016 09:25	11/11/2016 15:00	Near Fire Hydrant 166 Texaco Road	Tsuen Wan Driving Test Centre.
21/11/2016	21/11/2016 15:35	21/11/2016 18:00	Near No.2-4 Chai Wan Kok Street	Chai Wan Kok Street Toilet
22/11/2016	22/11/2016 19:05	23/11/2016 15:05	Near No.66 Sha Tsui Road	No.26-76 Sha Tsui Road
24/11/2016	24/11/2016 15:40	24/11/2016 21:15	Near No.603-609 Castle Peak Road	No.603-609 Castle Peak Road
25/11/2016	25/11/2016 19:40	26/11/2016 00:30	Near No.83-93 Chai Wan Kok Street	No.83-93 Chai Wan Kok Street
25/11/2016	25/11/2016 22:00	26/11/2016 04:40	Near No.52 Sha Tsui Road	No.26-76 Sha Tsui Road
26/11/2016	26/11/2016 01:30	26/11/2016 21:00	Near No.23 Shiu Wo Street	No.17-37 Shiu Wo Street, No.181-123 Castle Peak Road, No.1-11 Chung On Street
29/11/2016	29/11/2016 01:35	30/11/2016 05:08	Near Lamp Post W4936 Sai Lau Kok Road	Tsuen Wan MTR Station, Nan Fung Centre and Cheong Lok Mansion
6/12/2016	6/12/2016 09:55	6/12/2016 16:00	Near No.88 Kwok Shui Road	No.88 Kwok Shui Road.
8/12/2016	8/12/2016 01:30	8/12/2016 15:00	Near No.2 Kwu UK Lane	No.139-216 Sai Lau Kok Road, Wai Tsuen Road, Muk Min Ha Tsuen, Hoi Pa Village South Terrace
8/12/2016	8/12/2016 18:10	9/12/2016 09:00	Near No.46 Shiu Wo Street	No.46 Shiu Wo Street
9/12/2016	9/12/2016 15:29	9/12/2016 21:53	Near Lamp Post FB3018 Sha Tsui Road	No. 381-389 Sha Tsui Road
10/12/2016	10/12/2016 13:00	10/12/2016 16:30	Near Lamp Post 1978 Wo Tik Street	Wo Tik Street and Ho Pui Street
11/12/2016	11/12/2016 22:45	12/12/2016 14:00	Near Lamp Post FC3243 Pun Shan Street	No-22 Pun Shan Street

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
12/12/2016	12/12/2016 15:45	13/12/2016 09:00	Near No.65-69 Chai Wan Kok Street	No.65-69 Chai Wan Kok Street
17/12/2016	17/12/2016 11:00	17/12/2016 17:30	Near No.48 Pak Tin Par Street	No.23-63 Pak Tin Par Street
20/12/2016	20/12/2016 17:30	20/12/2016 19:10	Near No.28 Par Tin Par Street	No.2-32 and No.1-31 Pak Tin Par Street
24/12/2016	24/12/2016 09:40	24/12/2016 14:30	Near Lamp Post FB2838 Ting Kwok Street	Yeung Uk Tsuen
28/12/2016	28/12/2016 09:20	28/12/2016 17:00	Near No.117 Sam Tung Uk Resite Village	Part of Hoi Pa Village, Sam Tung Uk Resite Village
30/12/2016	30/12/2016 19:50	31/12/2016 10:00	Near No.10 Tso Kung Square	No.6-10 Tso Kung Square
1/1/2017	1/1/2017 11:15	2/1/2017 10:00	Near Lamp Post FA1788 Ho Pui Street	No.89 Ham Tin Street
2/1/2017	2/1/2017 15:00	5/1/2017 02:00	Near No.12-28 Tsuen Fu Street, Tsuen Wan.	Tsuen Kwai Street, Tsuen Fu Street.
6/1/2017	6/1/2017 09:40	6/1/2017 23:30	Near Lamp Post DC1208 Tsuen Wan Market Street	No.2-24 Chung On Street, No.67-95 Tsuen Wan Market Street
7/1/2017	7/1/2017 15:20	8/1/2017 09:28	Near 21 Ho Pui Tsuen	No.1-48 Ho Pui Tsuen
13/1/2017	13/1/2017 13:15	14/1/2017 02:30	Near Lamp Post FC0550 Tai Ho Road	Sha Tsui Road Playground & Princess Alexandra Community Centre
16/1/2017	16/1/2017 10:50	16/1/2017 11:35	Near No.119 Sam Tung UK Resite Village	No.119 Sam Tung UK Resite Village
16/1/2017	16/1/2017 12:00	16/1/2017 13:05	Near Lamp Post DC1203 Tsuen Wan Market Street	Jockey Club Tak Wah Park
18/1/2017	18/1/2017 20:00	19/1/2017 14:23	Near 7 Shing Mun Road	Shing Mun Road
21/1/2017	21/1/2017 16:30	21/1/2017 21:30	Near 121 Tsuen Wan Market Street	No.115-133 Castle Peak Road
23/1/2017	23/1/2017 00:45	23/1/2017 14:08	Near Lamp Post W1957 Kwu UK Lane	MTR Tsuen Wan Depot, Luk Yeung Sun Chuen (00:30-09:30 only)
23/1/2017	23/1/2017 16:20	24/1/2017 09:00	Near No.619 Castle Peak Road	No.611-619 Castle Peak Road
1/2/2017	1/2/2017 11:00	1/2/2017 16:00	Near No.22 Ho Pui Tsuen	No.1-48 Ho Pui Tsuen

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
3/2/2017	3/2/2017 13:45	3/2/2017 14:50	Near Lamp Post W1521 Kwok Shui Road	Kwok Shui Road Park
3/2/2017	3/2/2017 16:00	4/2/2017 09:15	Near Back lane No.12 Fu Yung Street	No.9-17 Fu Yung Street, No.16-32 Heung Shing Street
4/2/2017	4/2/2017 08:30	5/2/2017 09:30	Near No.83-93 Chai Wan Kok Street	Chai Wan Kok Street
6/2/2017	6/2/2017 17:30	6/2/2017 19:15	Back of No.62 Tak Wah Street	No.62-70 Tak Wah Street
8/2/2017	8/2/2017 14:00	8/2/2017 20:45	Near Lamp Pos No.W1957 Kwu Uk Lane	Sam Tung Uk Garden, Tsuen Wan MTR Depot
12/2/2017	12/2/2017 07:50	12/2/2017 15:50	Near No.90 Tsuen King Circuit	Tsuen Wan Centre Stage 2
14/2/2017	14/2/2017 07:55	16/2/2017 04:45	Near Lamp Post W3679 Sai Lau Kok Road	Tsuen Wan Station, Nan Fung Centre, Cheong Lok Mansion
18/2/2017	18/2/2017 10:25	18/2/2017 17:30	Back Lane of No.28 Tak Wah Street	No.2-34 Tak Wah Street, No.297-335 Sha Tsui Road
20/2/2017	20/2/2017 18:30	21/2/2017 05:30	Near Lamp Post No.W3679 Sai Lau Kok Road	No.100-120 Sai Lau Kok Road and Tsuen Wan Station.
23/2/2017	23/2/2017 02:10	23/2/2017 16:25	Near Lamp Post DC1207 Tsuen Wan Market Street	No.61-95 Tsuen Wan Market Street, No.135-173 Castle Peak Road
24/2/2017	24/2/2017 12:45	24/2/2017 14:30	Near 28 Pak Tin Par Street	No. 28 Pak Tin Par Street
25/2/2017	25/2/2017 19:15	26/2/2017 18:00	Near No.57 Sha Tsui Road	No.29-57 Sha Tsui Road
26/2/2017	26/2/2017 08:00	27/2/2017 09:00	Near No. 62 Sha Tsui Road	No.26-76 Sha Tsui Road
28/2/2017	28/2/2017 16:30	28/2/2017 17:40	Near No.5 Chung On Street.	No.1-11 Chung On Street
3/3/2017	3/3/2017 15:35	4/3/2017 09:00	Near No. 52 Hau Tei Square	No.32-46 Hau Tei Square
3/3/2017	3/3/2017 17:45	3/3/2017 22:00	Near No. 5-9 Chai Wan Kok Street	No.5-9 Chai Wan Kok Street
13/3/2017	13/3/2017 15:00	13/3/2017 22:00	Near No.123 Castle Peak Road	No.117-133 Castle Peak Road
15/3/2017	15/3/2017 13:10	15/3/2017 16:00	Near No.41 Pak Tin Par Street	No. 36-61 Pak Tin Par Street

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
17/3/2017	17/3/2017 14:00	17/3/2017 23:00	Near No. 19 Wo Tik Street	Wo Tik Street
18/3/2017	18/3/2017 13:15	18/3/2017 16:15	Near No. 106-114 Kwok Shui Road	No. 88-130 Kwok Shui Road
21/3/2017	21/3/2017 14:40	21/3/2017 17:35	Near No.25-33 Chung On Street	No. 25-55 Chung On Street, No. 120-150 Hoi Pa Street, No. 31-89 Chuen Lung Street and No. 237-255 Sha Tsui Road
21/3/2017	22/3/2017 14:00	23/3/2017 01:10	Near Lamp Post FA5850 Wai Tsuen Road	Wai Tsuen Sports Centre, Hong Yee Garden
25/3/2017	25/3/2017 08:30	25/3/2017 19:05	Near Lamp Post AC5666 Wang Wo Tsai Street	Wang Wo Tsai Street
3/4/2017	3/4/2017 17:55	4/4/2017 01:00	Near Lamp Post DC1769 Tai Ho Road	Nina Tower Bus Terminus
7/4/2017	7/4/2017 21:55	8/4/2017 16:25	Near Lamp Post FB5029 Tsuen King Circuit	Tsuen Wan Police Station, Waylee Industrial Centre, Block 6-7, Block 11-12, Tsuen King Garden
11/4/2017	11/4/2017 18:40	12/4/2017 15:30	Near No. 50 Sha Tsui Road	No. 28-76 Sha Tsui Road.
17/4/2017	17/4/2017 16:30	17/4/2017 19:45	Near No. 70 Hau Tei Square	No. 70-72 Hau Tei Square, No. 77-89 Tai Ho Road.
22/4/2017	22/4/2017 10:00	22/4/2017 17:15	Near No. 50 Wang Wo Tsai Street	Wang Wo Tsai Street
25/4/2017	25/4/2017 17:40	25/4/2017 19:20	Near No. 4 Fu Wing Street	Fu Wing Street
27/4/2017	27/4/2017 15:05	28/4/2017 09:00	Near No. 2-8 Yi Pei Square	No.93-99 Chuen Lung Street
8/5/2017	8/5/2017 20:40	9/5/2017 11:15	Back Lane of No. 112-118 Sha Tsui Road	No.112-144 Sha Tsui Road and No. 1-9 Heung Shing Street, No. 9-23 Heung Wo Street
12/5/2017	12/5/2017 17:05	14/5/2017 14:30	Near No, 37-41 Tak Wah Street	No. 37-41 Tak Wah Street
12/5/2017	12/5/2017 17:40	12/5/2017 19:00	Near No. 27 Ho Pui Tsuen	No.1-55 Ho Pui Tsuen
13/5/2017	13/5/2017 13:55	13/5/2017 18:45	No. 41 Tsuen Wan Market Street	No.12-36 Shui Wo Street, No.27-59 Tsuen Wan

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
				Market Street, No. 13-19 Chung on Street
16/5/2017	16/5/2017 11:10	16/5/2017 16:45	Near No. 11 Dung Fat Street	Lo Tak Court
17/5/2017	17/5/2017 12:00	17/5/2017 15:30	Near No. 36-44 Pak Tin Par Street	Pak Tin Par Street
18/5/2017	18/5/2017 13:00	18/5/2017 16:23	Near No. 34 Muk Min Ha Tsuen	No.34 Muk Min Ha Tsuen
19/5/2017	19/5/2017 17:15	20/5/2017 09:00	Near No. 54 Ho Pui Tsuen	No. 54 Ho Pui Tsuen
20/5/2017	20/5/2017 10:00	20/5/2017 16:45	Near Lamp Post AC1247 Kwan Mun Hau Street	No. 37-41 Tak Wah Street
23/5/2017	23/5/2017 15:15	23/5/2017 22:00	Near No. 68-82 Chai Wan Kok Street	No. 68-82 Chai Wan Kok Street
24/5/2017	24/5/2017 05:55	24/5/2017 17:55	Near No.121-129 Tsuen Wan Market Street	No. 121-129 Tsuen Wan Market Street
25/5/2017	25/5/2017 15:30	25/5/2017 17:00	Near No. 210 Yau Ma Hom Resite Village, Tsuen Wan.	No.210-216 Yau Ma Hom Resite Village
25/5/2017	26/5/2017 09:05	26/5/2017 12:10	Near No. 49 Pak Tin Par Street	No. 28-63 Pak Tin Par Street, No. 8-28 Tai Chung Road
5/6/2017	5/6/2017 16:00	5/6/2017 20:00	Near No. 18 Tak Hoi Street	No. 18 Tak Hoi Street. No. 74-90 Chung On Street
6/6/2017	6/6/2017 11:00	6/6/2017 15:30	Near No. 380 Castle Peak Road	No. 380 Castle Peak Road
6/6/2017	6/6/2017 16:10	6/6/2017 23:15	Near No. 115 Hoi Pa Street	No.103-117 Hoi Pa Street, No.4-22 Tsuen Wan Market Street
7/6/2017	7/6/2017 14:25	7/6/2017 16:30	Near Lamp Post W0047 Cheung Shan Estate Road East	Cheung Shan Estate. Shing Mun Valley Park
11/6/2017	14/6/2017 09:00	15/6/2017 09:00	Near No.40 Chai Wan Kok Street	Chai Wan Kok Street
15/6/2017	15/6/2017 14:45	15/6/2017 20:10	Near Lamp Post DC0581 Wo Tik Street	Hau Tei Square, Wo Tik Street Part of San Tsuen Street.
26/6/2017	26/6/2017 09:25	26/6/2017 20:00	Near Lamp Post FC0475 Texaco Road	Texaco Road, Lung Tak Road
28/6/2017	28/6/2017 10:35	28/6/2017 11:35	Near No. 38 Muk Min Ha Tsuen	No. 35-44 Muk Min Ha Tsuen

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
28/6/2017	28/6/2017 16:50	29/6/2017 09:00	Near No. 118 Sam Tung Uk Resite Village	No. 118 Sam Tung Uk Resite Village
30/6/2017	30/6/2017 16:40	30/6/2017 19:00	Back Lane of No. 123 Sam Tung Uk Resite Village	No. 117-124 Sam Tung Uk Resite Village
30/6/2017	1/7/2017 00:10	1/7/2017 15:50	Near Lamp Post AC1471 Tsuen King Circuit	Allway gardens, Tsuen King Circuit, Swimming Pool
28/6/2017	5/7/2017 10:30	5/7/2017 16:00	Near No. 53 Sam Tung Uk Resite Village	No. 49-56 Sam Tung Uk Resite Village
5/7/2017	5/7/2017 14:30	5/7/2017 20:00	Near Lamp Post W4936 Sai Lau Kok Road	No. 64-100 Sai Lau Kok Road
8/7/2017	8/7/2017 18:18	9/7/2017 09:30	Near Lamp Post FC0474 Texaco Road	Part of Texaco Road
9/7/2017	9/7/2017 11:50	9/7/2017 17:04	Back of No. 92 Kwan Mun Hau Tsuen	No. 91-104 Kwan Mun Hau Tsuen
14/7/2017	14/7/2017 09:25	14/7/2017 16:32	Near Lamp Post DC0564 Kin Ming Street	No. 303-313 Castle Peak Road
14/7/2017	14/7/2017 10:30	14/7/2017 17:00	Near Lamp Post FC3243 Pun Shan Street	No. 22-32 Pun Shan Street
22/7/2017	22/7/2017 16:05	22/7/2017 22:00	Near Lamp Post AC1471 Tsuen King Circuit	No. 100 , 145-185 Tsuen King Circuit , Allway Gardens
28/7/2017	28/7/2017 15:30	29/7/2017 03:45	Near Lamp Post FB 5088 Mei Wan Street	Discovery Park
1/8/2017	2/8/2017 10:30	2/8/2017 17:30	Near No. 60 Ham Tin Street	Bo Shek Mansion, No. 12-26 Luen Yuen Street, No. 61-89 Ham Tin Street
2/8/2017	2/8/2017 11:05	2/8/2017 14:30	Near Lamp Post W1520, Kwok Shui Road	Part of Hoi Pa San Tsuen & 168 Kwok Shui Road
7/8/2017	7/8/2017 13:35	7/8/2017 15:30	Near No. 16 Hoi Pa Village	No. 16-21 Hoi Pa Village
8/8/2017	8/8/2017 04:00	9/8/2017 03:00	Near No. 45-53 Sha Tsui Road	No. 29-43 Sha Tsui Road
8/8/2017	8/8/2017 12:45	8/8/2017 16:30	Near No. 117 Hoi Pa Street	No. 103-117 Hoi Pa Street / No. 45-55 Tai Hoi Road
9/8/2017	9/8/2017 16:00	9/8/2017 17:30	Near No. 144 Hoi Pa Street	Tsuen Wan Market
10/8/2017	10/8/2017 16:18	11/8/2017 17:06	Near Lamp Post FB5822 Sai Lau Kok Road	Tsuen Kam Centre, Tsuen Wan Government Offices Building Public Labrary,

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
				Nam Fung Centre, Cheong Lok Building, MTR Station, Luk Yeung Sun Tsuen
12/8/2017	12/8/2017 19:20	13/8/2017 04:00	Near No. 623 Castle Peak Road	No. 520-654 Castle Peak Road, No. 68 Hoi On Road, Yau Lai Road
14/8/2017	14/8/2017 01:15	14/8/2017 16:00	Near No. 68 Sha Tsui Road	No. 26-76 Sha Tsui Road
14/8/2017	14/8/2017 16:30	14/8/2017 23:55	Near No. 4 Chai Wan Kok Street	No. 2-4 Chai Wan Kok Street
17/8/2017	17/8/2017 09:40	17/8/2017 18:00	Near No. 16 Heung Wo Street	No. 2-44 Heung Wo Street, No. 3-47 Tai Pa Street
18/8/2017	18/8/2017 11:00	18/8/2017 12:17	Near Lamp Post AC1986 Tsuen Wan Market Street	No. 115-119 Tsuen Wan Market Street, No. 117 -133 Castle Peak Road
30/8/2017	30/8/2017 10:05	30/8/2017 18:00	Near No. 1-21 Tsuen Fu Street	No. 1-21 Tsuen Fu Street
30/8/2017	30/8/2017 16:00	30/8/2017 18:15	Near No. 92 Kwan Mun Hau Tsuen	No. 92 Kwan Mun Hau Tsuen
5/9/2017	5/9/2017 16:00	5/9/2017 21:00	Near No. 101-117 Chung On Street	No. 68-84 Ho Pui Street, No. 146 Chung On Street, No. 85-99 Yeung Uk Road
9/9/2017	9/9/2017 12:00	10/9/2017 03:00	No. 5 Tai Pa Street	No. 3-7 Tai Pa Street and No. 16-23 Heung Shing Street and No.9-17 Fu Yung Street
10/9/2017	10/9/2017 06:15	10/9/2017 12:10	Near Lamp Post DC1769 Tai Ho Road	Nina Tower Bus Terminus
11/9/2017	11/9/2017 12:30	12/9/2017 09:00	Near Lamp Post DC2196 Castle Peak Road-Tsuen Wan	No. 633 Castle Peak Road
11/9/2017	11/9/2017 15:40	12/9/2017 10:00	Junction of Yeung Uk Road and Tai Ho Road	Vision City
12/9/2017	12/9/2017 10:00	12/9/2017 15:25	Near No. 160 Sha Tsui Road	No. 112-188 Sha Tsui Road and No. 9-63 Heung Wo Street
13/9/2017	13/9/2017 14:40	13/9/2017 17:30	Back Lane of No. 26-30 Tso Kung Square	No. 20-36 Tso Kung Square
14/9/2017	14/9/2017 13:00	14/9/2017 23:00	Near Lamp Post FA5153, Tai Chung	Chai Wan Kok Street

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
			Road	
15/9/2017	15/9/2017 14:15	15/9/2017 16:30	Near Lamp Post AC3607 Cheung Shan Estate Road East	Cheung Shan Estate
17/9/2017	17/9/2017 06:30	17/9/2017 14:15	Near Lamp Post FA1766 Tsuen Wan Market Street	No. 131-143 Tsuen Wan Market Street
18/9/2017	18/9/2017 17:30	18/9/2017 22:00	Near Lamp Post U7676 Hoi Pa Street	Lo Tak Court and Tsuen Hing Path
19/9/2017	19/9/2017 09:25	19/9/2017 15:20	Near No. 52A Sha Tsui Road	No. 26-76 Sha Tsui Road
21/9/2017	21/9/2017 03:00	21/9/2017 15:00	Near Lamp Post FC3190 Tsuen King Circuit	Kam Fung Garden
23/9/2017	23/9/2017 13:30	23/9/2017 19:30	Near No. 600 Castle Peak Road	Partially of Castle Peak Road, Yau Lai Road
26/9/2017	26/9/2017 19:00	27/9/2017 00:45	Near Lamp Post FB2844 Kwok Shui Road	No. 682-704 Castle Peak Road
7/10/2017	7/10/2017 10:15	7/10/2017 16:00	Near No. 19 Tai Pa Street	No. 9-17 Fu Yung Street, No. 3-47 Tai Pa Street, and No. 2-64 Heung Shing Street
9/10/2017	9/10/2017 10:55	9/10/2017 14:45	Near Lamp Post W1984 Kwok Shui Road	No. 682-690 Castle Peak Road
9/10/2017	9/10/2017 16:16	10/10/2017 06:11	Near Lamp Post AC1254 Tsuen Kwai Street	Wealthy Garden, East Asia Garden
9/10/2017	9/10/2017 19:00	10/10/2017 01:00	Near Lamp Post W4127 Hoi Shing Road	Hoi Shing Road, Hoi Pa Street, Tai Pa Street, Tai Chung Road, Chai Wan Kok Street, Sha Tsui Road, Yuen Tun Circuit, Fu Yung Street
19/10/2017	19/10/2017 13:05	19/10/2017 14:35	Near No. 37 Chung On Street	Chung On Street, Hoi Pa Street, Tai Pei Square
20/10/2017	20/10/2017 10:55	20/10/2017 16:25	Near No. 3-7 Kin Ming Street	No. 3-7 Kin Ming Street
26/10/2017	26/10/2017 10:00	26/10/2017 17:45	Near No. 40-50 Sha Tsui Road	No. 26-76 Sha Tsui Road
28/10/2017	28/10/2017 13:00	28/10/2017 16:00	No. 20-40 Lo Tak Court	Lo Tak Court, Tsuen Hing Path, No.27-101Hoi Pa Street

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
30/10/2017	30/10/2017 10:25	30/10/2017 11:40	Near No. 43 Ho Pui Tsuen	No. 1-48 Ho Pui Tsuen
2/11/2017	2/11/2017 15:00	2/11/2017 19:10	Near No. 18 Yeung Uk Road	No. 18 Yeung Uk Road
5/11/2017	5/11/2017 12:50	5/11/2017 16:45	Near Lamp Post FC0474 Texaco Road	No. 231 Texaco Road
9/11/2017	9/11/2017 09:30	9/11/2017 11:05	Near No. 89 Tai Ho Road	No. 77-89 Tai Ho Road & No. 24-72 Hau Tei Square
9/11/2017	10/11/2017 10:05	10/11/2017 14:30	No. 2-4 Tso Kung Square	No. 2-32 Hoi Pa Street, No. 2-36 Tso Kung Square, Heung Che Street Market & Refuse Collection Point
12/11/2017	12/11/2017 02:40	12/11/2017 19:25	Near Lamp Post FA5870 Shek Wai Kok Road	Shek Wai Kok Estate
14/11/2017	14/11/2017 09:30	14/11/2017 16:40	Near No. 160 Tsuen Wan Market Street	No. 120-160 Tsuen Wan Market, No.1-17 Tsuen Lok Street
14/11/2017	14/11/2017 20:50	15/11/2017 06:50	Near No. 53 Pak Tin Par Street	Pak Tin Par Street
15/11/2017	15/11/2017 09:40	15/11/2017 14:10	Near No. 115 Hoi Pa Street	No. 103-117 Hoi Pa Street, No. 4-22 Tsuen Wan Market Street
15/11/2017	15/11/2017 18:10	16/11/2017 09:00	Near No.77 Chai Wan Kok Street	No. 77-81 Chai Wan Kok Street.
15/11/2017	15/11/2017 22:00	15/11/2017 23:45	Back of No. 20, Hoi Pa Street	No. 2-32 Hoi Pa Street and No. 2-36 Tso Kung Square, No. 2-6, Tso Kung Street
16/11/2017	16/11/2017 11:30	16/11/2017 23:20	Near No.49-51, Pak Tin Par Street	No. 49-51 Pak Tin Par Street
19/11/2017	19/11/2017 02:50	19/11/2017 19:00	Near Lamp Post FA5867 Shek Wai Kok Road	Part of Shek Wai Kok Estate
20/11/2017	20/11/2017 16:13	20/11/2017 23:41	Near Lamp Post FB3108, Sha Tsui Road	Young Ya Industrial Building, Sheung Chui Court
25/11/2017	25/11/2017 10:30	25/11/2017 13:00	Near Lamp Post W3295 Chai Wan Kok Street	Toilet of Chai Wan Kok Street
15/12/2017	15/12/2017 18:15	15/12/2017 23:32	Near No. 57, Sha Tsui Road	No. 23-57 Sha Tsui Road
19/12/2017	19/12/2017 16:10	20/12/2017 00:30	Near Lamp Post AC0722, Tak Hoi Street	No. 68, Chung On Street

Date	Supply Isolation Time	Supply Resumption Time	Location	Premises Affected
19/12/2017	19/12/2017 23:00	20/12/2017 14:00	Near Back Lane of No. 41, Tak Wah Street	Part of Yan Chai Hospital and Tsuen Wan Catholic Primary School.
23/12/2017	23/12/2017 10:30	23/12/2017 16:44	Near Lamp Post AC1447, Tsuen King Circuit	Part of Tsuen Wan Adventist Hospital.
24/12/2017	24/12/2017 08:21	25/12/2017 09:40	Near No. 34, San Tsuen Street	No.34-58 San Tsuen Street, No.33-37 Ho Pui Street, No.23-33 Wo Tik Street
24/12/2017	24/12/2017 15:00	24/12/2017 15:45	Near Lamp Post FA5845, Wai Tsuen Road	Tsuen Wan Tin Hau Temple Garden

- End -

CONTROLLING OFFICER'S REPLY

DEVB(W)177

(Question Serial No. 6120)

Head: (194) Water Supplies Department

Subhead (No. & title): Not Specified

Programme: (1) Water Supply: Planning and Distribution

Controlling Officer: Director of Water Supplies (C L WONG)

Director of Bureau: Secretary for Development

Question:

1. Under Programme (1), it is mentioned that the Water Supplies Department (WSD) plans to supply reclaimed water for non-potable purposes in the north-eastern part of the New Territories. What are the daily supply rate, water quality standards, purposes and cost per cubic metre of the reclaimed water in the future?

2. Will the Government conduct more studies on reclaimed water to make the production of it possible and make it suitable for general water uses? If yes, what are the related expenditure? If no, what are the reasons?

Asked by: Hon KWOK Wai-keung (Member Question No. (LegCo use): 44)

Reply:

1. We plan to supply reclaimed water for toilet flushing in the north-eastern part of the New Territories in phases starting with Sheung Shui and Fanling from 2022 onwards. The unit production cost of reclaimed water is estimated to be \$6.4 per cubic metre (at 2016-17 price level). The water quality standards of the reclaimed water are at the Annex. The reclaimed water supply in the north-eastern part of the New Territories will be up to 56 000 cubic metres per day.

2. At present, very few places in the world use reclaimed water for direct potable use because most people do not accept drinking reclaimed water. We have conducted a public opinion survey in the pilot scheme for the use of reclaimed water at Ngong Ping which showed that the majority of the public in Hong Kong does not accept the use of reclaimed water for potable use. As such, the reclaimed water supply in the north-eastern part of the New Territories will be for the major non-potable use of toilet flushing. We will also explore other minor uses of reclaimed water such as irrigation, street washing etc.

Annex to SFCQ 6120

Water Quality Standards for Reclaimed Water in Hong Kong
(for non-potable uses, including toilet flushing)

Parameter	Unit	Recommended water quality standards at user end
E. coli	cfu /100 ml	Non detectable
Total residual chlorine	mg/l	≥ 0.2 ; and ≥ 1 at exiting treatment system
Dissolved oxygen in reclaimed water	mg/l	≥ 2
Total suspended solids (TSS)	mg/l	≤ 5
Colour	Hazen unit	≤ 20
Turbidity	NTU	≤ 5
pH		6 - 9
Threshold Odour Number (TON)		≤ 100
5-day Biochemical oxygen demand (BOD5)	mg/l	≤ 10
Ammoniacal nitrogen	mg/l as N	≤ 1
Synthetic detergents	mg/l	≤ 5

- End -

CONTROLLING OFFICER'S REPLY

DEVB(W)178

(Question Serial No. 6028)

Head: (194) Water Supplies Department

Subhead (No. & title): Not Specified

Programme: (1) Water Supply: Planning and Distribution

Controlling Officer: Director of Water Supplies (C L WONG)

Director of Bureau: Secretary for Development

Question:

Regarding the tender invitation for construction of the desalination plant at Tseung Kwan O and the laying of associated trunk water mains, please inform this Committee of:

- (a) the progress, timetable, staff involved, the estimated and actual expenditures of each work item, as well as the future working plans since the announcement of this desalination plant project in tabular format;
- (b) whether there will be cost overrun in this project; if yes, the details and the Government's follow-up actions.

Asked by: Hon KWOK Wing-hang, Dennis (Member Question No. (LegCo use): 148)

Reply:

- (a) The progress, timetable, number of staff involved and expenditures for the construction of the desalination plant at Tseung Kwan O and the laying of associated trunk water mains are tabulated below-

1.	Construction of desalination plant	Progress and Timetable	The consultants engaged for the first stage of the proposed desalination plant at Tseung Kwan O have completed the reference design of the plant. We have prequalified tenderers for the "Design, Build and Operate" contract for the plant in March 2018 and will invite tenders for this contract in due course. We have scheduled to brief members of the Panel on Development of the Legislative Council in April 2018 and seek funding approval of the Finance Committee subsequently with a view to commencing construction of the plant in end 2018 for its commissioning in 2022.

		Number of staff involved	We have engaged consultant to supervise the construction of the desalination plant. The number of staff involved in the administration and supervision of the consultant is five.
		Expenditure	The estimated expenditure for construction of the desalination plant in 2018-19 is \$500 million.
2.	Laying of associated trunk water mains	Progress and Timetable	The works contract for laying the trunk water mains commenced in November 2017 for completion by mid-2022. The contractor is procuring pipe materials and excavating trial pits along the pipe alignment on site.
		Number of staff involved	The number of staff involved in the administration and supervision of the works contract for laying the trunk water mains is 15.
		Expenditure	The actual expenditure in 2017-18 and the estimated expenditure in 2018-19 for laying the trunk water mains are \$4.5 million and \$60 million respectively.

(b) We do not anticipate any cost overrun for the project.

- End -

CONTROLLING OFFICER'S REPLY

DEVB(W)179

(Question Serial No. 4164)

Head: (194) Water Supplies Department

Subhead (No. & title): Not Specified

Programme: (1) Water Supply: Planning and Distribution, (2) Water Quality Control, (3) Customer Services

Controlling Officer: Director of Water Supplies (C L WONG)

Director of Bureau: Secretary for Development

Question:

Regarding the provision of sign language interpretation services in the past 5 years, will the Government inform this Committee of the following:

1. whether the sign language interpretation service was provided; if yes, the frequency, occasions and causes for providing sign language interpretation services in each year;
2. subsequent to the last question, the number of sign language interpreters involved in each year, their pay and the organisations to which they belong; and
3. whether the Government will consider allocating more resources to improve the services for communicating with the deaf and/or persons with hearing impairment in future. If yes, what are the details (including measures, manpower and expenditure involved and timetable, etc.)? If no, what are the reasons?

Asked by: Hon LEUNG Yiu-chung (Member Question No. (LegCo use): 103)

Reply:

The Water Supplies Department currently does not provide sign language interpretation services. We will continue to monitor the need for such services and consider allocating the necessary resources based on the actual situation.

- End -

CONTROLLING OFFICER'S REPLY

DEVB(W)180

(Question Serial No. 6130)

Head: (194) Water Supplies Department

Subhead (No. & title): Not Specified

Programme: (1) Water Supply: Planning and Distribution

Controlling Officer: Director of Water Supplies (C L WONG)

Director of Bureau: Secretary for Development

Question:

Regarding the water quality control by the Water Supplies Department (WSD), please inform this Committee of:

- 1) the respective number of complaints made by citizens about the odour in drinking water in the 18 districts received in the past 3 years, in tabular format;
- 2) when the WSD receives a complaint from a citizen about the odour in drinking water, whether there is a mechanism to handle the complaint; if yes, the details;
- 3) whether there is a remedial mechanism when it is confirmed that there is an odour in drinking water by the WSD; if yes, the details, and the mechanism for releasing the latest information.

Asked by: Hon MAK Mei-kuen, Alice (Member Question No. (LegCo use): 59)

Reply:

1) The Water Supplies Department (WSD) does not maintain specific records on complaints related to odour in drinking water. Instead, the WSD has grouped complaint figures on odour and/or taste of drinking water together in maintaining the department's complaint statistics and such complaint figures in 2015, 2016 and 2017 are tabulated below:-

District	2015	2016	2017
Central & Western	25	29	20
Eastern	34	33	40
Islands	10	0	0
Southern	0	5	6
Wan Chai	17	9	7

Kowloon City	10	18	13
Kwun Tong	6	10	7
Sham Shui Po	13	22	17
Wong Tai Sin	4	8	6
Yau Tsim Mong	28	47	34
North	6	18	4
Sai Kung	6	22	14
Sha Tin	12	22	14
Tai Po	6	10	11
Kwai Tsing	25	23	64
Tuen Mun	3	17	11
Tsuen Wan	0	0	15
Yuen Long	5	0	0
Total	210	293	283

Most of the complaints tabulated above are isolated cases and related to the maintenance of inside services.

2 &3) When a complaint on taste/odour of drinking water is received, the WSD will carry out timely site inspection to investigate the complaint and arrange collection of water samples for laboratory testing if necessary. If the problem is due to the inside service, the WSD will provide technical advice to the management office/owners corporation on the appropriate actions to be taken to clean up the inside service. If the problem is due to the Government's water supply system, the WSD will take appropriate rectification action and provide emergency temporary water supply for the affected customers if necessary, and at the same time provide assistance deemed necessary to the management office/owners corporation including the technical advice as mentioned above. In this regard, the WSD issued in January 2018 guidelines to the management offices on actions to be taken in the event of water quality incidents. In respect of the mechanism for releasing the latest information about incidents related to taste/odour of drinking water, the Public Relation Unit of the WSD will respond to enquiries and issue press release where necessary in a timely manner to keep the affected customers and the media informed of the latest situation of the incidents. Also, the WSD's Customer Telephone Enquiry Centre (Tel: 2824 5000) will be provided with the updated situation of the incidents and the emergency temporary water supply arrangement, if any, for responding to enquiries from the general public.

- End -

CONTROLLING OFFICER'S REPLY

DEVB(W)181

(Question Serial No. 5880)

Head: (194) Water Supplies Department

Subhead (No. & title): Not Specified

Programme: (1) Water Supply: Planning and Distribution

Controlling Officer: Director of Water Supplies (C L WONG)

Director of Bureau: Secretary for Development

Question:

The aim of the Water Supplies Department is to plan and develop water resources and to design, construct, maintain and operate water supply systems in order to provide round-the-clock supplies throughout the year to meet the demands of the territory. However, there is frequent occurrence of bursting of old fresh water mains aged over 20 to 30 years in many developed areas in Hong Kong due to the ageing problem, causing road subsidence and flooding, and in turn resulting in disruptions to the traffic and damages to the property of the public. In this regard, please provide the details of the bursting of fresh water mains and salt water mains for flushing in the past 3 years using the table below.

Date and time	Location	Duration (hours)	Type of pipe (fresh water / salt water for flushing)	Age of water mains	Are there any claims made by the public / commercial tenants due to main bursting; if yes, what is the amount of claims?	Estimated date of next comprehensive replacement of the pipes involved

Asked by: Hon MO Claudia (Member Question No. (LegCo use): 72)

Reply:

There were 145, 116 and 88 water main burst cases in 2015, 2016 and 2017 respectively. Details of these 349 cases are tabulated in **Appendices I and II** respectively for fresh and salt water main bursts.

Among these cases, 169 cases were fresh water main bursts while the remaining 180 cases were salt water main bursts. There were 31 cases with fresh water supply interrupted for more than eight hours and 29 cases with the traffic at Red/Pink routes affected.

There were 242 cases with age of water mains over 30 years and 80 cases between 15 years and 30 years. Regarding the remaining 27 cases with age of water mains of less than 15 years, the main causes were due to corrosion of salt water mains and damage by others.

We have received 13 claims for damages due to the above burst cases. There is one case still under investigation with a claimed amount of about \$28,000. The remaining 12 claims were found not justified after investigation.

The defective part of the burst mains were replaced immediately during emergency repair. Out of the 349 main burst cases, there were 150 cases with the relevant section of water mains subsequently replaced or rehabilitated, and 69 cases required no further action as they were either damaged by others or considered as isolated incidents. For the remaining 130 cases, we will adopt a risk-based assessment approach to determine the necessary improvement works including reprovisioning so as to sustain the healthiness of the water supply networks. The risk-based assessment comprises a review of the consequence and probability of failure of the water mains taking into account various factors such as population and customers served, location, material, age, failure record, pipe size, etc.

Fresh Water Main Bursts
(2015 to 2017)

No.	Date and Time	Location	Water Supply Interruption (hour)	Age of Water Main (Note 1)
1	14/1/2015 8:25	No. 26 Des Voeux Road Central	Not affected	Unknown
2	16/1/2015 17:20	San Wan Road near Light Pole No. N3107, Fanling	Not affected	Unknown
3	17/1/2015 18:36	Castle Peak Road near Light Pole No. Ad6135, Sheung Shui	7.0	31.6
4	22/1/2015 16:24	Kwun Fat Street near Fire Hydrant No. Ph10493	6.6	12.0
5	23/1/2015 6:51	Tsing Yi Road near Light Pole No. Ac0779, Tsing Yi	11.0	Unknown
6	23/1/2015 11:39	No. 36C Siu Lek Yuen Road, Sha Tin	Not affected	25.6
7	31/1/2015 18:22	No. 106 King Fuk Street	Not affected	Unknown
8	9/2/2015 7:13	Des Voeux Road West near Eastern Street, Sai Ying Pun	Not affected	Unknown
9	13/2/2015 3:27	Sheung Sze Wan Road near Clear Water Bay Road, Sai Kung	7.0	Unknown
10	13/2/2015 7:45	No. 1 Waterloo Road	11.9	Unknown
11	24/2/2015 8:39	Container Port Road near Light Pole No. Fc1374, Kwai Chung	Not affected	Unknown
12	2/3/2015 13:50	Wang Yip Street West, Yuen Long	Not affected	20.0
13	5/3/2015 16:12	Tuen Hi Road near Fire Hydrant No. Ph2286	5.6	Unknown
14	9/3/2015 13:51	Container Port Road near Light Pole No. Fc1379, Kwai Chung	Not affected	Unknown
15	23/3/2015 13:29	No. 1-3 Ting Kok Road, Tai Po	11.7	34.8
16	27/3/2015 2:54	Hop Choi Street near Light Pole No. U8546, Yuen Long	6.8	Unknown
17	3/4/2015 12:22	Tin Sam Street, Sha Tin	Not affected	32.0
18	6/4/2015 15:18	Science Museum Road	8.0	Unknown
19	11/4/2015 14:03	No. 23 Hang Hau Wing Lung Road, Tseung Kwan O	7.0	Unknown

No.	Date and Time	Location	Water Supply Interruption (hour)	Age of Water Main (Note 1)
20	18/4/2015 0:20	Fung Cheung Road near Hop Yick Road, Yuen Long	10.0	Unknown
21	1/5/2015 8:53	Chung Mei Road near Light Pole No. U7277, Tsing Yi	8.8	Unknown
22	15/5/2015 2:43	Chung Mei Road near Light Pole No. U7279, Tsing Yi	15.8	Unknown
23	21/5/2015 20:06	Castle Peak Road near Light Pole No. Fc2623, Tsuen Wan	7.0	Unknown
24	28/5/2015 6:37	No. 48 MacDonnell Road, Central	8.0	Unknown
25	29/5/2015 22:17	Mong Kok Road near Tong Mi Road	Not affected	Unknown
26	5/6/2015 9:16	Near 188 Kwai Shing Circuit, Kwai Chung	3.5	Unknown
27	7/6/2015 18:02	Wai Yip Street near Sheung Yee Road	Not affected	31.0
28	10/6/2015 7:07	Kam Tin Road near Kam Tin Mung Yeung Public School, Yuen Long	6.4	Unknown
29	11/6/2015 9:51	Ping Che Road near Light Pole No. EB4893, Fanling	12.6	28.0
30	13/6/2015 8:36	Junction of Science Museum Road and Granville Road	3.6	Unknown
31	13/6/2015 18:30	Ping Che Road near Light Pole EB4893, Fanling	22.8	28.0
32	14/6/2015 19:00	Man Wo House, Wo Che Estate, Sha Tin	Not affected	33.0
33	18/6/2015 18:01	No. 111A, Argyle Street	Not affected	Unknown
34	19/6/2015 4:30	No. 31 Au Pui Wan Street, Fo Tan	5.7	Unknown
35	27/6/2015 15:34	Tai Po Tsai Village near Light Pole No. Eb4656, Tseung Kwan O	2.6	43.0
36	1/7/2015 21:03	Wang Kwong Road near Sheung Yuet Road	Not affected	Unknown
37	8/7/2015 19:08	No.44 Tanner Road	6.9	Unknown
38	26/7/2015 8:39	Shek Ku Street near Perth Street	6.9	Unknown
39	6/8/2015 6:10	No. 289 Queen's Road West	Not affected	Unknown
40	11/8/2015 4:32	Junction of Mong Kok Road and Canton Road	Not affected	Unknown

No.	Date and Time	Location	Water Supply Interruption (hour)	Age of Water Main (Note 1)
41	11/8/2015 11:00	No.63 Sai Wan Ho Street	1.7	Unknown
42	23/8/2015 1:19	Footpath near Garden Rivera Block E and F, Sha Tin	Not affected	31.2
43	3/9/2015 3:02	Kwai Lok Street near Light Pole No. Fc4678, Kwai Chung	Not affected	Unknown
44	4/9/2015 10:55	No. 20 Good Shepherd Street	7.5	Unknown
45	11/9/2015 15:44	Ting Kok Road near Light Pole No. Eb0387	6.7	35.2
46	11/9/2015 23:59	Chi Kiang Street near Lung Tak Street	17.5	Unknown
47	23/9/2015 5:09	No. 22 Chi Kiang Street	7.7	Unknown
48	25/9/2015 14:04	Construction Site near King Fuk Street	11.7	5.0
49	26/9/2015 12:07	No. 16 Shouson Hill Road, Shouson Hill	4.8	33.0
50	2/10/2015 3:29	Hop Yick Road near Light Pole No. FB4339, Yuen Long.	Not affected	Unknown
51	6/10/2015 23:08	Queen Mary Hospital, Pok Fu Lam	4.6	8.0
52	12/10/2015 14:07	Lung Sum Avenue near Light Pole DD0387	2.2	5.9
53	12/10/2015 21:23	No. 22 Good Shepherd Street	5.2	Unknown
54	14/10/2015 4:46	No. 30 Good Shepherd Street	9.8	Unknown
55	16/10/2015 14:56	Mui Wo Ferry Pier Road near Light Pole No. SM0131, Mui Wo	3.0	19.0
56	17/10/2015 10:14	Mui Wo Ferry Pier Road near Light Pole No. FB2463, Mui Wo	4.8	Unknown
57	9/11/2015 20:27	Fu Ning Street near Shing Tak Street	3.1	Unknown
58	11/11/2015 14:59	Shun Hing Street near Light Pole No. EA3253, Sha Tau Kok	6.0	Unknown
59	25/11/2015 20:23	Mui Wo Ferry Pier Road near Light Pole No. FB2464, Mui Wo	24.3	Unknown
60	26/11/2015 9:54	Backlane of No. 256 Tung Chau Street	2.7	Unknown
61	27/11/2015	Tsing Yi Heung Sze Wui Road,	4.9	Unknown

No.	Date and Time	Location	Water Supply Interruption (hour)	Age of Water Main (Note 1)
	14:57	Tsing Yi		
62	4/12/2015 22:06	Hiram's Highway near Light Pole No. Ea9639	3.7	43.5
63	8/12/2015 18:01	Cha Kwo Ling Road near Fan Wa Street	Not affected	Unknown
64	12/12/2015 14:05	Sha Tau Kok Road near Light Pole No. Cd1856	Not affected	Unknown
65	14/12/2015 5:39	Hop Yick Road near Light Pole No. Fb4340, Yuen Long	7.6	Unknown
66	16/12/2015 13:11	Chung Hau Street, Ho Man Tin	Not affected	Unknown
67	16/12/2015 17:49	Tuen Mun Heung Sze Wui Road near Light Pole No. H0913	7.6	36.0
68	18/12/2015 13:23	Kwong Fuk Square, Tai Po	1.7	Unknown
69	26/12/2015 11:25	Junction of Ngan Shing Street and Tak Wing Street, Sha Tin	Not affected	Unknown
70	2/1/2016 13:10	No. 70 Ma Tau Wai Road	6.4	Unknown
71	9/1/2016 9:21	Canton Road near Saigon Street	7.0	Unknown
72	15/1/2016 19:43	Near Chung Hau Tsuen Public Toilet, Mui Wo	6.0	20.0
73	16/1/2016 6:29	Near Chung Hau Tsuen Public Toilet, Mui Wo	9.7	20.0
74	18/1/2016 7:10	Wang Lee Street near Light Pole No. Fa8671, Wang Chau, Yuen Long	7.2	34.0
75	20/1/2016 13:02	No. 190 Hollywood Road	5.5	Unknown
76	21/1/2016 2:12	Mei Tin Road, Tai Wai	Not affected	7.1
77	21/1/2016 10:16	Mui Wo Ferry Pier Road, Mui Wo, Lantau	12.5	Unknown
78	24/1/2016 6:06	No. 2-28 Kwai Lok Street, Kwai Chung	Not affected	Unknown
79	26/1/2016 9:12	No. 64 Nam Wan San Tsuen, Peng Chau	Not affected	12.0
80	28/1/2016 7:08	Wan Hoi Street near Tai Wan Shan Swimming Pool	9.3	Unknown
81	19/2/2016 14:06	Junction of Che Kung Miu Road and Sha Tin Tau Road	6.9	Unknown

No.	Date and Time	Location	Water Supply Interruption (hour)	Age of Water Main (Note 1)
82	29/2/2016 4:44	Belcher's Street near Sai Cheung Street	Not affected	Unknown
83	29/2/2016 8:26	Yau Shin Street near Light Pole No. Ad6826, Au Tau, Yuen Long	Not affected	Unknown
84	7/3/2016 14:27	No. 21 Kwai Tei New Village, Fo Tan	3.4	18.7
85	15/3/2016 10:39	Olympic Garden, Kowloon City	Not affected	5.0
86	15/3/2016 23:50	No. 47-49 Ma Tau Wai Road	5.4	Unknown
87	17/3/2016 13:56	Ngan Kwong Wan Road near Light Pole No. Dc0170, Mui Wo	13.5	Unknown
88	31/3/2016 10:47	Kwai Tei New Village, Fo Tan	3.0	19.0
89	15/4/2016 17:00	King's Road near Light Pole No. 43497	Not affected	4.0
90	19/4/2016 8:04	Wang Chiu Road near Kai Lai Road	6.9	32.0
91	19/4/2016 12:48	Wang Yip Street West near Light Pole No. Ad9143, Yuen Long	Not affected	Unknown
92	25/4/2016 17:10	No. 148 Electric Road	Not affected	Unknown
93	26/4/2016 7:16	Clear Water Bay Road near Tseng Lan Shue	Not affected	33.9
94	26/4/2016 10:04	No.104 Kat Hing Back Street, Tai O	2.2	15.0
95	28/4/2016 13:05	No. 1-35, Tai Wai Road, Sha Tin	Not affected	33.0
96	5/5/2016 11:39	Sai Ching Street near Fire Hydrant No. Ph2962, Yuen Long	7.8	34.0
97	5/5/2016 15:29	Fantasy Road near Light Pole No. Dc0907, HK Disneyland, Lantau	Not affected	12.0
98	18/5/2016 7:35	Sheung Yee Road near Wai Yip Street	5.7	Unknown
99	22/5/2016 10:16	Fung Cheung Road, Yuen Long	Not affected	Unknown
100	22/5/2016 13:33	Kan Tau Tsuen near Light Pole No. Eb3081, Fanling	16.1	Unknown
101	5/6/2016	Ma Tau Chung Road	Not affected	Unknown

No.	Date and Time	Location	Water Supply Interruption (hour)	Age of Water Main (Note 1)
	6:52			
102	9/6/2016 0:50	City Garden Road near Fire Hydrant No. 1473	11.8	Unknown
103	10/6/2016 6:59	Container Port Road near Light Pole No. Fc1390, Kwai Chung	Not affected	Unknown
104	11/6/2016 17:26	Shek Pai Tau Road near Light Pole No. Dd0958	13.1	Unknown
105	15/6/2016 5:49	On Po Road near Light Pole No. Eb3779, Tai Po	12.9	Unknown
106	16/6/2016 17:49	Lung Mun Road near Ho Wan Street	Not affected	35.0
107	20/7/2016 7:02	Tsuen Wah Street near Light Pole No. Ac1720, Tsuen Wan	Not affected	Unknown
108	26/7/2016 16:50	Near Tung Chung Pipe Bridge, Tung Chung, Lantau	6.0	19.0
109	27/7/2016 11:57	Ngan Kwong Wan Road near Fire Hydrant No. Ph68, Mui Wo	7.0	33.0
110	1/8/2016 7:04	Hop Yick Road near Light Pole No. Fb4340, Yuen Long	Not affected	25.0
111	3/8/2016 11:38	No. 222-224 Sai Lau Kok Road, Tsuen Wan	Not affected	36.0
112	8/8/2016 11:50	City Garden Road near Light Pole No. 44594	2.0	32.0
113	11/8/2016 3:48	Kung Um Road near Light Pole No. Dd1155, Yuen Long	Not affected	Unknown
114	14/8/2016 9:20	Java Road	Not affected	Unknown
115	22/8/2016 6:26	Science Museum Road near Mody Road	Not affected	Unknown
116	23/8/2016 11:06	Junction of Ma Kok Lane and Lung Tak Street, Tsuen Wan	Not affected	Unknown
117	1/9/2016 9:35	No. 2-4 Greig Road	5.7	Unknown
118	7/9/2016 6:51	Kwai Yan Road near Kwai Chung Plaza, Kwai Chung	10.3	Unknown
119	13/9/2016 16:53	No. 163 Hai Tan Street	Not affected	12.0
120	13/9/2016 18:06	No. 180 Pok Fu Lam Road, Pok Fu Lam	7.1	Unknown
121	19/9/2016 10:35	Man Yue Street near Ma Tau Wai Road	Not affected	30.0
122	20/9/2016	Hong Lee Road near Kung Lok	Not affected	Unknown

No.	Date and Time	Location	Water Supply Interruption (hour)	Age of Water Main (Note 1)
	3:09	Road		
123	20/9/2016 6:28	No. 8 Leung Yip Street, Yuen Long	7.8	Unknown
124	30/9/2016 10:13	Aberdeen Praya Road near Light Pole No. 41995, Aberdeen	3.9	4.0
125	6/10/2016 12:05	Ngai Shing Street near Light Pole No. N0304	Not affected	Unknown
126	13/10/2016 7:14	Wan Po Road near Light Pole No. Cr1407, Tseung Kwan O	12.3	28.4
127	25/10/2016 5:44	Wong Nai Chung Road	7.0	Unknown
128	8/11/2016 2:37	Arsenal Street	6.9	Unknown
129	14/11/2016 0:15	Mody Road near Kowloon Shangri-La Hotel	6.5	Unknown
130	16/11/2016 23:24	Mody Road near Kowloon Shangri-La Hotel	6.6	Unknown
131	2/12/2016 20:06	No. 98-102 Babington Path, Sai Wan	9.1	Unknown
132	9/12/2016 4:57	No. 44 Yiu Wa Street	Not affected	Unknown
133	23/12/2016 10:34	Lee Nam Road near Light Pole No. 35329, Aberdeen	4.1	22.0
134	4/1/2017 7:38	Ting Kok Road near Light Pole No. EB0388	Not affected	36.5
135	5/2/2017 20:55	Jordan Road near Parkes Street	Not affected	Unknown
136	15/2/2017 5:18	Johnston Road near Fenwick Street	Not affected	Unknown
137	27/2/2017 10:40	No.8 Wharf Road, North Point	4.9	35.0
138	27/2/2017 15:50	No. 3 Comfort Terrace, North Point	2.2	Unknown
139	1/3/2017 15:45	Victoria Park Road	Not affected	11.0
140	2/3/2017 4:55	No.2, Lei Muk Road, Kwai Chung	26.1	Unknown
141	3/3/2017 0:49	Po Yip Street near Light Pole No. H2018, Yuen Long	10.0	Unknown
142	16/3/2017 6:15	No.1 Java Road	7.9	0.0
143	18/3/2017	Cheung Hong Street junction	7.8	Unknown

No.	Date and Time	Location	Water Supply Interruption (hour)	Age of Water Main (Note 1)
	4:32	King's Road		
144	13/4/2017 11:20	No. 348-350 Lockhart Road	0.5	Unknown
145	19/4/2017 15:14	Castle Peak Road near Light Pole No. AC0206, Tsuen Wan	Not affected	27.0
146	20/4/2017 4:38	Tsuen Wan Market Street near Light Pole No. W3073, Tsuen Wan	2.2	48.0
147	23/4/2017 6:34	South Lantau Road near Light Pole No. FB4594, Lantau	26.0	32.0
148	24/4/2017 4:07	Yun Ping Road near Light Pole No. 47494	5.7	Unknown
149	19/5/2017 13:30	Tsing Yi North High Level Fresh Water and Salt Water Pumping Station, Tsing Yi	8.5	35.0
150	26/5/2017 21:27	Tsung Tau Ha Road near Light Pole No. ST1266, Fo Tan	6.1	Unknown
151	14/6/2017 15:45	Victoria Park Road near Light Pole No. 45258	Not affected	11.0
152	15/6/2017 4:47	Cheung Shun Street near Cheung Sha Wan Cooked Food Stall	3.5	Unknown
153	28/6/2017 4:43	Opposite of No. 6 Fenwick Street	4.9	Unknown
154	13/7/2017 2:14	Butterfly Valley Road near Lai Chi Kok Reception Centre	12.0	Unknown
155	14/7/2017 13:25	Harbour Road near Light Pole No. 27310	7.0	32.0
156	23/7/2017 1:11	Container Port Road near Light Pole No. FC1379, Kwai Chung	Not affected	Unknown
157	7/8/2017 16:04	Mai Po Lung near Light Pole No. FA8235, San Tin, Yuen Long	5.3	28.0
158	31/8/2017 1:36	Backlane of No.94 Lockhart Road	3.8	Unknown
159	16/9/2017 23:53	Exit D, Fo Tan MTR Station	6.3	Unknown
160	15/10/2017 12:06	Ma Tin Road near Light Pole No. FB5828, Yuen Long	13.3	Unknown
161	25/10/2017 6:06	Nam Long Shan Road near Light Pole No. 40486, Aberdeen	Not affected	Unknown
162	14/11/2017 12:15	No.1-11, Kwai Hei Street, Kwai Chung	29.4	Unknown

No.	Date and Time	Location	Water Supply Interruption (hour)	Age of Water Main (Note 1)
163	21/11/2017 0:14	No. 60 Pok Fu Lam Road, Western	13.0	Unknown
164	22/11/2017 13:54	Keung Shan near Keung Shan Raw Water Break Pressure Tank, Lantau	3.4	10.0
165	2/12/2017 8:08	No. 26 Po Tung Road, Sai Kung	4.7	Unknown
166	14/12/2017 11:22	Ta Chuen Ping Street near Light Pole No. FB2908, Kwai Chung	Not affected	Unknown
167	17/12/2017 5:40	Queen Street junction Des Voeux Road West	Not affected	Unknown
168	19/12/2017 1:36	Nga Tsin Wai Road near Nam Kok Road, Kowloon City	Not affected	Unknown
169	27/12/2017 6:32	Water Street near Connaught Road West	Not affected	Unknown

Note 1: "Unknown" denotes no record of age of the water main. The year of completion was not incorporated in WSD's water mains record in the past until early eighties. Hence, the age of these water mains will likely be over 30 years.

Salt Water Main Bursts
(2015 to 2017)

No.	Date and Time	Location	Water Supply Interruption (hour)	Age of Water Main (Note 1)
1	3/1/2015 7:05	On Po Road near Light Pole No. N6671, Tai Po	23.9	29.5
2	3/1/2015 13:50	No. 48 Mody Road	6.8	6.0
3	6/1/2015 5:42	No. 39 Mong Kok Road	20.2	Unknown
4	14/1/2015 3:41	Pak Hoi Street near Canton Road	25.4	32.0
5	14/1/2015 6:49	Near No.11 Tsing Yi Heung Sze Wui Road, Tsing Yi	Not affected	20.0
6	15/1/2015 5:28	Choi Hung Road near Rhythm Garden	16.7	Unknown
7	23/1/2015 14:08	No. 31-32 Chui Yi Street, Tai Po	15.9	28.6
8	27/1/2015 19:25	Aberdeen Main Road near Light Pole No. 26718, Aberdeen	7.3	25.0
9	29/1/2015 6:54	Connaught Road Central near Gilman Street, Central	19.5	Unknown
10	5/2/2015 6:19	Tsun Wen Road near Light Pole No. Fb9415	11.5	Unknown
11	9/2/2015 3:52	Canton Road near Haiphong Road	16.8	38.0
12	13/2/2015 7:43	No. 1 Waterloo Road	14.2	Unknown
13	24/2/2015 8:32	No.51 Container Port Road, Kwai Chung	20.0	Unknown
14	28/2/2015 4:29	Tolo Highway, Shatin	27.0	30.7
15	28/2/2015 8:12	No. 85 Wo Tong Tsui Street, Kwai Chung	14.8	14.0
16	9/3/2015 13:51	Container Port Road near Light Pole No. Fc1379, Kwai Chung	10.0	Unknown
17	9/3/2015 16:31	Mau Yip Road near Light Pole No. Eb0222, Tseung Kwan O	6.6	21.7
18	17/3/2015 5:12	Tai Yau Street near Ng Fon Street	Not affected	Unknown
19	28/3/2015	Hong Ning Road near Wo	7.3	Unknown

No.	Date and Time	Location	Water Supply Interruption (hour)	Age of Water Main (Note 1)
	0:34	Hong Path		
20	28/3/2015 5:43	No. 1-7 Man Cheong Street	Not affected	Unknown
21	31/3/2015 18:37	No. 22 Yuk Yat Street	22.2	Unknown
22	1/4/2015 11:29	Kam Wa Street near Light Pole No. 34958	4.0	21.0
23	6/4/2015 11:46	Bulkeley Street near Gillies Avenue South	11.3	Unknown
24	6/4/2015 14:12	Bulkeley Street near Marsh Street	9.9	Unknown
25	11/4/2015 5:50	Cheung Sha Wan Road near Un Chau Estate	8.6	Unknown
26	18/4/2015 14:48	No. 104 Connaught Road West, Central	Not affected	17.0
27	22/4/2015 2:48	Hong Ning Road near Kung Lok Road	19.3	Unknown
28	29/4/2015 9:59	No. 75 Lok Shan Road	43.8	16.0
29	10/5/2015 19:10	Fat Kwong Street near Sheung Foo Street	20.8	15.0
30	21/5/2015 11:19	No. 8 Wyndham Street, Central	8.5	21.0
31	26/5/2015 6:49	Choi Hung Road near Shatin Pass Road	21.4	Unknown
32	1/6/2015 22:16	No. 1 Tai Wing Avenue	7.0	Unknown
33	4/6/2015 16:20	Junction of Sha Tsui Road & Chung On Street, Tsuen Wan	Not affected	Unknown
34	7/6/2015 12:43	Wai Yip Street Near Siu Yip Street	Not affected	Unknown
35	10/6/2015 20:55	Kai Cheung Road near Wang Kwong Road	Not affected	32.0
36	13/6/2015 7:27	Junction of Science Museum Road and Granville Road	11.4	Unknown
37	23/6/2015 10:50	Luard Road near Light Pole No. 24508	12.8	28.0
38	25/6/2015 14:48	Ma Tau Chung Road near Mok Cheong Street	13.9	16.0
39	30/6/2015 11:27	Tsui Lam Road near Hong Sing Gardens, Tseung Kwan O	4.8	26.0
40	3/7/2015	Mody Road near Chatham	20.3	Unknown

No.	Date and Time	Location	Water Supply Interruption (hour)	Age of Water Main (Note 1)
	4:08	Road South		
41	4/7/2015 8:40	Plover Cove Road near Light Pole No. 6022, Tai Po	9.0	32.0
42	4/7/2015 14:24	Sun Sing Street near Shau Kei Wan Road	11.9	Unknown
43	8/7/2015 19:37	Backlane of No. 5-9 Tsz Wah Lane	4.3	7.0
44	16/7/2015 14:07	Lung Tak Street near Light Pole No. FC3727, Tsuen Wan	13.2	Unknown
45	17/7/2015 14:56	Plover Cove Road near Kwong Fuk Football Ground, Tai Po	Not affected	32.0
46	17/7/2015 16:40	Sai Wan Ho Street near Light Pole No. 44793	Not affected	22.0
47	18/7/2015 22:12	Bulkeley Street near Kun Yam Street	Not affected	Unknown
48	19/7/2015 5:44	No. 69C Waterloo Road	6.3	Unknown
49	25/7/2015 12:51	Ting Kok Road near Light Pole No. EB0396, Tai Po	11.3	29.1
50	30/7/2015 2:37	Junction Road near Carpenter Road	20.5	Unknown
51	1/8/2015 13:10	Junction of Argyle Street and Sai Yee Street	11.3	Unknown
52	6/9/2015 1:03	Tsing Wun Road near Light Pole No. Fc3773	20.3	34.0
53	9/9/2015 17:25	Hiu Kwong Street near Bus Terminus	Not affected	Unknown
54	17/9/2015 4:01	Wui Cheung Road near Canton Road	44.3	17.0
55	21/9/2015 8:56	Junction of Canton Road and Wui Cheung Road	15.6	30.0
56	24/9/2015 16:16	Ting Kok Road near Light Pole No. EB5685, Tai Po	5.1	19.0
57	29/9/2015 19:38	Bulkeley Street near Whampoa Street	Not affected	Unknown
58	2/10/2015 8:05	Hung Luen Road near Kin Wan Street	14.2	14.0
59	7/10/2015 12:01	Serenity Park near Light Pole No. EA7243, Tai Po	42.6	28.0
60	17/10/2015 15:31	Texaco Road near Light Pole No. Fb1805, Kwai Chung	12.0	Unknown

No.	Date and Time	Location	Water Supply Interruption (hour)	Age of Water Main (Note 1)
61	21/10/2015 16:02	Yuen Shin Park near Light Pole No. Ea8044, Tai Po	30.0	27.3
62	29/10/2015 2:32	San Shan Road near Pak Tai Street	8.8	Unknown
63	4/11/2015 2:23	Tai Kwai Street near Light Pole No. M7479, Tai Po	12.7	29.4
64	4/11/2015 20:06	No. 33C Portland Street	Not affected	Unknown
65	8/11/2015 5:10	Castle Peak Road near Tuen Hing Road	18.4	19.0
66	9/11/2015 4:10	Fu Ning Street near Shing Tak Street	11.5	Unknown
67	14/11/2015 10:35	Dai Fuk Street near Light Pole No. Eb5685, Tai Po	21.8	19.0
68	15/11/2015 10:46	Kwai Fuk Road near Light Pole No. Dc0100, Kwai Chung	Not affected	Unknown
69	24/11/2015 14:45	Ting Kok Road near Light Pole No. Eb2815, Tai Po	54.0	27.4
70	7/12/2015 15:59	Sha Tin Wai Road near Sha Kok Street, Sha Tin	7.6	33.5
71	8/12/2015 1:31	Lai Chi Kok Road near Tonkin Street.	Not affected	27.0
72	9/12/2015 14:13	Ting Kok Road near Light Pole No. Be1883, Tai Po	Not affected	22.6
73	14/12/2015 18:06	No. 90 Kung Lok Road	5.2	16.0
74	15/12/2015 3:34	Woh Chai Street near Nam Cheong Street	9.0	Unknown
75	16/12/2015 15:52	Nga Tsin Long Road near Nga Tsin Wai Road	34.0	Unknown
76	29/12/2015 7:17	Shan King Estate near King On House	11.0	8.0
77	5/1/2016 0:42	Tak On House, Tsueng Kwan O	13.0	25.5
78	13/1/2016 3:25	Lai Yip Street near Hoi Bun Road	29.0	Unknown
79	19/1/2016 13:06	Hiu Kwong Street near Hiu Lai Court	15.9	34.0
80	20/1/2016 5:19	Plover Cove Road, Tai Po	13.6	27.0
81	26/1/2016 4:03	Hip Wo Street near Hiu Kwong Street	77.3	Unknown

No.	Date and Time	Location	Water Supply Interruption (hour)	Age of Water Main (Note 1)
82	28/1/2016 17:26	Tai Po Road near Berwick Street Sitting Out Area	Not affected	Unknown
83	29/1/2016 12:54	Fat Kwong Street near Yan Man House	12.0	Unknown
84	31/1/2016 15:20	Fu Ning Street near Shing Tak Street	40.3	17.0
85	1/2/2016 8:28	Yeung Uk Road near Texaco Road, Kwai Chung	16.6	Unknown
86	3/2/2016 3:12	Hiu Kwong Street near Hiu Lai Court	29.4	20.0
87	5/2/2016 8:21	Yau Ma Tei Public Cargo Working Area, Hoi Fai Road	7.8	23.0
88	11/2/2016 12:55	Hoi Bun Road near Lai Yip Street	40.8	22.0
89	20/2/2016 3:37	Lok Shan Road near Mei King Street	Not affected	17.0
90	20/2/2016 13:59	Ngan Shing Street near Tak Wing Street, Sha Tin	Not affected	Unknown
91	27/2/2016 16:46	No. 81 Bulkeley Street	Not affected	28.0
92	1/3/2016 22:33	Wo Yi Hop Road near Light Pole No. Fa9987, Kwai Chung	6.4	19.0
93	9/3/2016 13:24	Sau Mau Ping Salt Water Pumping Station	Not affected	Unknown
94	12/3/2016 3:15	To Kwa Wan Road near San Ma Tau Street	12.8	Unknown
95	18/3/2016 2:29	Wo Yi Hop Road near Light Pole No. Cc1224, Kwai Chung	26.2	Unknown
96	23/3/2016 6:27	No.71-81 Container Port Road, Kwai Chung	7.6	Unknown
97	31/3/2016 2:31	Jaffe Road near Light Pole No. 24537	5.8	26.0
98	7/4/2016 15:23	Site of Kwong Lee Road near Fat Tseung Street	3.8	Unknown
99	12/4/2016 3:55	To Kwa Wan Road near Lok Shan Road	9.8	Unknown
100	12/5/2016 11:38	Nam Wan Road near Light Pole No. Ce1876	Not affected	9.9
101	15/5/2016 12:39	Junction of Hip Wo Street and Hiu Kwong Street	9.5	Unknown

No.	Date and Time	Location	Water Supply Interruption (hour)	Age of Water Main (Note 1)
102	24/5/2016 10:33	Kwok Shui Road near Light Pole No. W1531, Tsuen Wan	12.3	36.0
103	28/5/2016 13:32	Kai Cheung Road near Wang Kwong Road	Not affected	Unknown
104	12/6/2016 6:02	Lei Muk Road near Light Pole No. Fb2948, Kwai Chung	Not affected	24.0
105	16/6/2016 4:20	Yeung Uk Road near Light Pole No. Dc1786, Tsuen Wan	46.7	21.0
106	22/6/2016 0:17	Ting Kok Road near Light Pole No. De0068, Tai Po	20.9	23.0
107	24/6/2016 12:36	Po Heung Street, Tai Po	15.5	33.0
108	4/7/2016 3:23	No. 14-18 Austin Avenue	43.8	Unknown
109	18/7/2016 12:24	Princess Margaret Road near Pui Ching Road	45.3	Unknown
110	2/8/2016 6:35	Tsing Luk Street near Light Pole No. Fc2256, Tsing Yi	12.1	28.0
111	4/8/2016 14:34	Junction of Nam Wan Road and Tat Wan Road	16.5	28.0
112	7/8/2016 15:08	No.2 Shing Mun Road, Tsuen Wan	5.3	8.0
113	8/8/2016 13:15	Electric Road near Light Pole No. 45115	2.6	Unknown
114	7/9/2016 6:51	Kwai Yan Road near Kwai Fong MTR Station, Kwai Chung	37.3	Unknown
115	5/10/2016 14:11	Junction of Ma On Shan Road and Sai Sha Road, Ma On Shan	14.4	28.0
116	13/10/2016 5:27	Sai Sha Road near Light Pole No. Be3462, Mo On Shan	14.4	27.0
117	18/10/2016 18:04	No. 54 Waterloo Road	10.7	Unknown
118	20/10/2016 21:07	Fat Kwong Street near Sheung Fu Street	Not affected	Unknown
119	24/10/2016 6:54	Un Chau Street near Pei Ho Street	32.8	46.0
120	29/10/2016 9:26	No. 1 Yee Shing Street, Chai Wan	8.7	Unknown
121	31/10/2016 9:35	Hung Hom Road near Tak Hong Street	Not affected	17.0

No.	Date and Time	Location	Water Supply Interruption (hour)	Age of Water Main (Note 1)
122	2/11/2016 18:29	No.31 Tin Hau Temple Road	6.5	16.0
123	14/11/2016 16:55	King's Road near Light Pole No. 43493	Not affected	Unknown
124	16/11/2016 23:24	Mody Road near Kowloon Shangri-La Hotel	8.3	Unknown
125	30/11/2016 16:10	Dai King Street near Light Pole No. Ea7540	11.9	Unknown
126	4/12/2016 19:49	Tsat Tsz Mui Road near Fire Hydrant No. Ph166	3.7	Unknown
127	20/12/2016 5:50	Heng On Estate near Hang Hong Street, Ma On Shan	Not affected	26.0
128	28/12/2016 12:00	Ting Tai Road near Light Pole No. Ea7295	20.8	29.5
129	4/1/2017 4:18	Lei Muk Road near Wo Yi Hop Road, Kwai Chung	Not affected	24.0
130	6/1/2017 15:20	Fook Yum Road near Electric Road	6.3	13.2
131	8/1/2017 14:43	Wo Yi Hop Road junction Tai Loong Street, Kwai Chung	13.8	Unknown
132	15/1/2017 5:59	Wu Chui Road near Light Pole No. FA2689	10.0	31.0
133	17/1/2017 2:34	Tsing Lun Road near Tsun Wen Road, near Siu Hin Court	8.7	29.0
134	17/1/2017 2:59	Sunshine City Phase 2, near On Luk Street, Ma On Shan	77.5	30.6
135	1/3/2017 3:00	Ting Kok Road near Light Pole No. EA8525, Tai Po	9.7	20.5
136	8/3/2017 18:43	Castle Peak Road near Light Pole No. FA 6095, Kwai Chung	Not affected	Unknown
137	14/3/2017 3:51	Dai Hei Street near Light Pole No. EA7498	59.8	29.7
138	18/3/2017 2:19	Hennessy Road near Light Pole No. 33659	7.8	22.0
139	6/4/2017 5:32	Un Chau Street near Tonkin Street	8.0	46.8
140	14/4/2017 10:00	Power Street near Electric Road	7.7	29.0
141	16/4/2017 8:43	Tak Hong Street near Tak Ting Street	Not affected	18.0

No.	Date and Time	Location	Water Supply Interruption (hour)	Age of Water Main (Note 1)
142	18/4/2017 2:05	Wu Chui Road near Light Pole No. H4885	11.7	Unknown
143	18/4/2017 9:39	Connaught Road West near Water Street, Sai Ying Pun	Not affected	Unknown
144	18/4/2017 16:03	Kwun Tong Road near the junction of Choi Shek Lane	Not affected	11.0
145	19/4/2017 0:03	Lung Mun Road near Light Pole No. FA2782	29.1	35.0
146	25/4/2017 3:03	Ching Tak Street near Lung Cheung Road	Not affected	9.0
147	16/5/2017 3:01	Sheung Shing Street near Sheung Lok Street	16.1	Unknown
148	19/5/2017 5:34	No. 137 Sai Wan Ho Street	Not affected	24.0
149	31/5/2017 1:47	Waterloo Road near Canton Road	Not affected	Unknown
150	4/6/2017 3:11	Fu Ning Street near Shing Tak Street	Not affected	19.0
151	10/6/2017 16:32	Connaught Road Central near Rumsey Street	Not affected	Unknown
152	22/6/2017 19:12	No. 38 Cloud View Road	85.3	10.0
153	13/7/2017 18:17	No.17 Pak Tai Street	Not affected	18.0
154	17/7/2017 22:07	Kwai Fuk Road near Light Pole No. FA9728, Kwai Chung	30.7	Unknown
155	23/7/2017 1:11	Container Port Road near Light Pole No. FC1379, Kwai Chung	Not affected	Unknown
156	28/7/2017 5:41	Kwai Shing Circuit near Light Pole No. FA9806, Kwai Chung	7.7	Unknown
157	4/8/2017 5:43	Kwai Hing Road near MTR Station, Kwai Chung	13.3	Unknown
158	8/8/2017 21:08	Opposite No. 43 Tsun Yip Street	Not affected	Unknown
159	10/8/2017 15:35	Tolo Highway near Chainage 9.15, Sha Tin	10.0	10.2
160	12/8/2017 12:03	Sai On Street near Light Pole No. 44710, Aberdeen	10.8	Unknown
161	18/8/2017 10:53	Tsuen Wan Market Street near Light Pole No. AC1986,	1.3	Unknown

No.	Date and Time	Location	Water Supply Interruption (hour)	Age of Water Main (Note 1)
		Tsuen Wan		
162	29/8/2017 13:14	Chik Fai Street near Light Pole No. N1495, Tai Wai, Shatin	15.5	35.0
163	29/8/2017 13:19	No. 53-55 Ngau Tau Kok Road	24.5	Unknown
164	8/9/2017 7:27	Nga Chuk Street near Light Pole No. AA4986	17.8	17.0
165	10/9/2017 6:30	Canton Road near Wui Cheung Road	4.7	Unknown
166	15/9/2017 3:23	Cheung Wing Road near Light Pole No. FA6348, Kwai Chung	Not affected	Unknown
167	23/9/2017 23:02	Hui Kwong Street near Sau Mau Ping Road	18.0	Unknown
168	13/10/2017 4:03	Hoi Bun Road near Kai Hing Road	Not affected	Unknown
169	13/10/2017 5:17	Lung Mun Road near Light Pole No. AD0417	12.3	18.0
170	25/10/2017 14:01	Opposite of No.83, Kung Lok Road, Kwun Tong	9.2	Unknown
171	31/10/2017 16:15	Jaffe Road junction O'Brien Road	6.3	Unknown
172	1/11/2017 0:16	Nam On Street junction Sun Sing Street, Shau Kei Wan	4.0	24.0
173	3/11/2017 5:03	No. 216-218 Texaco Road, Tsuen Wan	Not affected	32.0
174	9/11/2017 5:22	South Bound of Tai Po Road-Sha Tin near Chainage 8.0, Sha Tin	24.3	33.4
175	13/11/2017 5:34	Kansu Street near Ferry Street	26.3	32.0
176	22/11/2017 8:00	No. 139 Hennessy Road	4.1	28.0
177	7/12/2017 11:40	Shing Mun Road near Light Pole No. V3871, Kwai Chung	31.3	Unknown
178	19/12/2017 2:40	Lung Mun Road near Light Pole No. FC3459, Tuen Mun	18.7	31.0
179	20/12/2017 4:16	No.1 Po Tai Street near Block 3 Ocean View, Ma On Shan	9.7	17.2
180	21/12/2017 16:08	Hung Mui Kuk Road, Tai Wai	Not affected	34.5

Note 1: “Unknown” denotes no record of age of the water main. The year of completion was not incorporated in WSD’s water mains record in the past until early eighties. Hence, the age of these water mains will likely be over 30 years.

- End -

CONTROLLING OFFICER'S REPLY

DEVB(W)182

(Question Serial No. 5218)

Head: (194) Water Supplies Department

Subhead (No. & title): Not Specified

Programme: (1) Water Supply: Planning and Distribution

Controlling Officer: Director of Water Supplies (C L WONG)

Director of Bureau: Secretary for Development

Question:

According to the figures released by the Hong Kong Government, the water lost from inside services in buildings and government water supply networks in 2017 was 29%. It shows that the facilities of water supply are ageing. Does the Administration have plans to replace the aged facilities of water supply? If yes, what are the details?

Asked by: Hon TAM Man-ho, Jeremy (Member Question No. (LegCo use): 612)

Reply:

Due to the hilly terrain of Hong Kong, the operating pressure in our water supply networks is generally higher than that of other cities. Together with vibration and disturbance caused by busy traffic and frequent roadworks, there is a higher risk of water mains bursts and leaks in the water supply networks in Hong Kong.

The 29% "water loss" mentioned in the question actually means the "unmetered consumption" which includes water used for fire fighting and operation of waterworks (such as plant water used in water treatment works, cleansing of service reservoirs/water tanks and flushing of government water mains, augmentation of the salt water flushing systems, temporary water supply due to emergency repairs, etc.), recording of lower water consumption by aging water meters, unlawful taking of water as well as leakage in the government and private water mains.

On tackling water loss in the government water supply networks, the Water Supplies Department (WSD) is implementing the Water Intelligent Network (WIN) by stages. With the WIN, we can collect data from the water supply networks by establishing District Metering Areas (DMAs) and Pressure Management Areas (PMAs). Furthermore, the procurement of an Intelligent Network Management System (INMS) is in progress. The main function of the INMS is to continuously monitor and analyse the vast amount of network data collected from DMAs and PMAs. The WIN therefore enables us to timely determine any abnormal condition in the water supply networks and take the most appropriate network management measures (including water pressure management, active

detection and control of leakage, quality and prompt repair, and reprovisioning of water mains) and set the work priorities accordingly.

Given the much improved condition of the water supply networks after the substantial completion of the programme of replacement and rehabilitation of 3 000 kilometres aged water mains in end 2015, WSD considers that it will be more effective to sustain the healthiness of the network by a continuous risk-based assessment of the water mains to determine the need for improvement works including reprovisioning. The risk-based assessment comprises a review of the consequence and probability of failure of the water mains which takes into account various factors such as population and customers served, location, material, age, failure record, pipe size, etc. Based on the risk-based approach, a total of about 40 kilometres of water mains of high-risk or repeated failures will be reprovisioned in 2018-19.

As for water loss in private water mains, WSD has been installing master meters for building developments to monitor water loss and will follow up on suspected cases. According to the Waterworks Ordinance (Cap. 102), it is the responsibility of registered agents (usually management agents) to rectify any water loss in their water mains. WSD will provide necessary technical advice to assist property owners and registered agents on leak detection and maintenance of their water mains. WSD will also assist the development of a market in leak detection and maintenance of water mains, so that a professional and competitive leak detection and maintenance service can be provided to property owners and registered agents.

Furthermore, WSD will step up enforcement actions in accordance with the Waterworks Ordinance (Cap. 102) on those property owners or registered agents who are not cooperative to rectify water loss in their communal water mains. WSD will also explore imposing water charges on property owners or registered agents for the amount of water loss from their communal water mains based on master meter readings through legislative amendments.

- End -

CONTROLLING OFFICER'S REPLY

DEVB(W)183

(Question Serial No. 5219)

Head: (194) Water Supplies Department

Subhead (No. & title): Not Specified

Programme: (2) Water Quality Control

Controlling Officer: Director of Water Supplies (C L WONG)

Director of Bureau: Secretary for Development

Question:

Did the Administration allocate funding to conduct studies on drinking water safety over the past 5 years? If yes, please list the studies in table format.

Asked by: Hon TAM Man-ho, Jeremy (Member Question No. (LegCo use): 613)

Reply:

The studies conducted in the past five years on drinking water safety are tabulated below:

Item No.	Title of study
1.	Consultancy study on the development of Water Safety Plan for Buildings for Hong Kong
2.	Consultancy study on the review of drinking water standards and sampling protocols (metal parameters)
3.	Improvement on Cryptosporidium & Giardia (C&G) monitoring at water treatment works
4.	Consultancy study on the review of drinking water standards (non-metal parameters)
5.	Consultancy study on organophosphate flame retardants (OPFRs) and perfluoroalkyl substances (PFASs)
6.	Consultancy service on enhancement of Drinking Water Quality Management System and development of guidelines and templates for Water Safety Plan for Buildings for specific types of developments (e.g. schools, elderly homes)

The expenditure for conducting the above studies is \$3.9 million.

- End -

CONTROLLING OFFICER'S REPLY

DEVB(W)184

(Question Serial No. 5220)

Head: (194) Water Supplies Department
Subhead (No. & title): Not Specified
Programme: (2) Water Quality Control
Controlling Officer: Director of Water Supplies (C L WONG)
Director of Bureau: Secretary for Development

Question:

The information of the Water Supplies Department (WSD) mentions that: the WSD takes 170 000 water samples from different parts of water supply systems every year to test all the parameters related to water safety, including their chemical, bacterial and radioactive concentration. It also mentions that drinking water samples taken from water reservoirs, untreated Dongjiang water, treated water from service reservoirs, drinking water from the water supply systems and water drawn from consumers' taps in households are tested. Are these testing parameters and related test statistics publicised to the public? If yes, what are the details?

Asked by: Hon TAM Man-ho, Jeremy (Member Question No. (LegCo use): 614)

Reply:

The Water Supplies Department (WSD) monitors the water quality of the entire water supply system systematically by means of physical, chemical, bacteriological, biological and radiological examinations of water samples taken at catchment, intakes, receiving point of Dongjiang water at Muk Wu Pumping Station, impounding reservoirs, water treatment works, service reservoirs, distribution systems and publicly accessible consumer taps. The rolling 12-month statistics of the key test results of the water samples are updated half-yearly and published on the WSD's website.

In addition, the WSD commenced the enhanced water quality monitoring programme (Enhanced Programme) in December 2017 to monitor the drinking water quality at consumers' taps and collect local water quality data for review of the Hong Kong Drinking Water Standards for six metals, namely antimony, cadmium, chromium, copper, lead and nickel that could be present in an internal plumbing system. The statistics of the test results of the water samples collected under the Enhanced Programme are uploaded to the WSD's website on a weekly basis.

- End -

CONTROLLING OFFICER'S REPLY

DEVB(W)185

(Question Serial No. 5223)

Head: (194) Water Supplies Department

Subhead (No. & title): Not Specified

Programme: (2) Water Quality Control

Controlling Officer: Director of Water Supplies (C L WONG)

Director of Bureau: Secretary for Development

Question:

- (a) On what criteria does the Water Supplies Department (WSD) determine the dosage and concentration of the drinking water treatment agents and disinfectants at the moment?
- (b) What are the treatment methods adopted by the WSD's treatment system at the moment? What are the treatment agents used and their components and amounts?
- (c) Is there an adjustment mechanism that functions regularly according to the scientific research published worldwide?

Asked by: Hon TAM Man-ho, Jeremy (Member Question No. (LegCo use): 617)

Reply:

- (a) The Water Supplies Department (WSD) monitors and controls each stage of the water treatment process closely by means of an on-line water quality monitoring system and taking regular water samples for testing to ensure compliance with the performance specifications of the whole treatment process. The dosages of treatment chemicals and disinfectants will be adjusted as necessary according to the monitoring results to ensure that the treated water is in full compliance with the Hong Kong Drinking Water Standards which currently adopt the guideline values / provisional guideline values of the World Health Organization's Guidelines for Drinking-water Quality.
- (b) The treatment process of the water treatment works in Hong Kong mainly comprises coagulation, flocculation, clarification, filtration and disinfection. Alum (aluminum sulphate) is firstly dosed to coagulate impurities in the raw water for removal in the clarification process. In the subsequent filtration process, the clarified water is filtered through granular media filters comprising fine sand and anthracite to remove the residual fine particles. Finally, chlorine and hydrated lime (calcium hydroxide) are dosed to the filtered water for disinfection and pH adjustment respectively, while a

small dose of fluoride is provided for dental protection. During the period from April 2016 to March 2017, the average dosages of alum, chlorine, hydrated lime and fluoride used in the water treatment process were 14 milligram/litre (mg/L), 1.9 mg/L, 9.4 mg/L and 0.32 mg/L respectively. Advanced technologies such as ozonation together with biological filters are also adopted in some water treatment works for reduction of chlorine dosage and removal of organic carbon and ammonia in the raw water.

- (c) The WSD has established and implemented since July 2017 the Drinking Water Quality Management System (DWQMS). Under the DWQMS, the WSD will carry out assessment of the entire drinking water supply system to identify potential risks and devise corresponding control measures. Also, the WSD, with assistance from consultants, will keep track with the latest worldwide development on water treatment, and review regularly the DWQMS for making adjustment or improvement of the water treatment process as appropriate.

- End -

CONTROLLING OFFICER'S REPLY

DEVB(W)186

(Question Serial No. 5502)

Head: (194) Water Supplies Department
Subhead (No. & title): Not Specified
Programme: (2) Water Quality Control
Controlling Officer: Director of Water Supplies (C L WONG)
Director of Bureau: Secretary for Development

Question:

The Water Supplies Department (WSD) has launched the Action Plan on Enhancing Drinking Water Safety in Hong Kong. Regarding the drinking water sampling under the action plan over the past 1 year, would the WSD provide the expenditure, staff establishment, indicators used for measuring drinking water safety, formats of sampling, frequency of sampling, the types of substances covered by the testing indicators for drinking water safety?

Asked by: Hon WONG Kwok-kin (Member Question No. (LegCo use): 30)

Reply:

The Water Supplies Department (WSD) commenced the enhanced water quality monitoring programme (Enhanced Programme) under the Action Plan for Enhancing the Drinking Water Safety in Hong Kong in December 2017 for monitoring the drinking water quality at consumers' taps and collecting local water quality data for review of the Hong Kong Drinking Water Standards which currently adopt the guideline values/provisional guideline values of the World Health Organization's Guidelines for Drinking-water Quality. Under the Enhanced Programme, the WSD will collect water samples from the drinking water taps of 670 randomly selected premises each year to test for the contents of six metals, namely antimony, cadmium, chromium, copper, lead and nickel that could be present in an internal plumbing system.

A sampling team will visit the selected premises on any working day from 9 am to 5 pm to collect water samples. The team comprises a water sampler for collection of water samples and a licensed plumber for collection of plumbing information. Two-tier water samples will be collected from one of the drinking water taps in the premises including a Tier 1 – Random Day Time (“RDT”) water sample and a Tier 2 – 30-minute stagnation

("30MS") water sample. The Tier 2 water sample will only be tested if exceedance is found in the Tier 1 water sample to verify the test result.

At present, the WSD deploys one Senior Waterworks Chemist, two Waterworks Chemists, three Engineering Laboratory Technicians I, six Engineering Laboratory Technicians II, two Laboratory Attendants and two Water Samplers for the implementation of the Enhanced Programme. Additional posts will be created as necessary in 2018-19 in accordance with established mechanism to cater for sampling and testing of additional parameters that may be included in the Enhanced Programme.

The WSD has engaged an independent consultant to select premises for invitation to participate in the Enhanced Programme. The consultant also provides licensed plumbers to serve as members of the sampling teams.

The estimated expenditures for implementing the Enhanced Programme for monitoring the six metals are \$0.75 million and \$2.25 million in 2017-18 and 2018-19 respectively. These figures include the expenditures on (i) chemicals and consumables for collection and analysis of water samples, (ii) engagement of the independent consultant, and (iii) promotion of the Enhanced Programme.

- End -