

Enhanced Water Quality Monitoring Programme

Weekly Monitoring Data of the Six Metals at Consumers' Taps

| Week Ending | Total No. of Samples Taken | Metal Parameter | Monitoring Data ($\mu\text{g/L}$) | | Hong Kong Drinking Water Standards ⁽¹⁾ ($\mu\text{g/L}$) |
|------------------|----------------------------|-----------------|-------------------------------------|---------|---|
| | | | Minimum | Maximum | |
| 2-September-2018 | 14 | Antimony | <1 | <1 | 20 |
| | | Cadmium | <1 | <1 | 3 |
| | | Chromium | <1 | <1 | 50 |
| | | Copper | 3 | 38 | 2000 |
| | | Lead | <1 | 1 | 10 |
| | | Nickel | <1 | 6 | 70 |

Note:

- (1) The Government currently adopts the corresponding guideline values/provisional guideline values in the fourth edition of the World Health Organization's Guidelines for Drinking-water Quality ("WHO Guidelines") published in 2011 as the Hong Kong Drinking Water Standards.