

## Enhanced Water Quality Monitoring Programme

### Weekly Monitoring Data of the Six Metals at Consumers' Taps

Week Ending	Total No. of Samples Taken	Metal Parameter	Monitoring Data ( $\mu\text{g/L}$ )		Hong Kong Drinking Water Standards <sup>(1)</sup> ( $\mu\text{g/L}$ )
			Minimum	Maximum	
17-March-2019	14	Antimony	<1	<1	20
		Cadmium	<1	<1	3
		Chromium	<1	<1	50
		Copper	4	39	2000
		Lead	<1	2	10
		Nickel	1	18	70

Note:

- (1) The Government currently adopts the corresponding guideline values/provisional guideline values in the fourth edition of the World Health Organization's Guidelines for Drinking-water Quality ("WHO Guidelines") published in 2011 as the Hong Kong Drinking Water Standards.