

## Enhanced Water Quality Monitoring Programme

### Weekly Monitoring Data of the Six Metals at Consumers' Taps

| Week Ending    | Total No. of Samples Taken | Metal Parameter | Monitoring Data (µg/L) |         | Hong Kong Drinking Water Standards <sup>(1)</sup><br>(µg/L) |
|----------------|----------------------------|-----------------|------------------------|---------|---|
|                |                            |                 | Minimum                | Maximum |   |
| 11-August-2019 | 13                         | Antimony        | <1                     | <1      | 20  |
|                |                            | Cadmium         | <1                     | <1      | 3   |
|                |                            | Chromium        | <1                     | <1      | 50  |
|                |                            | Copper          | <3                     | 20      | 2000  |
|                |                            | Lead            | <1                     | 1       | 10  |
|                |                            | Nickel          | <1                     | 2       | 70  |

Note:

- (1) The Government currently adopts the corresponding guideline values/provisional guideline values in the fourth edition of the World Health Organization's Guidelines for Drinking-water Quality ("WHO Guidelines") published in 2011 as the Hong Kong Drinking Water Standards.