Enhanced Water Quality Monitoring Programme Weekly Monitoring Data of the Six Metals at Consumers' Taps

Week Ending	Total No. of	Metal Parameter	Monitoring Data (μg/L)		Drinking Water Standards ⁽¹⁾
	Samples Taken		Minimum	Maximum	Standards (μg/L)
25-February-2018	14	Antimony	<1	<1	20
		Cadmium	<1	<1	3
		Chromium	<1	<1	50
		Copper	<3	120	2000
		Lead	<1	<1	10
		Nickel	<1	5	70

Note:

(1) The government has adopted the corresponding guideline values/provisional guideline values in the fourth edition of the World Health Organization's Guidelines for Drinking-water Quality ("WHO Guidelines") published in 2011 as the Drinking Water Standards of Hong Kong.