

Enhanced Water Quality Monitoring Programme

Weekly Monitoring Data of the Six Metals at Consumers' Taps

Week Ending	Total No. of Samples Taken	Metal Parameter	Monitoring Data ($\mu\text{g/L}$)		Hong Kong Drinking Water Standards ⁽¹⁾ ($\mu\text{g/L}$)
			Minimum	Maximum	
26-January-2020	14	Antimony	<1	<1	20
		Cadmium	<1	<1	3
		Chromium	<1	<1	50
		Copper	<3	53	2000
		Lead	<1	<1	10
		Nickel	<1	4	70

Note:

- (1) The Government currently adopts the corresponding guideline values/provisional guideline values in the fourth edition of the World Health Organization's Guidelines for Drinking-water Quality ("WHO Guidelines") published in 2011 as the Hong Kong Drinking Water Standards.