

## Enhanced Water Quality Monitoring Programme

### Weekly Monitoring Data of the Six Metals at Consumers' Taps

| Week Ending     | Total No. of Samples Taken | Metal Parameter | Monitoring Data (µg/L) |         | Hong Kong Drinking Water Standards <sup>(1)</sup><br>(µg/L) |
|-----------------|----------------------------|-----------------|------------------------|---------|---|
|                 |                            |                 | Minimum                | Maximum |   |
| 7-February-2021 | 15                         | Antimony        | <1                     | <1      | 20  |
|                 |                            | Cadmium         | <1                     | <1      | 3   |
|                 |                            | Chromium        | <1                     | <1      | 50  |
|                 |                            | Copper          | 3                      | 170     | 2000  |
|                 |                            | Lead            | <1                     | <1      | 10  |
|                 |                            | Nickel          | 1                      | 19      | 70  |

Note:

- (1) The Government currently adopts the corresponding guideline values/provisional guideline values in the fourth edition of the World Health Organization's Guidelines for Drinking-water Quality ("WHO Guidelines") published in 2011 as the Hong Kong Drinking Water Standards.