

Enhanced Water Quality Monitoring Programme

Weekly Monitoring Data of the Six Metals at Consumers' Taps

| Week Ending | Total No. of Samples Taken | Metal Parameter | Monitoring Data (µg/L) | | Hong Kong Drinking Water Standards ⁽¹⁾ (µg/L) |
|---------------|----------------------------|-----------------|------------------------|---------|---|
| | | | Minimum | Maximum | |
| 28-March-2021 | 10 | Antimony | <1 | <1 | 20 |
| | | Cadmium | <1 | <1 | 3 |
| | | Chromium | <1 | <1 | 50 |
| | | Copper | 4 | 78 | 2000 |
| | | Lead | <1 | 3 | 10 |
| | | Nickel | <1 | 3 | 70 |

Note:

- (1) The Government currently adopts the corresponding guideline values/provisional guideline values in the fourth edition of the World Health Organization's Guidelines for Drinking-water Quality ("WHO Guidelines") published in 2011 as the Hong Kong Drinking Water Standards.