

# Enhanced Water Quality Monitoring Programme

## Weekly Monitoring Data of the Six Metals at Consumers' Taps

Week Ending	Total No. of Samples Taken	Metal Parameter	Monitoring Data (µg/L)		Hong Kong Drinking Water Standards (µg/L)
			Minimum	Maximum	
16-May-2021	13	Antimony	<1	<1	20
		Cadmium	<1	<1	3
		Chromium	<1	<1	50
		Copper	<3	55	2000
		Lead	<1	1	10
		Nickel	1	11	70