

## Enhanced Water Quality Monitoring Programme

### Weekly Monitoring Data at Consumers' Taps

Week Ending	Total No. of Sampling Premises	Parameter	Unit	Monitoring Data		Hong Kong Drinking Water Standards
				Minimum	Maximum	
27-June-2021	14	Antimony	µg/L	<1	<1	20
		Cadmium		<1	<1	3
		Chromium		<1	<1	50
		Copper		5	190	2000
		Lead		<1	2	10
		Nickel		1	6	70
		Residual Chlorine	mg/L	<0.1	0.7	5
		<i>Escherichia coli</i>	cfu* /100 mL	0	0	0

\* cfu = Colony forming unit