

## Enhanced Water Quality Monitoring Programme

### Weekly Monitoring Data at Consumers' Taps

| Week Ending     | Total No. of Sampling Premises | Parameter               | Unit         | Monitoring Data |         | Hong Kong Drinking Water Standards |
|-----------------|--------------------------------|-------------------------|--------------|-----------------|---------|------------------------------------|
|                 |                                |                         |              | Minimum         | Maximum |                                    |
| 10-October-2021 | 14                             | Antimony                | µg/L         | <1              | <1      | 20                                 |
|                 |                                | Cadmium                 |              | <1              | <1      | 3                                  |
|                 |                                | Chromium                |              | <1              | <1      | 50                                 |
|                 |                                | Copper                  |              | <3              | 140     | 2000                               |
|                 |                                | Lead                    |              | <1              | <1      | 10                                 |
|                 |                                | Nickel                  |              | 1               | 4       | 70                                 |
|                 |                                | Residual Chlorine       | mg/L         | <0.1            | 0.6     | 5                                  |
|                 |                                | <i>Escherichia coli</i> | cfu* /100 mL | 0               | 0       | 0                                  |

\* cfu = Colony forming unit