

Enhanced Water Quality Monitoring Programme Weekly Monitoring Data at Consumers' Taps

Week Ending	Total No. of Sampling Premises	Parameter	Unit	Monitoring Data		Hong Kong Drinking Water Standards
				Minimum	Maximum	
17-October-2021	10	Antimony	µg/L	<1	<1	20
		Cadmium		<1	<1	3
		Chromium		<1	<1	50
		Copper		<3	94	2000
		Lead		<1	<1	10
		Nickel		1	9	70
		Residual Chlorine	mg/L	<0.1	0.5	5
		<i>Escherichia coli</i>	cfu* /100 mL	0	0	0

* cfu = Colony forming unit