

## Enhanced Water Quality Monitoring Programme

### Weekly Monitoring Data at Consumers' Taps

| Week Ending | Total No. of Sampling Premises | Parameter               | Unit         | Monitoring Data |         | Hong Kong Drinking Water Standards |
|-------------|--------------------------------|-------------------------|--------------|-----------------|---------|------------------------------------|
|             |                                |                         |              | Minimum         | Maximum |                                    |
| 15-May-2022 | 9                              | Antimony                | µg/L         | <1              | <1      | ≤20                                |
|             |                                | Cadmium                 |              | <1              | <1      | ≤3                                 |
|             |                                | Chromium                |              | <1              | <1      | ≤50                                |
|             |                                | Copper                  |              | <3              | 260     | ≤2000                              |
|             |                                | Lead                    |              | <1              | <1      | ≤10                                |
|             |                                | Nickel                  |              | 2               | 6       | ≤70                                |
|             |                                | Residual Chlorine       | mg/L         | <0.1            | 0.6     | ≤5                                 |
|             |                                | <i>Escherichia coli</i> | cfu* /100 mL | 0               | 0       | 0                                  |

\* cfu = Colony forming unit