

Enhanced Water Quality Monitoring Programme

Weekly Monitoring Data at Consumers' Taps

Week Ending	Total No. of Sampling Premises	Parameter	Unit	Monitoring Data		Hong Kong Drinking Water Standards
				Minimum	Maximum	
22-May-2022	15	Antimony	µg/L	<1	<1	≤20
		Cadmium		<1	<1	≤3
		Chromium		<1	<1	≤50
		Copper		<3	140	≤2000
		Lead		<1	<1	≤10
		Nickel		1	12	≤70
		Residual Chlorine	mg/L	0.1	0.8	≤5
		<i>Escherichia coli</i>	cfu* /100 mL	0	0	0

* cfu = Colony forming unit