

## Enhanced Water Quality Monitoring Programme

### Weekly Monitoring Data of the Six Metals at Consumers' Taps

| Week Ending  | Total No. of Samples Taken | Metal Parameter | Monitoring Data (µg/L) |         | Drinking Water Standards <sup>(1)</sup> (µg/L) |
|--------------|----------------------------|-----------------|------------------------|---------|--|
|              |                            |                 | Minimum                | Maximum |  |
| 4-March-2018 | 13                         | Antimony        | <1                     | <1      | 20   |
|              |                            | Cadmium         | <1                     | <1      | 3  |
|              |                            | Chromium        | <1                     | <1      | 50   |
|              |                            | Copper          | <3                     | 42      | 2000   |
|              |                            | Lead            | <1                     | <1      | 10   |
|              |                            | Nickel          | <1                     | 4       | 70   |

Note:

- (1) The government has adopted the corresponding guideline values/provisional guideline values in the fourth edition of the World Health Organization's Guidelines for Drinking-water Quality ("WHO Guidelines") published in 2011 as the Drinking Water Standards of Hong Kong.