

Enhanced Water Quality Monitoring Programme

Weekly Monitoring Data of the Six Metals at Consumers' Taps

| Week Ending | Total No. of Samples Taken | Metal Parameter | Monitoring Data (µg/L) | | Drinking Water Standards ⁽¹⁾ (µg/L) |
|-------------|----------------------------|-----------------|------------------------|---------|--|
| | | | Minimum | Maximum | |
| 20-May-2018 | 14 | Antimony | <1 | <1 | 20 |
| | | Cadmium | <1 | <1 | 3 |
| | | Chromium | <1 | <1 | 50 |
| | | Copper | <3 | 190 | 2000 |
| | | Lead | <1 | 1 | 10 |
| | | Nickel | 1 | 4 | 70 |

Note:

- (1) The government has adopted the corresponding guideline values/provisional guideline values in the fourth edition of the World Health Organization's Guidelines for Drinking-water Quality ("WHO Guidelines") published in 2011 as the Drinking Water Standards of Hong Kong.