



Office of the Water Authority

Immigration Tower
7 Gloucester Road
Hong Kong

水務監督辦事處

香港灣仔
告士打道七號
人民入境事務大樓

Telephone
電話 2829 4446

Facsimile
圖文傳真 2824 0578

Reference
檔號 (41) in WWO 1493/50 VIII

Date
日期 9 February 1996

Distribution: To all Licensed Plumbers and Authorized Persons

Dear Sir,

WSD Circular Letter No. 3/96
Hong Kong Waterworks Standard Requirements (Aug 95)
Amendment No. 1

From now on, application for exemption from Clause 9.11 of the Hong Kong Waterworks Standard Requirements (HKWSR) (Aug 95 Edition) will be considered if it is accompanied by the written endorsement of the Fire Services Department.

In connection with this, HKWSR Clause 9.11 is now amended to read: **'No part of any fire service sprinkler / drencher system supplied from the Government mains shall be used for supplying any other services including other fire service installations, e.g. hose reels, except that a common suction tank can be used for both sprinkler / drencher and hose reel systems. Any exemption from this requirement should have the endorsement of the Director of Fire Services.'**

Yours faithfully,

(CHAN Chi-chiu)
for Water Authority

c.c. WWO 10/3318/75

SKM/CML/CCC