



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (5) in WSD 3318/50 Pt.11 T/J(1)
Our ref.
來函檔號 :
Your ref.

電話 : 2824 5000
Tel.
傳真 : 2824 0578
Fax.

致：所有持牌水喉匠及認可人士

水務署通函第7/2026號
消防供水申請自行認證計劃

水務監督經檢視後，認為由於在消防水缸的入水點處已經把水壓中斷，能有效防止消防水缸內的水倒流入進水管，因此消防水缸下游的管道不會對供水系統造成水安全風險。

2. 為簡化消防供水系統的申請供水流程，水務監督現制定了消防供水申請自行認證計劃（計劃）。為免生疑問，即使採用此計劃，消防裝置的任何部分亦須繼續遵從消防處現行的申請程序及合規要求。

適用性

3. 在計劃下，消防供水系統劃分為兩個部分，即 (i) 第一個消防水缸下游第一個控制閥之前的部分（A部）及 (ii) 第一個消防水缸下游第一個控制閥之後的部分（B部）。計劃僅適用於B部。

4. 作為現行規定及程序的替代方案，計劃適用於符合以下條件的新建建築物項目及現有消防裝置的更換水管工程的消防供水申請：

- (i) 消防供水系統須包括消防水缸；
- (ii) 提交申請的負責持牌水喉匠須是提升管制水喉工程自願參與計劃下之註冊水喉承建商（臨時）¹所委任的獲授權代表；以及
- (iii) 該註冊水喉承建商（臨時）須在申請日期前的兩年內，曾完成至少一項消防供水系統工程，並獲得水務監督簽發的WWO 46第五部分（乙部）。

¹ 詳情見水務署通函第3/2022號補編第一號“提升管制水喉工程自願參與計劃第二階段 - 於水喉工程提供工地監督團隊”。

工作流程

5. 以下表格總結了計劃下B部的主要工作流程。

主要工作流程	
1	<p>提交水管工程建議書：</p> <ul style="list-style-type: none"> • 申請人須提交表格WWO 542及水管工程建議書，當中須標明A部和B部。 • 水務監督滿意後，會根據現行程序向整體消防供水申請（包括A部及B部）給予批准（即WWO 1085）。
2	<p>申請開展水管工程：</p> <ul style="list-style-type: none"> • 負責持牌水喉匠須提交「參加消防供水申請自行認證計劃的通知表格」（附錄A）供水務監督審批。 • 負責持牌水喉匠須提交表格WWO 46A（附錄B）第一部分及第二部分作B部申請。雖然B部喉管及裝置的表格WWO 1149可選擇一起提交，但負責持牌水喉匠須保證擬安裝的喉管及裝置已獲發一般認可，並符合《水務設施條例》、《水務設施規例》及水務監督的要求。 • 水務監督滿意後，會簽發表格WWO 46A第三部分。
3	<p>申請實施供水：</p> <ul style="list-style-type: none"> • 負責持牌水喉匠須在B部的水管工程竣工後，透過表格WWO 46A第四部分向水務監督報告完工，並附上以下證明文件： <ul style="list-style-type: none"> (a) 竣工證書（附錄C）； (b) 竣工圖則； (c) 竣工表格WWO 1149A（附錄D）；以及 (d) 視察清單（附錄E） • 負責持牌水喉匠須在竣工證書中證明該水管工程已根據核准水管工程建議書（包括垂直水管路線圖）及竣工記錄進行，並符合《水務設施條例》、《水務設施規例》及水務監督的要求。

4	<p>水務監督批准供水而毋須視察B部的水管裝置：</p> <ul style="list-style-type: none"> • 水務監督檢查所需的文件是否齊備。 • 水務監督簽發表格WWO 46A第五部分並批准供水，而毋須視察B部的水管裝置。 • 水務監督就A部簽發表格WWO 46第五部分（乙部），及就B部簽發表格WWO 46A第五部分後，向申請人簽發「消防供水完工證明書」（附錄F）。
---	---

合規與監控檢查

6. 為了監察合規情況，水務監督會以風險為本方式抽選個案（例如5%），並安排與負責持牌水喉匠進行現場視察檢查及覆核。

7. 水務監督於現場視察覆核期間，會核實負責持牌水喉匠填妥的檢查清單。倘若不同意視察結果，水務監督會於清單上標明所需的修訂，而水務監督和負責持牌水喉匠須於修訂旁簽署作實。水務監督會隨後向負責持牌水喉匠發出表格WWO 1008² 要求其就有關須修改的項目進行糾正，直至水務監督滿意。

生效日期

8. 上述安排即時生效。

查詢

9. 如有疑問，請致電2829 4574向本署的工程師/技術支援(5)查詢。
水務監督

(原文已簽署)

(葉家駿 代行)

二零二六年四月二十四日

² 該表格是水務監督根據「罰分和記分制度」發給持牌水喉匠，以記錄在現場視察中所發現的不合規之處。

附件

- 附錄 A – 參加消防供水申請自行認證計劃的通知表格
- 附錄 B – 計劃下的表格 WWO 46A
- 附錄 C – 竣工證書
- 附錄 D – 計劃下的表格 WWO 1149A
- 附錄 E – 視察清單
- 附錄 F – 消防供水完工證明書（只有英文版本）

副本存：

房屋署 (經辦人: 高級經理/品質管理)
 屋宇署
 建築署
 消防處
 香港房屋協會
 香港建築師學會
 香港工程師學會
 香港測量師學會
 英國特許水務工程師學會—香港分會
 香港水喉潔具業商會有限公司
 香港持牌水務專業學會
 香港水務專業協會有限公司
 香港給排水學會有限公司
 水務技術同學會
 香港註冊消防工程公司商會有限公司
 香港地產建設商會
 香港建造商會有限公司
 香港建築業承建商聯會有限公司
 香港機電工程商聯會
 承建商授權簽署人協會有限公司
 註冊小型工程承建商簽署人協會有限公司
 香港註冊承建商商會有限公司
 香港專業教育學院
 建造業議會香港建造學院
 香港持牌水喉匠總會有限公司
 香港都會大學李嘉誠專業進修學院
 機電工程協會(香港)有限公司
 管藝坊(國際)有限公司
 香港水務安全學會
 香港喉管從業員總會



水務監督
香港灣仔告士打道 7 號入境事務大樓 43 樓
電話：2824 5000 傳真：2802 7333
電郵：wsdinfo@wsd.gov.hk

參加「消防供水申請自行認證計劃」的通知表格

第一部分 (由申請供水者填寫)

致：水務監督

本人現通知水務監督，本人就以下處所_____的消防水箱後的
第一個控制閥的消防水管工程 (標註為 B 部) 參加消防供水申請自行認證計劃。

水管工程詳情如下：

水務署批函檔號：_____ 日期：_____ 申請書編號：_____

核准圖則的編號：_____

本人委任 _____ (持牌水喉匠名稱) 承接上述水喉工程。

簽署：_____ 姓名：_____

(申請供水人士)

電話號碼：_____ 傳真號碼：_____

通訊地址：_____

電郵地址：_____

_____ 日期：_____

公司蓋章 (如適用)

*請刪去不適用者



水務監督
香港灣仔告士打道 7 號入境事務大樓 43 樓
電話：2824 5000 傳真：2802 7333
電郵：wsdinfo@wsd.gov.hk

第二部分（由註冊水喉承建商（臨時）和負責持牌水喉匠填寫）

致：水務監督

供水申請人（姓名）_____委託我們進行上述第一部份所述的水喉工程。

我們將提供現場監督團隊，對水喉工程進行持續監督。現附上水喉工程的現場監督計劃書。

我們確認簽署表格 WWO 46A 的負責持牌水喉匠是我們的獲授權代表，並負責領導現場監督團隊。

請注意以下本通知前兩年已完成的並獲得水務監督發出的 WWO46 第五部分（乙部）消防水管工程項目：

註冊水喉承建商（臨時）

註冊號碼：_____

註冊水喉承建商（臨時）名稱：_____

獲授權代表姓名：_____

電話號碼：_____ 電郵：_____

傳真號碼：_____ 地址：_____

註冊水喉承建商（臨時）簽署@：_____

日期：_____

@由授權代表代表註冊水喉承建商（臨時）簽署

致：水務監督

我確認本人為以上註冊水喉承建商（臨時）的獲授權代表，並負責領導現場監督團隊。

簽署表格 WWO46A 的負責持牌水喉匠

水喉匠牌照號碼：_____

姓名：_____

簽署：_____

日期：_____



申請建造、安裝、更改或拆除
內部供水系統或消防供水系統

根據《水務設施條例》(第 102 章) 第 14 條及《水務設施規例》(第 102A 章) 第 3/5 條

第一部分 (由持牌水喉匠填寫) (見附註1)

致：水務監督

有關下列地址的處所的內部供水系統或消防供水系統

*我/我們受填寫下文第二部分的*用戶#/代理人#/初次申請供水人士所聘用，負責*建造/安裝/更改/拆除上址的*內部供水系統/消防供水系統。有關內部供水系統/消防供水系統的核准水管工程計劃(「核准水管計劃」)詳情如下：

水務署批函檔號：_____ 日期：_____ 申請書編號：_____

核准圖則的編號(如無需圖則，請簡述水管工程)：_____

涉及/所需水錶的尺寸和數目：_____

預計需要供水的日期：_____ (見附註4)

備註：_____

2. 遞交表格的目的(見附註2)

*我/我們現向水務監督申請許可於_____年_____月_____日展開本表格所涵蓋在核准水管計劃下的工程的建造、安裝、更改或拆除工作。

*我/我們保證擬安裝/用於建造、安裝、更改或拆除本表格所涵蓋的工程的喉管及裝置已獲發一般認可，並符合《水務設施規例》的規定和水務監督的要求。

* 請刪去不適用者

「用戶」及「代理人」的定義請參照《水務設施條例》第 2 條。



3. *我/我們完全明白並同意水務監督可把從*我/我們收集所得與本申請有關的資料，用於處理本申請和本申請中任何與內部供水系統或消防供水系統的核准建造、安裝、更改或拆除工作有關的跟進行動，或用於與這些方面有直接關連的事宜。如*我/我們沒有提供足夠資料，水務監督可能無法處理 *我/我們的申請。*我/我們同意收集的資料可轉交其他政府決策局及部門[和任何其他相關人士]作上述用途。*我/我們亦同意該等資料(包括持牌水喉匠的姓名和有關處所的詳情)可能會向公眾公開(例如於互聯網發布相同資料)。*我/我們明白可向水務署部門秘書(地址：香港告士打道7號入境事務大樓48樓)要求查閱及更正個人資料。

持牌水喉匠

水喉匠牌照號碼： _____

姓名： _____

簽署： _____

日期： _____

電話號碼： _____

傳真號碼： _____

電郵： _____

僱主公司名稱⁺： _____

僱主商業登記號碼⁺： _____

僱主地址： _____

擬選擇的聯絡方式：*郵遞/電郵/傳真

⁺持牌水喉匠須提供聘用他/她的公司/承建商名稱、商業登記號碼和地址。

* 請刪去不適用者
「用戶」及「代理人」的定義請參照《水務設施條例》第2條。



第二部分 (由用戶#/代理人#/初次申請供水人士填寫) (見附註1)

致：水務監督

本人現簽認所聘用持牌水喉匠*在第一部分遞交的資料。

本人完全明白並同意水務監督可把從本人收集所得與本申請有關的資料，用於處理本人聘用持牌水喉匠的申請和本申請中任何與內部供水系統或消防供水系統的核准建造、安裝、更改或拆除工作有關的跟進行動，或用於與這些方面有直接關連的事宜。如本人沒有提供足夠資料，水務監督可能無法處理本人聘用持牌水喉匠的申請。本人同意收集的資料可轉交其他政府決策局及部門和任何其他相關人士作上述用途。本人亦同意有關處所的名稱可能會向公眾公開(例如於互聯網發布相同資料)作上述用途。本人明白可向水務署部門秘書(地址：香港告士打道7號入境事務大樓48樓)要求查閱及更正本人的個人資料。

簽署： _____ 姓名： _____
(*用戶#/代理人#/初次申請供水人士)

電話號碼： _____

傳真號碼： _____

公司蓋章： _____ 地址： _____
(如適用)

日期： _____

* 請刪去不適用者
「用戶」及「代理人」的定義請參照《水務設施條例》第2條。



第三部分 (由水務監督填寫)

致：持牌水喉匠
持牌水喉匠的郵寄地址

致：用戶／代理人／申請人
用戶／代理人／申請人的郵寄地址

現准許你進行本表格所涵蓋在核准水管計劃下的工程。

_____ 姓名： _____
(代水務監督簽署)

_____ 職位： _____

_____ 電話號碼： _____

_____ 日期： _____ 傳真號碼： _____



第四部分 (由持牌水喉匠填寫) (見附註6)

致：水務監督

申請書編號： _____

本表格所涵蓋在核准水管計劃下的全部工程(請註明及遞交有關圖則： _____
_____)已於_____年_____月_____日竣工並且可供檢
查。

本人現向你申請批准上述工程。*本人亦保證上述工程的各水錶位正確無誤。連同夾附於本表格部分的已簽署竣工證書，本人證明上述的已完成工程符合《水務設施條例》，《水務設施規例》和水務監督的規定。

_____ 水喉匠的姓名： _____
(填寫第一部分的持牌水喉匠簽署)
牌照號碼： _____
日期： _____

* 本人信納持牌水喉匠於上述所示的各個水錶位正確無誤。

_____ 姓名： _____
(填寫第二部分的申請人簽署)

_____ 日期： _____
公司蓋章(如適用)

* 請刪去不適用者
「用戶」及「代理人」的定義請參照《水務設施條例》第2條。



第五部分 (由水務監督填寫)

致：持牌水喉匠
持牌水喉匠的郵寄地址

致：申請人
申請人的郵寄地址

符合水務監督要求的水樣本檢驗結果亦已於____年____月____日收到，我們沒有發現明顯不合規格之處。*如《水務設施規例》附表 1 第 1 部訂明的收費已獲清付，*我們會於其後安裝總水管接駁裝配，*以及在政府持有的土地上安裝部分消防供水系統或內部供水系統。

持牌水喉匠須注意在建造、安裝、更改或拆除本表格所涵蓋的工程時，有責任遵循核准水管計劃、《水務設施條例》和《水務設施規例》。即使獲發此表格或獲批准進行水管工程計劃或獲批予總水管接駁裝配，*以及在政府持有的土地上已安裝部分消防供水系統或內部供水系統，都不應視為獲批准違反任何《水務設施條例》或《水務設施規例》的規定。

(代水務監督簽署)

姓名： _____

職位： _____

電話號碼： _____

日期： _____ 傳真號碼： _____

* 請刪去不適用者
「用戶」及「代理人」的定義請參照《水務設施條例》第 2 條。

附註：

1. 本表格適用於由水務設施供水或擬由水務設施供水的處所。表格的第一部分須由持牌水喉匠填寫，用以向水務監督申請展開本表格所涵蓋在核准水管計劃下的工程。第二部分須由用戶#／代理人#／初次申請供水人士填寫。表格的資料如有任何遺漏，均可導致申請延誤。
2. 本表格的第一及第二部分須遞交水務監督，以供批核本表格所涵蓋在核准水管計劃下的工程的建造、安裝、更改或拆除工作。
3. 本表格必須以郵遞/傳真方式送交水務監督。
4. 不同階段的水管工程如須於不同日期獲得供水，便須各遞交一套表格。**如表格第一部分的「預計需要供水的日期」有任何更改，填寫第二部分的用戶#／代理人#／初次申請供水人士及/或填寫第一部分的持牌水喉匠須以書面通知水務監督。**
5. 申請的處理程序完成後，持牌水喉匠和用戶#／代理人#／申請人會收到已印上表格編號的表格第三部分，以及表格第一及第二部分的副本。
6. 如要申報已完成本表格所涵蓋的工程（包括須隱藏的水管），便須填寫本表格第四部分。如要申報已完成本表格所涵蓋的工程，持牌水喉匠和用戶#／代理人#／申請人（如適用）應填寫表格第四部分，並連同表格第一、第二及第三部分的副本一併遞交，**請在第四部分註明表格編號和申請書編號。**
7. 持牌水喉匠在進行工程時，應時刻注意及避免觸犯反貪法例。詳情請瀏覽廉政公署網頁 <http://www.icac.org.hk/>。

#「用戶」及「代理人」的定義請參照《水務設施條例》第2條。

竣工證書

地址： _____

致：水務監督

本人就表格 WWO 46A 第四部分附上補充文件（其中包括已填妥的視察清單）。

本人證明上述表格 WWO 46A 第四部分所述的已完成水管工程根據核准水管工程計劃（包括垂直水管路線圖）、竣工圖則和竣工物料清單(表格 WWO 1149A)進行，在所有方面均符合《水務設施條例》（第 102 章）和《水務設施規例》（第 102A 章）所訂的條文，以及符合《樓宇水管工程技術要求》、致各持牌水喉匠及認可人士的水務署通函及《申請供水指引》等所訂的水務監督要求和有關的適用規格。*所有軟焊接口採用的焊接物料均為無鉛（若使用銅喉）／沒有採用軟焊。所有已進行的檢查、視察和驗收測試的結果符合相關要求。本人已檢視和信納載於附件的已填妥視察清單。

負責持牌水喉匠簽署_____
姓名（全名）_____
水喉匠牌照號碼_____
*電郵／通訊地址

日期： _____

* 請刪去不適用者



申請書編號：_____

表格編號 _____

(本署專用)

處所地址：_____

已安裝的喉管及裝置清單：

第__頁(共__頁)

喉管及裝置類別說明 (見附註 6)	品牌名稱	尺寸	製造商	原產國	一般認可信編號/ 用水效益標籤計劃註冊號碼 (見附註 3, 4 及 5)	安裝所指定已註冊用水效益標籤 計劃的產品/「組合式」節水裝 置的位置

如有需要，可另加紙張填寫。

請參閱背頁附註

持牌水喉匠簽署：_____ 牌照號碼：_____ 日期：_____

附註：

1. 本表格須與表格 WWO 46A 的第四部分一併提交。
2. 所有已使用於水管工程的喉管及裝置均須按水務監督於水務署網頁登載的「須於水務表格 WWO 1149 內申報的喉管及裝置」的要求申報。
3. 所有已使用於核准水管工程的喉管及裝置，都必須符合水務設施條例及水務設施規例訂明的要求及所有相關標準。若已使用的喉管及裝置已獲發一般認可，申請人必須在本表格上列明其認可信編號。
4. 所有擬於住宅處所的廚房及所有處所的浴室和洗手間使用的水龍頭、沐浴花灑、小便器沖水閥和水廁設備，均須先在用水效益標籤計劃（標籤計劃）下註冊，並符合《樓宇水管工程技術要求》第 7 節的規定及水務署通函。申請人必須在本表格上清楚列明其在標籤計劃下的註冊號碼。
5. 如套裝式水廁(一體式水廁)，必須清楚列明其在標籤計劃下的註冊號碼。如水廁水箱，除其在標籤計劃下的註冊號碼外，還必須清楚列明水廁廁盆在標籤計劃下的註冊號碼，以檢查兩者的用水效益級別是否匹配。申請人應參閱水務署網頁內標籤計劃的計劃文件(水廁)。
6. 對於不符合《樓宇水管工程技術要求》所規定用水效益要求的水龍頭或沐浴花灑，如把已註冊標籤計劃並具所須用水效益的節流器安裝在該水龍頭或沐浴花灑內，成為「組合式」節水裝置以符合所規定的用水效益要求，水務監督亦可接納。如要為非混合式水龍頭選擇上述節流器，申請者須按水務署網頁上標籤計劃登記冊挑選具備合適標稱流量的節流器，以符合所規定的用水效益要求。安裝在「組合式」節水裝置的已註冊標籤計劃節流器的詳情，亦須包括在本表格中。

General Information 一般資料 Date of Inspection 視察日期: Premises Address 處所地址: Name of Licensed Plumber 持牌水喉匠姓名: Plumber's Licence Number 水喉匠牌照號碼: Serial Number of Form WWO46 表格WWO46編號:	TICK THIS BOX IF NO INSPECTION CARRIED OUT FOR THIS TYPE OF WORKS <input type="checkbox"/> 如沒有就此類別工程進行視察，請剔此格	(Revised April 2026) P.1 of 5
Inspection Checklist 視察清單 (Section A) (A部)		
Inspection Type (please tick) 視察類別 (請剔): <input type="checkbox"/> Final Inspection 最終視察 <input type="checkbox"/> Interim Inspection 中期視察 <input type="checkbox"/> Re-inspection 重新視察 Type of Plumbing Works 水管工程類別: () *		

A Type 類別	B Contravention of WWO / WWR or Non-compliance with WA's Requirements 違反《水務設施條例》/《水務設施規例》或不符合水務監督的要求	Penalty Point / Demerit Point / 罰分 / 配分	Defects/irregularities found? (please tick) 發現不合規格/不妥當之處? (請剔)			Type (FW, FL, FS) ^ 類別 (食水、沖廁水、消防供水)	Defects/irregularities (Please specify the extent and details of defects/irregularities, if any) 不合規格/不妥當之處(如有，則請訂明不合規格/不妥當的程度和詳情)	Details of Inspected Location (refers code below, if applicable) 已視察位置的詳情(請參見下方的編號，如適用)	Details (e.g. Brand Name/Model No., if available) 詳情 (例如品牌名稱/型號，如有的話)	Photo Taken (Y / N) 夾附圖片 (有 / 沒有)	Remarks 備註
			Y 有	N 沒有	Not Applicable 不適用						
(A) Piping (including all pipes and fittings, and connection pipe) 喉管 (包括所有喉管與裝置，以及接駁喉)	(1) Pipe size less than minimum permissible size 水管尺寸小於准許的尺寸	P									
	(2) Not bitumen painted or hessian / other suitable material wrapped 未塗上瀝青或纏上麻布/其他適當物料	P									
	(3) A bend or curve made in any pipe that will diminish the waterway or alter the internal diameter of the pipe 水管上有屈曲或彎位，而令水道變窄或改變水管的內部直徑	P									
	(4) Used / covered up prior to inspection 在視察前已經使用/覆蓋	P									
	(5) Pipe/fittings made of material not allowed or not complied with the prescribed standard 水管/裝置所用的材料並不獲批准或不符合規定的標準	P									
	(6) Leaded solder used for jointing pipes and fittings@ 使用含鉛焊料接駁喉管與裝置@	P									
	(7) Not of the materials already accepted by the Water Authority (WA) in WWO 1149A 並非在WWO1149A表格內水務監督已接納的物料	D									
	(8) Connection pipes not of the sizes or at the position already accepted by the WA 接駁喉管並非水務監督已接納的尺寸或位置	D									

@ If this contravention of WWO/WWR item is found, the Licensing Authority will consider initiating the procedures to deliberate cancellation or suspension of the plumber's licence. 如發現違反《水務設施條例》/《水務設施規例》，發牌當局將考慮啟動相關程序，以取消或暫時吊銷持牌水喉匠的牌照。

Please insert ✓ at the appropriate box under the "Defects/irregularities found?" column. 請在「發現不合規格/不妥當之處?」欄下的適當空格內加✓。

* Fresh Water 食水 (FW), Flushing Water 沖廁水 (FL), Fire Service 消防供水 (FS)

* Please insert the code for the corresponding type of plumbing works: 請加入相應水管工程類別的編號:

- (a) Building of Storey 樓層 >=4
- (b) Building of Storey 樓層 <=4
- (c) Village House 村屋
- (d) Separate Meter 安裝獨立水錶
- (e) Construction Supply 地盤供水

Photos should be taken on defects / irregularities 須為不合規格/不妥當之處拍照

Code for Inspected Location 已視察位置的編號:

(a) underground pipe and connection pipe	(g) master meter position 總水錶位	(m) communal riser pipe 公用喉管
(b) concealed pipework above ground	(h) check meter position 檢測錶位	(n) communal down-feed pipe 公用主給管
(c) roof tank 天台儲水箱	(i) meter position 水錶位	(o) feed tank for swimming pool 游泳池供水箱
(d) intermediate tank 中間儲水箱	(j) meter cabinet 水錶櫃/水錶房 (chamber) 井	(p) irrigation supply points 澆灌供水點
(e) break pressure tank 減壓缸	(k) meter cabinet 水錶櫃/room (typical典型)	(q) cleansing supply points 盥洗供水點
(f) break tank 斷流水箱	(l) meter cabinet 水錶櫃/room (non-typical, please specify 非常型，請註明)	(r) hydrant, hose reel, sprinkler, fountain 消防龍頭、消防捲盤、噴水沙
		(s) other location 其他位置 (please specify 請註明)

ASN 申請書編號:	
WSD Inspection Staff 水務署督察人員 (if applicable) (如適用) Signature 簽名: _____ Name 姓名: _____ Post 職位: _____ Date 日期: _____	Responsible Licensed Plumber 負責持牌水喉匠 Signature 簽名: _____ Name 姓名: _____ Plumber Licence Number 水喉匠牌照號碼: _____ Date 日期: _____

General Information 一般資料 Date of Inspection 視察日期: Premises Address 處所地址: Name of Licensed Plumber 持牌水喉匠姓名: Plumber's Licence Number 水喉匠牌照號碼: Serial Number of Form WWO46 表格WWO46編號:	TICK THIS BOX IF NO INSPECTION CARRIED OUT FOR THIS TYPE OF WORKS <input type="checkbox"/> 如沒有就此類別工程進行視察，請劃此格	(Revised April 2026) P.2 of 5
Inspection Checklist 視察清單 (Section B) (B部)		
Inspection Type (please tick) 視察類別 (請劃): <input type="checkbox"/> Final Inspection 最終視察 <input type="checkbox"/> Interim Inspection 中期視察 <input type="checkbox"/> Re-inspection 重新視察		
Type of Plumbing Works 水管工程類別: () *		
*		

A Type 類別	B Contravention of WWO / WWR or Non-compliance with WA's Requirements 違反《水務設施條例》/《水務設施規例》或不符合水務監督的要求	Penalty Point / Demerit Point 罰分 / 配分	Defects/irregularities found? (please tick) 發現不合規格/不妥當之處? (請劃)			Type (FW, FL, FS) ^ 類別 (食水、沖廁水、消防供水)	Defects/irregularities (Please specify the extent and details of defects/irregularities, if any) 不合規格/不妥當之處(如有，則請訂明不合規格/不妥當的程度和詳情)	Details of Inspected Location (refers code below, if applicable) 已視察位置的詳情(請參見下方的編號，如適用)	Details (e.g. Brand Name/Model No., if available) 詳情 (例如品牌名稱/型號，如有的話)	Photo Taken (Y/N) 夾附圖片 (有/沒有)	Remarks 備註
			Y 有	N 沒有	Not Applicable 不適用						
(B) Meter Position / Check Meter Position 錶位/檢測錶位	(1A) Meter position / check meter position not at suitable height above the floor level 錶位/檢測錶位非位於地面以上的適當高度	D									
	(1B) Meter installed in a landscape area with a clear working headroom less than 2m 安裝於園境地帶的水錶，其空間作業高度少於2米	D									
	(1C) Meters not arranged in groups and housed in meter rooms / boxes / cabinet / chamber 水錶並非集中排列及安放於水錶房/箱/櫃/井中	D									
	(2) Meter room / box not located at the hoarding recess area of the construction site 建築地盤的錶房/箱不設在圍板凹處	D									
	(3) No loose jumper stopcock at inlet side of the meter 水錶入水處缺少皮心掣	D									
	(4) Working clearance at check meter position not meeting the minimum requirement 檢測錶位的工作空間沒有達到最低要求	D									
	(5) No non-return valve provided on the delivery side of the meter 水錶出水口的一方缺少止回流閥	D									
(6) No fullway gate valve provided before meter position 水錶前缺少全通閘閥	D										
(7) Meter room/meter cabinet not satisfying the architectural requirements 水錶房/水錶櫃沒有達到建築要求	D										

© If this contravention of WWO/WWR item is found, the Licensing Authority will consider initiating the procedures to deliberate cancellation or suspension of the plumber's licence.
 如發現違反《水務設施條例》/《水務設施規例》，發牌當局將會考慮啟動相關程序，以取消或暫時吊銷持牌水喉匠的牌照。
 Please insert ✓ at the appropriate box under the "Defects/irregularities found?" column. 請在「發現不合規格/不妥當之處?」欄下的適當空格內加✓。
 ^ Fresh Water 食水 (FW), Flushing Water 沖廁水 (FL), Fire Service 消防供水 (FS)
 * Please insert the code for the corresponding type of plumbing works: 請加入相應水管工程類別的編號:
 (a) Building of Storey 樓層 ≥4
 (b) Building of Storey 樓層 <4
 (c) Village House 村屋
 (d) Separate Meter 安裝獨立水錶
 (e) Construction Supply 地盤供水
 Photos should be taken on defects / irregularities須為不合規格/不妥當之處拍照

Code for Inspected Location 已視察位置的編號		
(a) underground pipe and connection pipe	(g) master meter position 總水錶位	(m) communal riser pipe 公用豎管
(b) concealed pipework above ground	(h) check meter position 檢測錶位	(n) communal down/feet pipe 公用下給管
(c) roof tank 天台儲水箱	(i) meter position 水錶位	(o) feed tank for swimming pool 游泳池供水箱
(d) intermediate tank 中間儲水箱	(j) master meter room/水錶房/chamber 井	(p) irrigation supply points 灌溉供水點
(e) break pressure tank 減壓缸	(k) meter cabinet/水錶櫃/room 房 (typical 典型)	(q) clematis supply points 泮泮供水點
(f) break tank 斷流水箱	(l) meter cabinet/水錶櫃/room 房 (non-typical, please specify 非典型, 請註明)	(r) hydrant, hose reel, sprinkler, fountain 消防龍頭、消防喉盤、消防花灑、噴水池
		(s) other location 其他位置 (please specify 請註明)

ASN 申請書編號:	
WSD Inspection Staff 水務署視察人員 (if applicable) (如適用) Signature 簽名: _____ Name 姓名: _____ Post 職位: _____ Date 日期: _____	Responsible Licensed Plumber 負責持牌水喉匠 Signature 簽名: _____ Name 姓名: _____ Plumber Licence Number 水喉匠牌照號碼: _____ Date 日期: _____

General Information 一般資料 Date of Inspection 視察日期: Premises Address 處所地址: Name of Licensed Plumber 持牌水喉匠姓名: Plumber's Licence Number 水喉匠牌照號碼: Serial Number of Form WWO46 表格WWO46編號: Inspection Type (please tick) 視察類別 (請劃):	TICK THIS BOX IF NO INSPECTION CARRIED OUT FOR THIS TYPE OF WORKS <input type="checkbox"/> 如沒有就此類別工程進行視察，請劃此格
(Revised April 2026) P.3 of 5	
Inspection Type (please tick) 視察類別 (請劃): <input type="checkbox"/> Final Inspection 最終視察 <input type="checkbox"/> Interim Inspection 中期視察 <input type="checkbox"/> Re-inspection 重新視察	
Type of Plumbing Works 水管工程類別: () *	

Inspection Checklist 視察清單
(Section C) (C部)

A Type 類別	B Contravention of WWO / WWR or Non-compliance with WA's Requirements 違反《水務設施條例》/《水務設施規例》或不符合水務監督的要求	Penalty Point / Demerit Point 罰分/配分	Defects/irregularities found? (please tick) 發現不合規格/不妥當之處? (請劃)			Type (FW, FL, FS) ^ 類別 (食水、沖廁水、排 防供水)	Defects/irregularities (Please specify the extent and details of defects/irregularities, if any) 不合規格/不妥當之處(如有，則請訂明不合規格/不妥當的程度和詳情)	Details of Inspected Location (refers code below, if applicable) 已視察位置的詳情(請參見下方的編號，如適用)	Details (e.g. Brand Name/Model No., if available) 詳情(例如品牌名稱/型號，如有的話)	Photo Taken (Y/N) 夾附圖片 (有/沒有)	Remarks 備註
			Y 有	N 沒有	Not Applicable 不適用						
(C) Storage Tanks 儲水缸	(1) Tanks made of material not allowed or not complied with the prescribed standard 水缸所用的材料並不獲批准或不符合規定的標準	P									
	(2) No control valve at inlet fed by gravity 在入水位缺少利用天然水壓供水的控制閥	P									
	(3) No automatic control switch for inlet of storage tank fed by pumped supply 儲水缸的入水位缺少利用泵壓供水的自動控制開關	P									
	(4) No control valve/drain-off pipe at outlet 出水位缺少控制閥/排水管	P									
	(5) Overflow pipe of fresh water tank not made of a corrosion-resisting material 食水水缸的溢流管所用的物料並非抗腐蝕物料	P									
	(6) Overflow pipe undersized 溢流管尺寸太小	P									
	(7) Invert of the inlet or the outlet of ball float valve less than 25mm above the top of the overflow pipe 入水管倒拱或浮球閥出水口離溢流管的頂部不足25毫米	P									
	(8) Overflow pipe connected to a drain or sewer or to the overflow pipe from another tank 溢流管接駁至排水渠或污水渠或另一個水缸的溢流管	P									
	(9) Fresh water tank connected for storage of water other than that supplied from the waterworks 食水水缸接駁並作儲存來自水務設施以外所供應的用水	P									
	(10) Water tank not easily accessible or safe access by ladder not provided 水缸不容易通往或未有提供梯子作安全通道	P									
	(11) Tank not provided with lockable covers 水缸缺少可上鎖的封蓋	P									
	(12) Storage capacity exceeds the maximum permitted capacity 儲水量超過最高准許儲水量	P									
	(13) No physical break between potable & non-potable tanks 可飲用及非飲用水缸中間沒有實際分隔	P									
	(14) Ball float valves or floats made of material not allowed or not complied with the prescribed standard 浮球閥或浮標所用的物料並不獲批准或不符合規定的標準	P									
	(15) Ball float valve/float operated valve improperly installed/provided 浮球閥/浮標操作閥安裝/安置不當	P									
	(16) Fresh water tank not provided with lockable double sealed covers 食水水缸缺少可上鎖的雙邊密封箱蓋	D									
	(17) Overflow pipes/ warning pipes/ any other openings of storage cistern not covered with non-corrodible or corrosion-resistant mesh to exclude ingress of animal, insects or foreign objects 儲水缸的溢流管、警戒管或其他開口缺少不鏽或抗腐蝕鐵絲網以防止動物、昆蟲或外物進入	D									

* If this contravention of WWO/WWR item is found, the Licensing Authority will consider initiating the procedures to deliberate cancellation or suspension of the plumber's licence.
 如發現違反《水務設施條例》(《水務設施規例》)，發牌當局將考慮啟動相關程序，以取消或暫時吊銷持牌水喉匠的牌照。
 Please insert ✓ in the appropriate box under the "Defects/irregularities found?" column. 請在“發現不合規格/不妥當之處?”欄下的適當方格內加✓。
 ^ Fresh Water 食水 (FW), Flushing Water 沖廁水 (FL), Fire Service 消防供水 (FS)
 * Please insert the code for the corresponding type of plumbing works: 請加入相應水管工程類別的編號:
 (a) Building of Storey 樓層 >=4
 (b) Building of Storey 樓層 <4
 (c) Village House 村屋
 (d) Separate Meter 安裝獨立水錶
 (e) Construction Supply 地盤供水
 Photos should be taken on defects /irregularities 須為不合規格/不妥當之處拍照

Code for Inspected Location 已視察位置的編號:		
(a) underground pipe and connection pipe	(g) master meter position 總水錶位	(m) communal riser pipe 公用管
(b) concealed pipework above ground	(h) check meter position 檢查錶位	(n) communal down-feed pipe 公用下給管
(c) roof tank 天台儲水箱	(i) meter position 水錶位	(o) feed tank for swimming pool 游泳池供水箱
(d) intermediate tank 中間儲水箱	(j) master meter room/水錶房(chamber)	(p) irrigation surety points 灌溉供水點
(e) break pressure tank 減壓缸	(k) meter cabinet 水錶櫃(room) (technical 專業)	(q) cleanline surety points 清洗用水供水點
(f) break tank 斷流水箱	(l) meter cabinet 水錶櫃(room) (non-technical, please specify 非專業, 請註明)	(r) hydrant, hose reel, sprinkler, fountain, fountain, fountain 消防喉帶、消防注水器、噴水喉
		(s) other location 其他位置 (please specify 請註明)

ASN 申請書編號:		Responsible Licensed Plumber 負責持牌水喉匠	
WSD Inspection Staff 水務署視察人員 (if applicable) (如適用)		Signature 簽名: _____	
Signature 簽名: _____		Name 姓名: _____	
Name 姓名: _____		Plumber Licence Number 水喉匠牌照號碼: _____	
Post 職位: _____		Date 日期: _____	
Date 日期: _____		Date 日期: _____	

General Information 一般資料 Date of Inspection 視察日期: Premises Address 處所地址: Name of Licensed Plumber 持牌水喉匠姓名: Plumber's Licence Number 水喉匠牌照號碼: Serial Number of Form WWO46 表格WWO46編號:	TICK THIS BOX IF NO INSPECTION CARRIED OUT FOR THIS TYPE OF WORKS <input type="checkbox"/> 如沒有就此類別工程進行視察，請剔此格
(Revised April 2026) P.4 of 5	
Inspection Checklist 視察清單 (Section D) (D部)	
Inspection Type (please tick) 視察類別 (請剔): <input type="checkbox"/> Final Inspection 最終視察 <input type="checkbox"/> Interim Inspection 中期視察 <input type="checkbox"/> Re-inspection 重新視察 Type of Plumbing Works 水管工程類別: ()	

A Type 類別	B Contravention of WWO / WWR or Non-compliance with WA's Requirements 違反《水務設施條例》/《水務設施規例》或不符合水務監督的要求	Penalty Point / Demerit Point 罰分/記分	Defects/irregularities found? (please tick) 發現不合規格/不妥當之處? (請剔)			Type (FW, FL, FS) ^ 類別 (食水、沖廁水、消防供水)	Defects/irregularities (Please specify the extent and details of defects/irregularities, if any) 不合規格/不妥當之處(如有，則請訂明不合規格/不妥當的程度和詳情)	Details of Inspected Location (refers code below, if applicable) 已視察位置的詳情(請參見下方的編號，如適用)	Details (e.g. Brand Name/Model No., if available) 詳情(例如品牌名稱/型號，如有的話)	Photo Taken (Y/N) 夾附圖片(有/沒有)	Remarks 備註
			Y 有	N 沒有	Not Applicable 不適用						
(D) Online Re-plumbing 同位更換水喉	(1) No low initial leaching rate fittings installed / fittings installed have not been pretreated for online re-plumbing works 於同位更換水喉工程沒有安裝低溶濾率配件 / 所安裝的配件沒有預先經過處理	D									
	(2) No temporary water supply arrangement implemented on site (where applicable) 沒有在地盤實施臨時供水的安排(如適用)	D									
	(3) No arrangement implemented on site to notify affected customers not to use tap water for drinking and cooking purposes (where applicable) 沒有在地盤實施安排以通知受影響用戶勿取用水龍頭水作飲用及煮食用途(如適用)	D									
	(4) Online re-plumbing works were carried out but has not been specifically mentioned in plumbing proposal 已進行同位更換水喉工程，但沒有在水管工程計劃中明確提及	D									
	(5) Solder joints were adopted on site but has not been specifically mentioned in plumbing proposal /WWO 46 已在地盤採用軟焊接口，但沒有在水管工程計劃/WWO46表格內明確提及	D									

© If this contravention of WWO/WWR item is found, the Licensing Authority will consider initiating the procedures to deliberate cancellation or suspension of the plumber's licence.
 如發現違反《水務設施條例》/《水務設施規例》，發牌處將考慮啟動相關程序，以取消或暫時吊銷持牌水喉匠的牌照。
 Please insert ✓ at the appropriate box under the "Defects/irregularities found" column. 請在「發現不合規格/不妥當之處?」欄下的適當空格內加✓。
 ^ Fresh Water 食水 (FW), Flushing Water 沖廁水 (FL), Fire Service 消防供水 (FS)
 * Please insert the code for the corresponding type of plumbing works: 請加入相應水管工程類別的編號。
 (a) Building of Storey 樓層 >=4
 (b) Building of Storey 樓層 <4
 (c) Village House 村屋
 (d) Separate Meter 安裝獨立水錶
 (e) Construction Supply 地盤供水
 Photos should be taken on defects / irregularities 須為不合規格/不妥當之處拍照

Code for Inspected Location 已視察位置的編號		
(a) underground pipe and connection pipe	(i) master meter room 總水錶位	(m) communal riser pipe 公用豎管
(b) concealed pipework above ground	(j) check meter position 檢測錶位	(n) communal down-feed pipe 公用下給管
(c) roof tank 天台儲水箱	(k) meter room 水錶位	(o) feed tank for swimming pool 游泳池供水箱
(d) intermediate tank 中間儲水箱	(l) master meter room 總水錶房(chamber 井)	(p) irrigation supply points 灌溉供水點
(e) break pressure tank 減壓缸	(m) meter cabinet 水錶櫃(room 房)(typical 典型)	(q) cleanline supply points 清洗供水點
(f) break tank 斷流水箱	(n) meter cabinet 水錶櫃(room 房)(non-typical, please specify 非常型, 請註明)	(r) hydrant, hose reel, sprinkler, fountain 消防龍頭、消防喉轆、消防花灑、噴水池
		(s) other location 其他位置 (please specify 請註明)

ASN 申請書編號:	
WSL Inspection Staff 水務管理人員 (if applicable) (如適用) Signature 簽名: _____ Name 姓名: _____ Post 職位: _____ Date 日期: _____	Responsible Licensed Plumber 負責持牌水喉匠 Signature 簽名: _____ Name 姓名: _____ Plumber Licence Number 水喉匠牌照號碼: _____ Date 日期: _____

General Information 一般資料	TICK THIS BOX IF NO INSPECTION CARRIED OUT FOR THIS TYPE OF WORKS <input type="checkbox"/>	(Revised April 2026) P.5 of 5
Date of Inspection 視察日期:	如沒有就此類別工程進行視察，請剔此格	
Premises Address 處所地址:		
Name of Licensed Plumber 持牌水喉匠姓名:		
Plumber's Licence Number 水喉匠牌照號碼:		
Serial Number of Form WWO46 表格WWO46編號:		
Inspection Type (please tick) 視察類別 (請別):	<input type="checkbox"/> Final Inspection 最終視察 <input type="checkbox"/> Interim Inspection 中期視察 <input type="checkbox"/> Re-inspection 重新視察	Type of Plumbing Works 水管工程類別: () *

**Inspection Checklist 視察清單
(Section E) (E部)**

A Type 類別	B Contravention of WWO / WWR or Non-compliance with WA's Requirements 違反《水務設施條例》/《水務設施規例》或 不符合水務監督的要求	Penalty Point / Demerit 點 罰分	Defects/irregularities found? (please tick) 發現不合規格/不妥當之處? (請劃)			Type (FW, FL, FS) ^ 類別 (食水、沖廁水、消 防供水)	Defects/irregularities (Please specify the extent and details of defects/irregularities, if any) 不合規格/不妥當之處(如有，則請訂明不合規格/不妥當 的程度和詳情)	Details of Inspected Location (refers code below, if applicable) 已視察位置的詳情(請參見 下方的編號，如適用)	Details (e.g. Brand Name/Model No., if available) 詳情(例如品牌名稱/型號， 如有的話)	Photo Taken (Y/N) 夾附圖片 (有/沒有)	Remarks 備註
			Y 有	N 沒有	Not Applicable 不適用						
(E) Others 其他	(1) Sanitary fittings not properly installed / provided 潔具安裝/安置不當	P									
	(2) No stopcocks at appliances & branches 用具及支喉未裝有水掣	P									
	(3) Flushing apparatus not properly installed / provided 沖廁設備安裝/安置不當	P									
	(4) Heater not properly installed 熱水器安裝不當	P									
	(5) Use of a fitting with a threaded outlet or any device facilitating the connecting of rubber hose or another type of flexible hose without WA's written permission 在未獲水務監督書面許可的情況下，使用有螺紋接駁的裝置，或任何利便連接橡膠軟管或其他 種類類軟管的器件	P									
	(6) Booster pump directly fed from a main 增壓泵直接由總水管抽水	P									
	(7) Water using apparatus used or installed without permission 未經許可下使用或安裝用水器具	P									
	(8) No locking device for draw-off tap that is freely accessible by the general public 公眾可自由接觸的排水龍頭缺少鎖緊裝置	D									
	(9) Designated products (showers for bathing, water taps and urinal flushing valves) used in kitchens of domestic premises and bathrooms and toilets of all premises not meeting the prescribed water efficiency requirements registered under WELS 住宅處所的廚房內，以及所有處所的浴室和洗手間內，所使用的指定產品(沐浴花灑、水龍頭 和小便器沖水閥)，不符合用水效益標籤計劃下規定的用水效益要求	D									
	(10) The flow controller not being a registered product under WELS or not of appropriate water efficiency grade to form a 'combined' water saving device that meets the prescribed water efficiency requirements. 節流器並非用水效益標籤計劃下的註冊產品，或並非合適的用水效益級別以形成「組合式」 節水裝置，因而未能達到規定的用水效益要求	D									
	(11A) Plumbing works not comply with mandatory requirements in the Technical Requirements for Plumbing Works in Buildings : Please give details 水管工程未有遵守《樓宇水管工程技術要求》內須遵守的技術要求： 請說明詳情	D									
	(11B) Plumbing works not constructed according to the approved drawings but not violate any mandatory requirements in the Technical Requirements for Plumbing Works in Buildings **: Please give details 水管工程未依批准圖則建造而未有違反《樓宇水管工程技術要求》內須遵守的技術要求**： 請說明詳情	N/A									
(12) Absence of the licensed plumber from the final inspection of new building project after submission of WWO 46 Part IV # 在提交WWO 46第四部分之後，持牌水喉匠缺席新建樓宇項目的最終視察#	D										

* If this contravention of WWO/WWR item is found, the Licensing Authority will consider initiating the procedures to deliberate cancellation or suspension of the plumber's licence.
如發現違反《水務設施條例》/《水務設施規例》，發牌處將考慮啟動相關程序，以取消或暫時吊銷持牌水喉匠的牌照。
Please insert ✓ at the appropriate box under the "Defects/irregularities found?" column. 請在「發現不合規格/不妥當之處?」欄下的適當空格內加✓。
^ Fresh Water 食水 (FW), Flushing Water 沖廁水 (FL), Fire Service 消防供水 (FS)
+ Please insert the code for the corresponding type of plumbing works: 請加入相應水管工程類別的編號:
(a) Building of Storey 樓宇 ≥4
(b) Building of Storey 樓宇 <4
(c) Village House 村屋
(d) Separate Meter 安裝獨立水錶
(e) Construction Supply 地盤供水

This item is not applicable to new building projects involving just one detached village type house. 此項並不適用於只涉及一座獨立村屋類型的新建樓宇項目。

Photos should be taken on defects / irregularities 須為不合規格/不妥當之處拍照
** Approved drawings include Drawing Nos. S-11 in Appendix II of the Guide to Application for Water Supply
** 批准圖則包括《申請供水指引》附錄II第S-11號圖則

Code for Inspected Location 已視察位置的編號:		
(a) underground pipe and connection pipe	(g) master meter position 總水錶位	(m) communal riser pipe 公用暖管
(b) concealed pipework above ground	(h) check meter position 檢測錶位	(n) communal down-feed pipe 公用下給管
(c) roof tank 天台儲水箱	(i) meter position 水錶位	(o) feed tank for swimming pool 游泳池供水箱
(d) intermediate tank 中間儲水箱	(j) master meter room 總水錶房/水錶房	(p) irrigation supply rooms 灌溉供水室
(e) break pressure tank 減壓缸	(k) meter cabinet 水錶櫃/水錶房 (non-typical, please specify in details, 請註明)	(q) cleaning supply rooms 清潔供水室
(f) break tank 斷流水箱	(l) meter cabinet 水錶櫃/水錶房 (non-typical, please specify in details, 請註明)	(r) hydrant, hose reel, sprinkler, fountain 消防龍頭、消防喉盤、消防花園、噴水亭
		(s) other location 其他位置 (please specify in details, 請註明)

ASN 申請書編號: WWO Inspection Staff 水務督察人員 (if applicable) (如適用) Signature 簽名: _____ Name 姓名: _____ Post 職位: _____ Date 日期: _____	Responsible Licensed Plumber 負責持牌水喉匠 Signature 簽名: _____ Name 姓名: _____ Plumber Licence Number 水喉匠牌照號碼: _____ Date 日期: _____
---	--



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 43 樓

43/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : CCID of
Our ref.
來函檔號 :
Your ref.

電話 : 2824 5000
Tel.
傳真 : 2802 7333
Fax.

EnglishReviewedDate

FrTo
FrTo_Address1
FrTo_Address2
FrTo_Address3
FrTo_Address4

FIRE SERVICE COMPLETION ADVICE

Address: G/F

FIRE SERVICE SUPPLY

I hereby advise that a permanent connection of a supply of *fresh* water from the Waterworks for the purpose of fire service (FS) has been made to the above premises.

Yours faithfully,

()
for Water Authority

To: BUILDINGS DEPARTMENT
CC: FIRE SERVICES DEPARTMENT

Authorized Person
xxx (Fax: xxxx)

Licensed Plumber
xxx (Fax: xxxx)