

主要工作表現指標

Key Performance Indicators

指標 Indicators	財政年度(百分比) Financial Year (Percentage)		
	15/16	16/17	17/18
食水水質(供水接駁位置) 100%符合世界衛生組織在2011年制定的《飲用水水質準則》 或2017年9月起採用的香港食水標準 Fresh Water Quality (at connection points) 100% compliant with WHO's "Guidelines for Drinking-water Quality"(2011) or Hong Kong Drinking Water Standards since September 2017	達到指標 Target achieved	達到指標 Target achieved	達到指標 Target achieved
海水水質(供水接駁位置) 96%符合水務署所定的水質指標 Salt Water Quality (at connection points) 96% compliant with WSD Water Quality Objectives	達到指標 Target achieved	達到指標 Target achieved	達到指標 Target achieved
食水供水水壓(15至30米) ^λ Fresh Water Supply Pressure (15 – 30 metres) ^λ	100%	100%	100%
海水供水水壓(15米) ^λ Salt Water Supply Pressure (15 metres) ^λ	100%	100%	100%
因預先計劃進行的工程而暫停供水的時間長度(98%於八小時內) Duration of Suspension of Water Supply for Planned Works (98% within 8 hours)	達到指標 Target achieved	達到指標 Target achieved	達到指標 Target achieved
水錶準確程度(偏差程度不超過±3%) Accuracy of Water Meters (inaccuracy not exceeding ± 3%)	97.0%	97.3%	97.7%

^λ 除了在系統的盡頭，配水系統內最低的剩餘水壓。
Minimum residual pressure in the distribution systems except at their extremities.