

Common Observations in Plumbing Proposals for Village Type Houses **(2021 April to June)**

Guidebook: Submission Requirements

Insufficient Information

- The information provided in Form WWO 542 should be completed including classification code and estimated number of meters.
- The consent of relevant private land owner(s) should be provided if the connection pipe has to be laid across other private land lots.
- For the connection Layout Plan, proposed alignment of the private connecting pipe between the proposed connection point and the new village type house should be provided if the proposed connection point is not located at the lot boundary of the new village type house.

Plumbing Drawings

- The concealed pipeworks above ground of inside service should be properly indicated.
- The boundary of the new village type house and the concerned land lot boundary should be clearly shown.
- All units of measurement should be clearly stated.

TR 3: Metering

Meter Position

- The meter position should be located at the boundary close to the connection point.
- The meter should be installed in meter room(s)/box(es)/cabinet(s) located at the boundary and shall be accessible from the public area.