

Common Observations in Plumbing Proposals for Village Type Houses (2021 Jan to March)

Guidebook: Submission Requirements

- Design details should be shown consistently in the plumbing proposals, e.g. size of water meter cage should be shown consistently in vertical plumbing line diagrams and meter box details.

TR 7.3: Water Efficiency Requirements for Fittings and water-closet fitments in Inside Service

Pipes and fittings to be reported in Form WWO1149

- Please be reminded that use of water-closet fitments complying with the prescribed water efficiency requirements shall be mandatory for all proposed plumbing works with Form WWO 1149 first submitted to WSD on or after 1 December 2020.
- For the Form WWO 1149, the location of designated products registered under WELS/combined water saving devices should be provided.