

## **Common Observations in Plumbing Proposals for Village Type Houses (2022 January to March)**

### **Guidebook: Submission Requirements**

#### **Insufficient Information**

- The proposed plumbing installations such as hot water supply system should be shown on the plumbing drawings.
- For the connection Layout Plan, proposed alignment and size of the private connecting pipe between the proposed connection point and the new village type house should be provided in the proposed connection point.

#### **Plumbing Drawings**

- It is recommended to make reference to Pre-Approved Standard Plumbing Design Drawings for simplicity and clearness.
- Amendment to the submitted drawings maybe required to suit the actual site conditions.