



NOTES :

1. LOCAL SUPPLEMENTARY BONDING IS REQUIRED FOR EXTRANEOUS CONDUCTIVE PART(S) WHICH ARE :
 - (i) WITHIN AREAS CONTAINING SHOWER OR BATH, OR
 - (ii) AT A DISTANCE NOT EXCEEDING 2m FROM ANY ELECTRICAL APPLIANCE OR POWER SOCKET, e.g. WINDOW FRAME SUPPORTING A VENTILATION FAN OR AN A/C UNIT ETC.
2. MINIMUM CROSS-SECTIONAL AREA OF A SUPPLEMENTARY BONDING CONDUCTOR SHALL COMPLY WITH TABLE 11 (1) OF THE CODE OF PRACTICE FOR THE ELECTRICITY (WIRING) REGULATION. VIZ. 4mm² FOR PVC (NON-SHEATHED) CONDUCTOR.
3. THE SUPPLEMENTARY BONDING CONDUCTOR SHALL BE TERMINATED AT, VIA A TELEPHONE CORD OUTLET PLATE, A COPPER EARTH TERMINAL FITTED INSIDE A IEC 670/BS 4662 METAL BOX FORMING AN INTEGRAL PART OF THE CONDUIT INSTALLATION.

B	RE-FORMATTED TO CSWP	W.K. CHIU	18/7/03
A	GENERAL REVISION	W.K. CHIU	10/10/00
REF.	REVISION	APPROVED	DATE

SUPPLEMENTARY BONDING FOR
EXTRANEOUS CONDUCTIVE PARTS



水務署
Water Supplies Department

APPROVED

M.C. LEUNG
AD/NW

DATE

17/4/97

SCALE

N.T.S.

DRAWING NO.

WSD 2.38B

CSWP