












TYPICAL PLUMBING LINE DIAGRAM FOR PUMPING STATION

NOTES :

1. DETAILS AND EXACT LOCATION OF THE METER BOX SHALL BE SUBMITTED BY THE CONTRACTOR AND APPROVED BY THE ENGINEER. THE METER BOX SHALL BE PROVIDED IN ACCORDANCE WITH CLAUSE 7.7 OF THE "HONG KONG WATERWORKS STANDARD REQUIREMENTS FOR PLUMBING INSTALLATION IN BUILDINGS" (HKWSR).
2. THE FLUSHING WATER TANK SHALL BE MADE OF SALT WATER CORROSION RESISTANT MATERIAL. ITS INSTALLATION SHALL COMPLY WITH CHAPTER 4 OF HKWSR.
3. FOR FLUSHING WATER SUPPLY, INSTALLATION OF METER IS ONLY APPLICABLE FOR TEMPORARY MAINS WATER FOR FLUSHING SUPPLY.
4. THE OVERFLOW PIPE SHALL BE EXTENDED TO A CONSPICUOUS POSITION.
5. MODIFICATIONS TO THIS TYPICAL PLUMBING LINE DIAGRAM SHALL BE MADE TO SUIT INDIVIDUAL PUMPING STATIONS.

LEGEND :

- | | |
|---|---------------------------------------|
|  | LOOSE JUMPER TYPE STOPCOCK |
|  | GATE VALVE |
|  | TAP |
|  | NON-RETURN VALVE |
|  | METER |
|  | REDUCING BUSH |
|  | FRESH WATER PIPE |
|  | FLUSHING WATER PIPE |
|  | RAINWATER PIPE |
|  | SOIL PIPE, WASTE PIPE OR
VENT PIPE |
|  | 75mm DEEP WATER SEALED TRAP |

D	RE-FORMATTED TO CSWP	W.K. CHIU	18/7/03
C	GENERAL REVISION	W.K. CHIU	6/12/01
B	NOTES ADDED	K.W. CHAN	15/2/97
A	G.I. PIPE REPLACED	K.W. CHAN	23/11/94
REF.	REVISION	APPROVED	DATE

TYPICAL PLUMBING LINE DIAGRAM FOR PUMPING STATION



水務署
Water Supplies Department

APPROVED	G.C. LEE AD/NW	DRAWING NO. WSD 2.3E	CSWP
DATE	9/6/92		
SCALE	N.T.S.		