


COVER

Cad Ref. : WSD075101 - E.dwg





E	KEYHOLE PLASTIC PLUG ADDED	C.Y. CHAN	4/5/23
D	FRAME, COVER AND KEY HOLE REVISED	W.K. CHIU	31/10/07
C	RE-FORMATTED TO CSWP	W.K. CHIU	14/11/03
B	GENERAL REVISION	W.K. CHIU	6/12/01
A	GENERAL REVISION	W.K. CHIU	10/10/00
REF.	REVISION	APPROVED	DATE

FABRICATED STEEL RECESSED COVER AND FRAME TO 915 SQUARE MANHOLE OPENING



水務署  
Water Supplies Department

APPROVED	M.C. LEUNG AD/NW	DRAWING NO.	CSWP
DATE	22/5/00	WSD 7.51E	
SCALE	1 : 10	(SHEET 1 OF 4)	



Cad Ref. : WSD075102-E.dwg

FABRICATED STEEL RECESSED COVER AND FRAME TO 915 SQUARE MANHOLE OPENING







水務署  
Water Supplies Department

APPROVED	M.C. LEUNG AD/NW
DATE	22/5/00
SCALE	1 : 10 OR AS SHOWN


DRAWING NO.	CSWP
WSD 7.51E	
(SHEET 2 OF 4)	





NOTES :

1. ALL DIMENSIONS ARE IN MILLIMETRES.
2. FOR DETAILS OF WATER SUPPLIES DEPARTMENT LOGO, REFER TO DRAWING NO. WSD 7.17.
3. COVER AND FRAME SHALL BE MANUFACTURED TO ENSURE A CLOSE MATCHING FIT AND SHALL BE FULLY FABRICATED WITH GRADE 43 STEEL TO BS 4360.
4. IN ADDITION TO THE MARKINGS SPECIFIED, THE MANUFACTURER'S NAME AND THE CONTRACT NUMBER SHALL BE INSCRIBED ON THE UNDERSIDE OF THE COVER WITH A MINIMUM LETTERING SIZE OF 20mm.
5. COVER AND FRAME SHALL BE GALVANIZED TO BS EN ISO 1461 WITH A GALVANIZED COATING 85µm THICK MINIMUM.
6. COVER SHALL BE DESIGNED TO WITHSTAND A 11 TONNES SLOW MOVING WHEEL LOAD.
7. SHARP EDGES SHALL BE REMOVED.
8. EDGES SHALL BE MACHINE FINISHED TO FORM A SMOOTH SURFACE.
9. THE APPROXIMATE WEIGHT OF THE COVER WITH INFILLING PAVING UNITS SHALL BE 165kg.
10. FOR DETAILS OF KEYHOLE PLASTIC PLUG REFER TO DRAWING NO. WSD 7.48.



Cad Ref. : WSD075104-E.dwg

FABRICATED STEEL RECESSED COVER AND FRAME TO 915 SQUARE MANHOLE OPENING



水務署  
Water Supplies Department

APPROVED	M.C. LEUNG AD/NW	DRAWING NO. WSD 7.51E (SHEET 4 OF 4)	CSWP
DATE	22/5/00		
SCALE	1 : 5 OR AS SHOWN		