

Manual of Mainlaying Practice (2012 Edition)

Amendment No. 1/2015

CONTENTS

- | | | |
|-----|--------------------|--|
| (a) | List of Appendices | To replace the table of content for Appendices 3.5 and 3.6 as follows: |
| | 3.5 | Not Used |
| | 3.6 | Not Used |

SECTION 2 - MATERIALS

- | | | |
|-----|-------------|--|
| (a) | Section 2.4 | To delete the contents on PE100RC materials as PE100 materials with equivalent slow crack growth resistance had been specified in the Model Tender Documents |
|-----|-------------|--|

SECTION 3 - INSTALLATION

- | | | |
|-----|--------------|--|
| (a) | Section 3.2 | To update the link for the “Guide to Trench Excavations (Shoring Support and Drainage Measures)” in paragraph (ii) |
| (b) | Section 3.2 | To delete the words “Standard Drawing WSD 1.3 or” in the third bullet point of paragraph (ix) |
| (c) | Section 3.6 | To add “butt fusion joints” and “compression joints with end load resistance” as jointing methods of PE pipes in paragraph (iii) |
| (d) | Section 3.8 | To revise “exceeding DN600” to “of DN700 and above” to tally with the wordings in the Model Tender Documents |
| (e) | Section 3.10 | To include washout pipes in hydrostatic pressure tests |
| (f) | Section 3.14 | To replace the reference to Appendices 3.5 and 3.6 with Standard Drawings WSD 1.54 and 1.55 |

APPENDICES

- | | | |
|-----|--------------|------------------------|
| (a) | Appendix 3.5 | To delete the appendix |
| (b) | Appendix 3.6 | To delete the appendix |