


NOTES :

1. ALL DIMENSIONS ARE IN MILLIMETRES.
2. FOR DETAILS OF PRECAST CONCRETE UNITS REFER TO DRG. NO. WSD 1.7.
3. DETAILS OF D.A.V. CHAMBER SHOWN ON THIS DRAWING ARE ONLY APPLICABLE IN LOCATIONS WHERE THE EXPECTED GROUND WATER LEVELS ARE LOWER THAN THE CROWN OF THE MAINS.
4. GRADE OF IN-SITU CONCRETE SHALL BE 30/20D.
5. ALL STAINLESS STEEL FITTINGS SHALL BE IN GRADE 316.



PLAN

E	GENERAL REVISION	K.H. HO	3/2/21
D	RE-FORMATTED TO CSWP	W.K. CHIU	5/9/03
C	GENERAL REVISION	W.K. CHIU	20/9/00
B	REFERENCE TO C.I. COVER DELETED	W.K. CHIU	14/9/99
A	GENERAL REVISION	K.W. CHAN	3/9/96
REF.	REVISION	APPROVED	DATE

Cod Ref. : WSD0109-E.dwg

DOUBLE AIR VALVE CHAMBER



水務署
Water Supplies Department

APPROVED	G.C. LEE AD/NW	DRAWING NO. WSD 1.9E	CSWP
DATE	9/6/92		
SCALE	1 : 25		