# WATER SUPPLIES DEPARTMENT STANDARD SPECIFICATION E-81-03 INTEGRATOR

# 1. GENERAL

An integrator is an equipment which shall be used for totalising a 4-20 mA analogue signal (such as water flow) for monitoring and control purpose in water industry. The equipment shall consist of an analogue to pulse converter unit and two electromechanical or digital totalising counters. One counter shall be 6-digit and resettable while the other shall be 8-digit and non-resettable.

### 2. DESIGN

The equipment shall meet the following design requirements:

(a) Analogue to Pulse Converter Unit

Input signal : 4-20 mA

Maximum input resistance : 100 ohms

Output signal : 24V pulses, minimum duration 50 msec.

Pulse rate shall be directly proportional to

the input signal

Maximum output pulse rate : continuously adjustable between 0.02 and 5

pulses/sec

Maximum output load : 250 mA

Inaccuracy : less than 0.2% of span

Linearity : better than 0.1% of span

Clip-off level : with inputs less than 2% of full scale,

the output of the converter shall be

inhibited

Supply voltage effects : less than  $\pm 0.1\%$  of span for  $\pm 10\%$  change

in supply voltage

Operating temperature : 0-55 °C

- 2 - E-81-03 Oct. 2010

Temperature effects : less than  $\pm 0.01\%$  of span per °C

Relative humidity 5-95 %

Supply voltage : 220V 50 Hz

(b) Counters

Input : 24V DC pulses

Maximum counting rate : 25 pulses/sec

# 3. CONSTRUCTION

The converter unit shall be suitable for DIN rail-mounted inside a panel.

The counters shall be suitable for flush mounting on a panel front. The numerical figures shall be not less than 4 mm and the overall facia dimensions shall be 52 mm x 28 mm with panel cut-out dimensions of 48 mm x 24 mm.

Resetting of the 6-digit counter shall be by an integral push-button at the front of the counter. A locking device shall be provided to prevent accidental or unauthorised resetting of the counter.

### 4. EQUIPMENT PARTICULARS

The contractor should refer to the Particular Specification for the following particulars of the equipment:-

- (a) Actual signal (e.g. the flow rate) at full scale input.
- (b) Scale factor of counter display.
- (c) Output pulse rate at full scale input.
- (d) Choice of electromechanical or digital type totalising counters. Either of the counters can be supplied if not specified.