

WATER SUPPLIES DEPARTMENT
STANDARD SPECIFICATION E-86-32
CALORIMETRIC TYPE NO-FLOW SWITCH

1. GENERAL

The no-flow switch shall be incorporated in water piping system for initiation of tripping or alarming at the preset value.

2. DESIGN

The no-flow switch shall be of calorimetric type and it shall operate on the principle of thermal conductivity with a flow sensor for measuring temperature change.

3. CONSTRUCTION

Material of Sensor & Housing:	Stainless steel 316
Operating Voltage:	220V 50Hz or 24V DC
Output Contact Rating:	2A 220V 50Hz changeover type
Controller's Setting Range:	0.03 m/s – 1.5 m/s or otherwise specified in the particular specification
Degree of Protection of Switch Enclosure:	IP65
Pressure Rating of Sensor:	PN16 or otherwise specified in the particular specification
Mounting of Sensor:	Flange mounted for pump delivery system. Depth of insertion shall be not less than 12 mm and not greater than 100 mm from the inner wall of the pipe or the radius of the inner pipe, whichever is the less.