

**WATER SUPPLIES DEPARTMENT**  
**STANDARD SPECIFICATION E-88-05**  
**POWER SUPPLY EQUIPMENT FOR TELEMETRY SYSTEMS**

1 **GENERAL**

1.1 **Extent of Supply**

This Standard covers the provision of power supply equipment for use with telemetry systems.

In general, the equipment shall include the following :-

- (a) Battery of maintenance free sealed lead-acid cells
- (b) Battery charger with both float and boost charging facilities
- (c) Panel enclosure for both (a) and (b)
- (d) Interconnecting cables between (a) and (b)

1.2 **System Operation**

The system shall operate from a 220V 50 Hz single-phase supply. Unless otherwise specified, the output voltage of the battery supply shall be 24V d.c.

The equipment supplied shall include all sub-units and components to form a complete system. The equipment shall be suitable for operation from 0°C to 40°C with a relative humidity up to 98%.

2 **DESIGN**

2.1 **Battery Cells**

Battery cells shall be of maintenance-free sealed lead-acid type. Cell containers shall be made of moulded translucent plastic and resistant to impacts and corrosive attack by the electrolyte.

The battery capacity shall be capable of powering the required telemetry equipment continuously for 5 hours with a 20% safety margin taking into account all various derating factors. The minimum battery life at 20°C shall be 10 years for continuous float charging and 150 charge/discharge cycles.

The minimum battery capacity for service reservoir type installation shall be 30Ah.

## 2.2 Battery Charger

### 2.2.1 Performance

The battery charger shall be designed to be suitable for operation under harsh process plant environment in meeting with the relevant electromagnetic compatibility (EMC) and safety standards.

Battery chargers shall comprise a power supply transformer, float and boost charge control units and the accessories. All control circuitry shall be of solid-state.

The float charger shall be rated such that following a mains supply failure and a normal continuous discharge for 5 hours, the battery shall be replenished to 50% of its nominal ampere-hour capacity within a 5-hour charging period.

The boost charger shall be rated such that following the same discharge conditions, the battery shall be replenished to 75% of its nominal ampere-hour capacity within a 5-hour period.

The maximum voltage across the load output terminals shall be limited to the range of 110 to 112.5% of the nominal battery voltage.

The charger output voltage shall be maintained to within  $\pm 2\%$  of its nominal value for variations of  $\pm 10\%$  in the mains voltage,  $\pm 2\%$  in frequency, 0 to 100% in load and  $5^{\circ}\text{C}$  to  $40^{\circ}\text{C}$  in ambient temperature.

The boost charger shall be manually selectable and shall provide a constant voltage output in accordance with a manually adjustable setting. Automatic return of the booster charging to float charging is preferred after the charging is full or a preset time.

### 2.2.2 Facilities for Chargers

The following features shall be included in the chargers :-

#### (a) Protection

The charger shall be protected against the following abnormal situations :-

- (i) Output short-circuit/overcurrent
- (ii) Charger temperature high

#### (b) Alarms and Indications

The following alarms/indications shall be provided for the charger :-

- (i) Charger temperature high
- (ii) Output voltage high/low

(iii) Charger on

(iv) Mains on

One changeover volt-free contact shall be provided for the common alarms of item (i) and (ii) above.

(c) Control Devices and Instruments

The following shall be provided with the chargers :-

(i) Mains On/Off switch

(ii) Boost/Float charge selector switch

(iii) Ammeter, charger output

(iv) Voltmeter, load output

2.2.3 Design of Electronic Circuitry

Maintenance and fault finding on the equipment shall be facilitated by the provision of fault-locating routines, test points and indicators on the function boards, and by an assembly technique that allows rapid replacement of components or sub-assemblies.

3 CONSTRUCTION

3.1 Panel Enclosure

The enclosure shall be fabricated with mild steel of 1.5 mm thickness with separate compartments for both the battery and the charger suitable for wall-mounting. The entire enclosure surface shall be applied with chemical rust inhibitor, rust resisting primer coat and top coat to give good corrosion protection.

The panel shall be designed for natural ventilation with an ambient temperature of up to 45°C and a degree of protection of IP32 to IEC 60529.

The indicators, instruments and control switches detailed in Clause 2.2.2 shall be flush-mounted on the panel front.

Cable entry to the panels shall be through gland plates mounted at the bottom of the panels.

3.2 Battery Cells

The polarity of each terminal shall be clearly marked by engraving, stamping or pressing into the cell container top beside the terminal. The wording shall be permanent and the use of coloured washers around the terminals as the sole means of polarity identification shall not be accepted.

## 4 INSPECTION AND TESTING

### 4.1 Inspection and Testing in Manufacturer's Works – General

The completely assembled power supply equipment shall be inspected and tested in the telemetry equipment manufacturer's works with test reports submitted for approval before delivery of the equipment.

### 4.2 Test Requirements

The tests shall clearly demonstrate that the equipment fully complies with the performance detailed in this Standard and the Particular Specification.

The Contractor shall provide all test equipment and facilities necessary to perform these tests. Test equipment for calibration purposes shall have been calibrated and certified by a recognised calibration authority not earlier than 12 months prior to the test.

The minimum requirements for the tests are listed below :-

- (a) Demonstration of the manual adjustable range of charger output voltage under float and boost charge respectively.
- (b) Demonstration of the operation of all protective devices.
- (c) Operational checks of all alarms and indication facilities.

## 5 INFORMATION TO BE SUBMITTED WITH TENDER

### 5.1 Catalogues

Catalogues for the complete system and auxiliary equipment shall be submitted with the tender. Failure to provide sufficient information will result in disqualification of the tenderer's offer.

### 5.2 Performance Data

The technical schedule in the Particular Specification shall be completed by the tenderer and returned with the tender. Incomplete data may result in difficulty in assessment and subsequent disqualification of the tenderer's offer.