

Water Supplies Department
Water Quality Objectives of Salt Water for Flushing Supply
 水務署
 沖廁用鹹水水質指標

Parameter 參數	Unit 單位	Water Quality Objectives of Salt Water for Flushing Supply 沖廁用鹹水水質指標
Colour 色度	Hazen Unit	< 40
Turbidity 混濁度	NTU	< 20
Threshold Odour Number 氣味閾值	--	< 100
Ammoniacal Nitrogen 氨氮	mg/L 毫克/公升	< 1
Suspended Solids 懸浮物	mg/L 毫克/公升	< 20
Dissolved Oxygen 溶解氧	mg/L 毫克/公升	> 2
5-day Biochemical Oxygen Demand 五日生化需氧量	mg/L 毫克/公升	< 10
Synthetic Detergents 合成清潔劑	mg/L 毫克/公升	< 5
<i>Escherichia. coli</i> 埃希氏大腸桿菌	cfu/100 mL 菌落數/100 毫升	< 5 000

Note 註：

mg/L: milligram per liter

cfu: colony forming unit